



Legend

- 01 Location Numbers
- 01a Positive Asbestos Bulk Sample Location (16313-xx)
- 01a Negative Asbestos Bulk Sample Location (16313-xx)
- Pb01 Lead Bulk Sample Location (16313-Pb-xx)
- Asbestos-Containing Vinyl Floor Tiles & Mastic (Non-Friable)
- Asbestos-Containing Texture Finish (Friable)
- Area Not Investigated

Asbestos-containing vinyl floor tile mastic may be present in other location not identified on this drawing

All information relating to room size and location is approximate and for visual aid only. ECOH does not guarantee the drawing to be complete, absolute, accurate or current. The drawing should not be used by any party in lieu of obtaining architectural drawings.

Figure 6

Fifth Floor Plan

LOCATION:
255 Riverside Drive,
Windsor, Ontario

PROJECT:
Designated Substances Survey

CLIENT: Windsor Essex Community Housing Corporation		
PROJECT NUMBER: 16313	DATE: March 2016	DRW BY: MM
CAD FILE: FIG1-22 P16313 DSUB Bsmt-21	SCALE: Not to Scale	CHK BY: MB

