



Legend

- 01** Location Numbers
- 01a** Positive Asbestos Bulk Sample Location (16313-xx)
- 01a** Negative Asbestos Bulk Sample Location (16313-xx)
- Pb01** Lead Bulk Sample Location (16313-Pb-xx)
- Asbestos-Containing Vinyl Floor Tiles & Mastic (Non-Friable)
- Asbestos-Containing Texture Finish (Friable)
- Asbestos-Containing Ceiling Tiles (Non-Friable)
- Area Not Investigated

Asbestos-containing vinyl floor tile mastic may be present in other location not identified on this drawing

All information relating to room size and location is approximate and for visual aid only. ECOH does not guarantee the drawing to be complete, absolute, accurate or current. The drawing should not be used by any party in lieu of obtaining architectural drawings.

Figure 21

Twenty-First Floor Plan

LOCATION:
255 Riverside Drive,
Windsor, Ontario

PROJECT:
Designated Substances Survey

CLIENT: Windsor Essex Community Housing Corporation

PROJECT NUMBER: 16313 **DATE:** March 2016 **DRW BY:** MM

CAD FILE: FIG1-22 P16313 DSUB Bsmt-21 **SCALE:** Not to Scale **CHK BY:** MB