

Custom Summary Report

Client Name: Windsor -ESSEX Community Housing Corporation (CHC)							Building Address: 445 Glengarry Ave						
Development: Cameron Montrose							District: 1						
SYSTEM	MATERIAL NAME	MATERIAL IDENTIFICATION	MATERIAL DESCRIPTION	LOCATIONS	FRIABILITY	ACCESSIBILITY	TOTAL QUANTITY	UNITS	HAZAROUS CONTENT		PRIORITY	ESTIMATED COST	
									RESULTS	HAZARD			
Floor	Vinyl Floor Tiles	VFT1	12"x12" Brown with White Streaks	1312 ,1416 ,1419 ,1511 ,1512 ,1522	N	A	6150	SF	Chrysotile 4%	Confirmed Asbestos	Priority 3		
Floor	Vinyl Floor Tiles	VFT2	12"x12" Beige with Brown and Yellow Specks	10001 ,10002 ,1110 ,1116 ,1117 ,1121 ,1200 ,1207 ,1312 ,1402 ,1411	N	A	8300		Chrysotile 2%	Confirmed Asbestos	Priority 3		
Floor	Vinyl Floor Tiles	VFT3	12"x12" Off-White with Light and Dark Brown Specks	1126 ,1128 ,1200 ,1229 ,1300 ,1329 ,1400 ,1429 ,1500 ,1529 ,1600 ,1629	N	A	16400		Confirmed Asbestos	Confirmed Asbestos	Priority 3		
Floor	Vinyl Floor Tiles	VFT4	12"x12" Blue with Dark Blue and White Specks	1200 ,1300 ,1400 ,1500 ,1600	N	A	15900		None Detected	None Detected	Priority 4		
Floor	Vinyl Sheet Flooring	VSF1	Beige and Brown Square Pattern	1121 ,1207 ,1416 ,1512	N	A	3050	SF	Chrysotile 30%	Confirmed Asbestos	Priority 3		
Floor	Vinyl Sheet Flooring	VSF1	Beige and Brown Square Pattern	1511	N	E	950	SF	Chrysotile 30%	Confirmed Asbestos	Priority 2		
Floor	Vinyl Sheet Flooring	VSF1	Beige and Brown Square Pattern	1522	N	E	1150	SF	Chrysotile 30%	Confirmed Asbestos	Priority 3		
Floor	Vinyl Sheet Flooring	VSF2	Light and Dark Beige Speckled Pattern	1131 ,1231 ,1331 ,1431 ,1531 ,1631	N	A	300	SF	None Detected	None Detected	Priority 4		
Floor	Mastic	Mastic	Mastic under VFT	10001 ,10002 ,10003 ,1110 ,1116 ,1117 ,1121 ,1200 ,1207 ,1312 ,1402 ,1411 ,1416 ,1419 ,1511 ,1512 ,1522 ,1600	N	E	20350	SF	Chrysotile 2%	Confirmed Asbestos	Priority 3		
Floor	Concrete	N/A	Concrete	1125 ,1127	N	A	0		None Detected	None Detected	Priority 4		
Floor	Concrete	N/A	Concrete	10001 ,10002 ,10003 ,1100 ,1123 ,1129 ,1130 ,1223 ,1224 ,1225 ,1226 ,1227 ,1228 ,1230 ,1323 ,1324 ,1325 ,1326 ,1327 ,1328 ,1330 ,1423 ,1424 ,1425 ,1426 ,1427 ,1428 ,1430 ,1523 ,1524 ,1525 ,1526 ,1527 ,1528 ,1530 ,1623 ,1624 ,1625 ,1626 ,1627 ,1628 ,1630			5700		No Asbestos	No Asbestos			