

# Action Summary Report

Client Name: Windsor -ESSEX Community Housing Corporation (CHC)							Building Address: 1323 Tilston Ave				
Development: Bridgeview I							District: 2				
SYSTEM	MATERIAL NAME	MATERIAL IDENTIFICATION	MATERIAL DESCRIPTION	LOCATIONS	FRIABILITY	TOTAL QUANTITY	UNITS	HAZAROUS CONTENT		PRIORITY	ESTIMATED COST
								RESULTS	HAZARD		
Floor	Vinyl Floor Tiles	VFT1	12"x12" Beige with black veins	9127502 ,9127503 ,9127504	N	200	SF	Chrysotile 2%	Confirmed Asbestos	Priority 3	
Floor	Vinyl Floor Tiles	VFT3	9"x 9" Black with light brown streak	9130601	N	80	SF	Chrysotile 2%	Confirmed Asbestos	Priority 3	
Ducts	Heat Shield	N/A	Heat Shield	9133901 ,9118101 ,9230001	Y	4	SF	Chrysotile 60%	Confirmed Asbestos	Priority 1	
Ducts	Heat Shield	N/A	Heat Shield	9130601 ,9127701 ,997201 ,9101401	Y	18	SF	Chrysotile 60%	Confirmed Asbestos	Priority 3	

Client Name: Windsor –ESSEX Community Housing Corporation (CHC)						Building Address: Various Addresses					
Development: Bridgeview II						District: 2					
SYSTEM	MATERIAL NAME	MATERIAL IDENTIFICATION	MATERIAL DESCRIPTION	LOCATIONS	FRIABILITY	TOTAL QUANTITY	UNITS	HAZAROUS CONTENT		PRIORITY	ESTIMATED COST
								RESULTS	HAZARD		
Walls	Drywall and Joint Compound	N/A	Drywall and Joint Compound	10228501 ,10213402 ,10213403 ,10213404 ,10213405 ,10213406 ,10213407 ,10213408 ,10213409 ,10227602 ,10227603 ,10227604 ,10227605 ,10227606 ,10227607 ,10227608 ,10227609 ,10211002 ,10211003 ,10211004 ,10211005 ,10211006 ,10211007 ,10211008 ,10211009 ,10228002 ,10228003 ,10228004 ,10228005 ,10228006 ,10228007 ,10228008 ,10228009 ,10227402 ,10227403 ,10227404 ,10227405 ,10227406 ,10227407 ,10227408 ,10227409 ,10228502 ,10228503 ,10228504 ,10228505 ,10228506 ,10228507 ,10228508 ,10228509	N	16020	%	Chrysotile 1%	Confirmed Asbestos	Priority 3	
Ceiling	Drywall and Joint Compound	N/A	Drywall and Joint Compound	10213402 ,10213403 ,10213405 ,10213406 ,10213407 ,10213408 ,10213409 ,10227602 ,10227603 ,10227605 ,10227606 ,10227607 ,10227608 ,10227609 ,10211002 ,10211003 ,10211005 ,10211006 ,10211007 ,10211008 ,10211009 ,10228002 ,10228003 ,10228005 ,10228006 ,10228007 ,10228008 ,10228009 ,10227402 ,10227403 ,10227406 ,10227407 ,10227408 ,10227409 ,10228502 ,10228503 ,10228505 ,10228506 ,10228507 ,10228508 ,10228509	N	5090	SF	Chrysotile 1%	Confirmed Asbestos	Priority 3	