

Regulated Design Record				
Project Address:				
Project Title:				
Consent No:			Body Corporate Reg No:	
Drawing Title:			Drawing No:	
Rev	Date	Description	DP Full Name	Reg No


GENERAL NOTE:

1. ALL KITCHEN EXHAUST DUCTS ARE TO BE INSTALLED AT 0.05% GRADE RAISE TO THE RISER.
2. ALL KITCHEN EXHAUST DUCTWORK TO BE MADE OF STAINLESS STEEL OF MIN 0.9mm THICKNESS.
3. ALL SLAB FIRE DAMPER FOR THE FIRST 2M ABOVE THE FIRE DAMPER REQUIRE TO BE INSULATED WITH THE ROCKWOOL MATERIAL AND WITH THE PURFOGATED METAL FOR THE DUCTWORK.



FOR CONTINUATION,
REFER TO DRAWING NO. TB-10-1005-08

Rev	Date	By	Revision Notes
INTERNAL CHECKED BY:			CLIENT CHECKED BY: DATE:



PROJECT INFORMATION

DRAWING TITLE:

**GROUND MEZZ MECH
OVERALL FLOOR PLAN
DUCTWORK**

SUITABILITY: **ISSUED FOR CONSTRUCTION**

DRAWING NUMBER

ION
REV: