

[illegible]

KEY PLAN

GENERAL NOTE

1. Generally all supply and return air ducts are internally or externally insulated 50mm thermal as shown on plans and/or sections.
2. Generally all acoustic insulation linings are 50mm with perforated foil. Refer to plans and/or section for insulation types.
3. Give best restriction fishing angles to all wall openings for one or both sides of opening as necessary to support that where visible, in visible on one side one flanging, two sides two flangings.
4. Allow for appropriate size A/P at all access for inspection if not shown on drawing.
5. Provide seismic restraint to all MEDS systems as necessary to project code requirement.
6. Allow turning vanes to all short rad and/or 90° bends if shown or not shown on drawing.
7. Allow all support brackets for "FAN, COND, etc" where shown or not shown on drawing and expansion as required. Refer to working schematic for location.
8. All Mechanical Ductwork pipework exposed to view shall be painted color selection Accordant to Australian Standard and Approved by the Council in Blue, galvanized steel or stainless steel, below floor concealed areas and carpark area.
9. All Temperature sensor has to be installed 500mm ceiling.

[illegible]

AB		AS BUILT	
	03	ISSUED FOR INTERNAL QA-CONSTRUCTION	
		UNIT REFERENCE DIMENSIONS ADDED	
	02	ISSUED FOR INTERNAL QA-CONSTRUCTION	
	01	ISSUED FOR INTERNAL QA-CONSTRUCTION	
A		ISSUED FOR APPROVAL	

ISSUED	REV
CAD FILE NAME	

CLIENT

BUILDE

PROJECT

MECHANICAL SERVICES

TITLE
MECHANICAL SERVICES
LEVEL 03 LAYOUT
PIPING WORK

APP. PM	DATE	DSGN CHECK	DATE
---------	------	------------	------

DRAWN	DATE	DRG CHECK	DATE
-------	------	-----------	------

PROJECT NUMBER SCALE 001

DRAWING NUMBER	ISSUE
----------------	-------

AR

NOTE :
ALL DIMENSIONS ARE TAKEN FROM ST RL 76400

