

NOTE:

SIZE OF ACCESS PANELS DEPEND ON SIZE OF DUCT

DUCT STEAM & HEATING COIL INSTALLATION



ELECTRIC DUCT HEATER INSTALLATION



HEATER (kw)	DISTANCE X (mm)
1-2	200
2-8	300
8-10	450
10 & ABOVE	600

DUCT MOUNTED ELECTRIC HEATER SAFETY SWITCH LOCATIONS



VOLUME CONTROL DAMPER INSTALLATION



VAV BOX INSTALLATION DETAIL



GRILLE & S/A PLENUM (13mm FOAM INSULATION) DETAIL

NOTE:

BULKHEAD FRAMING IS TO BE CONSTRUCTED TO ENABLE GRILLE TO BE LOCATED IN THE DESIRED LOCATION IN THE DESIRED POSITION. BOTH VERTICALLY AND HORIZONTALLY





DIRECTION OF HUMIDIFIER STEAM DISCHARGE





DETAIL OF ROOF MOUNTED FAN 80 kg AND OVER

THIS DRAWING PREPARED IN CONJUNCTION WITH:

XXX Revision

Discipline	Drg No	Revisions

KEY PLAN



ISSUED	REV	DESCRIPTION	DATE	DRAWN

CAD FILE NAME:

ARCHITECT

CLIENT

BUILDER

PROJECT

OES SAMPLE

Enter address here

MECHANICAL SERVICES

TITLE

MECHANICAL SERVICES DETAIL SHEET 03

APP.PM	DATE	DSGN CHECK	DATE
Approver		Designer	
DRAWN	DATE	DRG CHECK	DATE
Author		Checker	

PROJECT NUMBER: -

SCALE@A1: NTS

DRAWING NUMBER: MES-XXXX-00-004

ISSUE