

[illegible]

KEY PLAN

GENERAL NOTE:

1. ALL OPEN END DUCT WORK MUST BE COVER WITH PLASTIC TO PREVENT DUST ENTERING IN THE SYSTEM AFTER RELOCATION OR MODIFYING THE DUCT WORK.
2. ALL GRILLE AND FLEX. DUCT NEED TO BE STORE IN A SECURE PLACE ON SITE - SUBJECT TO REVIEW AND APPROVAL FROM PROJECT MANAGER/ENGINEER/CONSULTANT FOR REUSE.
3. ALL TEMP. SENSOR SHOULD BE ROLLED UP AND SECURE WITH A TAPE ON VAV ONCE DISMANTAL OR RELOCATED.

R  **FOR RELOCATION**

INTERFACE LINE

ORIGINAL POSITION OF DUCT NEED TO BE RELOCATED

NEW POSITION OF RELOCATED DUCT MIGHT BE NEED THE ALTERNATION

	EXISTING DUCT WORK NOT GOING TO CHANGE
--	--

DEMOLITION DUCT WORK

[illegible]

A		ISSUED FOR APPROVAL		OES
	01	ISSUED FOR INTERNAL REVIEW		OES
Issued	Rev	Description	Date	Drawn

CAD FILE NAME

ARCHITECT

CLIENT

BUILDE

PROJECT

MECHANICAL SERVICES

TITLE

MECHANICAL SERVICES
DEMOLITION PLAN
LEVEL 04 SOUTH LAYOUT

APP.PM	DATE	DSGN CHECK	DATE
--------	------	------------	------

DRAWN	DATE	DRG CHECK	DATE
-------	------	-----------	------

PROJECT NUMBER SCALE@81

DRAWING NUMBER	ISSUE
----------------	-------

