

WORK COMPLETION CERTIFICATE for DC Earthing				
SI. No	Check List	Value 1	Value 2	Value 3
01	BA Name	ASANSOL		
02	OA Name	ASANSOL		
03	Site Name / Id	ACHRA	ACHA01	
04	Site Incharge L1	GOURANGA GUIN	JTO	9434239000
05	Site Incharge L2	ASHOK BOSE	SDE	9434715141
06	Vendor	True Power Limited		
80	Initial Earth Value in Ohms (as per DIA or BTS info value which ever is greater)	2.45		
09	Permission to access the site granted by	L2		
09	Initial Earth value in Ohms measured by Vendor before commencement of any job	.5	27/01/2024 10:47	
	Permission to undertake minor rectification granted by	L1	Υ	
10	Minor Rectification of Existing Earthing done by vendor	Υ		
11	Earth value in Ohms after Initial Rectification	1	27/01/2024 12:35	
	Permission to undertake New Earth granted by	L2	Υ	
12	New Chemical Earthing done	Υ		
13	If Chemical Earthing Done, Number of Electrodes used	2		
14	New Plate Earthing Done	N		
15	Final Earth value in Ohms after completion of all Job	1		

THIS IS TO CERTIFY THAT

The above mentioned work has been carried out as per approved tender agreement and specification under the supervision < Site Incharge Name L1 or L2>

> (Sign) (Sign) Vendor L1/ L2 Incharge