

Outlook

From	david.fourie@infrastructure.ops.keystonebank.co.za
To	payments.ops@keystonebank.co.za, fraud.ops@keystonebank.co.za
Sent	Thu, 14 Feb 2019 14:24:00 -0000

Load shedding / rail impact - Eskom implements Stage 4 load shedding

Ops,

Eskom implements Stage 4 load shedding (2019-02-13) is affecting UPS runtime at Joburg DC2. Observed 2 bank timeout failures on loan payments this month – likely correlated.

ATM and POS decline rates are elevated in multichannel (see fraud dashboard). Failover to CPT active.

David Fourie
Infrastructure