



中国认可
国际互认
检测
TESTING
CNAS L0685

EMC TEST CERTIFICATE

No.202510666

Client: Beijing InHand Networks Technology Co., Ltd.

Sample Type: ISM5012D

Sample Name: Industrial Ethernet Switch

Test Report No.:JW251039E-EMC

Test Category:Type test

Test Items:

No	Standards		Verdict
1	Radiated emission test	IEC 61000-6-4:2018 IEC 61850-3:2013	Pass
2	Conducted emission test for auxiliary power supply port	IEC 61000-6-4:2018 IEC 61850-3:2013	Pass
3	Conducted emission test for wired network port	IEC 61000-6-4:2018 IEC 61850-3:2013	Pass
4	Radiated electromagnetic field immunity test	IEC 61000-6-2:2016 IEC 61000-6-5:2015 IEC 61850-3:2013	Pass
5	Electrostatic discharge immunity test	IEC 61000-6-2:2016 IEC 61000-6-5:2015 IEC 61850-3:2013	Pass
6	Conducted immunity test	IEC 61000-6-2:2016 IEC 61000-6-5:2015 IEC 61850-3:2013	Pass
7	Electrical fast transient/burst immunity test	IEC 61000-6-2:2016 IEC 61000-6-5:2015 IEC 61850-3:2013	Pass
8	Damped oscillatory wave immunity test	IEC 61000-6-5:2015 IEC 61850-3:2013	Pass
9	Surge immunity test	IEC 61000-6-2:2016 IEC 61000-6-5:2015 IEC 61850-3:2013	Pass
10	Power frequency magnetic field immunity test	IEC 61000-6-2:2016 IEC 61000-6-5:2015 IEC 61850-3:2013	Pass
11	0Hz - 150kHz common mode conducted immunity test	IEC 61000-6-5:2015 IEC 61850-3:2013	Pass
12	Voltage dips and short interruptions on d.c. input power port immunity test	IEC 61000-6-5:2015 IEC 61850-3:2013	Pass
13	Ripple on d.c. input power port immunity test	IEC 61000-6-5:2015 IEC 61850-3:2013	Pass

Issued by:

Xuchang KETOP Testing Research Institute Co.,Ltd.

National Quality Inspection & Testing Center For Relay Protection And Automation Equipment

May 15, 2025