


Vector Network Analyzer Fundamentals

POSTER



Vector Network Analyzer Fundamentals



Types of Measurement Error

WARNING: To reduce errors that affect measurement results, it is important to calibrate a VNA setup regularly. Calibration reduces the impact of systematic and drift errors.

SYSTEMATIC ERROR	RANDOM ERROR	DRIFT ERROR
<ul style="list-style-type: none">Imperfections in the test equipment or in the test setupTypically predictableCan be easily factored out by a user calibrationExamples that occur across the frequency range:<ul style="list-style-type: none">Output power variationsRipples in the VNA receiver's frequency responsePower loss of RF cables that connect the DUT to the VNA	<ul style="list-style-type: none">Error caused by noise emitted from the test equipment or test setup that varies with timeDetermines the degree of accuracy that can be achieved in your measurementCannot be factored out by a user calibrationExamples include:<ul style="list-style-type: none">Trace noise	<ul style="list-style-type: none">Measurement drift and variances that occur over time in test equipment and test setup after a user calibrationThe amount that the test setup drifts over time determines how often your test setup needs to be recalibratedExamples include:<ul style="list-style-type: none">Temperature changesHumidity changesMechanical movement of the setup

Understanding VNA Calibration

Factory Calibration

- Covers up to the Port 1 and Port 2 connectors
- Ensures output signals meet specs and input signals will be represented accurately

User Calibration

- Factors out the effects of cables, adaptors, and most things used in the connection of the DUT
- Allows for exact measurement of the DUT performance alone

Calibration Methods

Response	2-port One Path	2-port Two Path	Electronic
<p>S11, S21, S12, S22</p>	<p>S11, S21</p>	<p>S11, S21, S12, S22</p>	<p>S11, S21, S12, S22</p>
<ul style="list-style-type: none">Very simpleVery few connectionsLess accurateInexpensive	<ul style="list-style-type: none">SimpleFew connectionsModerately accurateLimited S-parameters	<ul style="list-style-type: none">ComplexMany connectionsHighly accurateFull S-parameters	<ul style="list-style-type: none">Very simpleVery few connectionsHighly accurateExpensive

Basic VNA Operation

A VNA contains both a source, used to generate a known stimulus signal, and a set of receivers, used to determine changes to this stimulus caused by the device-under-test or DUT. This illustration highlights the basic operation of a VNA. For the sake of simplicity, it shows the source coming from Port 1, but most VNAs today are multipath instruments and can provide the stimulus signal to either port.

S-Parameter Basics

S-Parameter Definition: Scattering parameters or S-parameters describe the electrical properties and performance of RF electrical components or networks of components when undergoing various steady state electrical signal stimuli. They are unitless complex numbers, having both magnitude and phase, and are related to familiar measurements such as gain, loss, and reflection coefficient.

Outside View

Inside VNA View

S-Parameter Theory View

Forward: $S_{11} = \frac{\text{Reflected}}{\text{Incident}} = \frac{b_1}{a_1} \Big|_{a_2=0}$

Reverse: $S_{22} = \frac{\text{Reflected}}{\text{Incident}} = \frac{b_2}{a_2} \Big|_{a_1=0}$

Transmission: $S_{21} = \frac{\text{Transmitted}}{\text{Incident}} = \frac{b_2}{a_1} \Big|_{a_2=0}$

Reverse: $S_{12} = \frac{\text{Transmitted}}{\text{Incident}} = \frac{b_1}{a_2} \Big|_{a_1=0}$

For more information on S-parameters go to tek.com/VNAprimer

Smith Chart 101

The Smith chart is a very useful tool used to determine complex impedances and admittances of RF circuits. Most network analyzers can automatically display the Smith chart, plot measured data on it, and provide adjustable markers to show the calculated impedance.

Impedance ($Z = R + jX$)

Admittance ($Y = G + jB$)

Impedance Smith Chart

- The circles touching the right corner are constant-resistance circles.
- The curves stretching from the right corner to the outer edges of the impedance Smith chart are constant-reactance curves.
- The center of the circle is the Z_0 point. In most cases, $Z_0 = 50$ ohms. This is also the 20-millisiemens (mS) point.

Admittance Smith Chart

- The circles in the Smith chart that touch the left corner are constant-conductance circles.
- The curves stretching from the left corner of the Smith chart to the outer edges of the admittance Smith chart are constant-susceptance curves.

Common S-Parameter Names

Forward reflection coefficient <ul style="list-style-type: none">Input return lossInput matchVSWR <p>S11</p>	Forward transmission coefficient <ul style="list-style-type: none">GainLoss <p>S21</p>
Reverse transmission coefficient <ul style="list-style-type: none">Reverse isolation <p>S12</p>	Reverse reflection coefficient <ul style="list-style-type: none">Output return lossOutput matchVSWR <p>S22</p>

Benchtop performance, at a surprising price.

The TTR500 Series Vector Network Analyzer rivals the leading benchtop competition, at 40% lower cost and one-seventh the size and weight! It has:

- 100 kHz up to 6 GHz frequency range
- >122 dB dynamic range
- <0.008 dBrms trace noise
- 50 to +7 dBm output power
- Bias Tee: 0 to ± 24 V and 0 to 200 mA

All, backed by Tektronix legendary service, support and quality.

Learn more at: tek.com/TTR500



Tektronix

Contact Information:

Australia 1 800 709 465
Austria 00800 2255 4835
Balkans, Israel, South Africa and other ISE Countries +41 52 675 3777
Belgium 00800 2255 4835
Brazil +55 (11) 3759 7627
Canada 1 800 833 9200
Central East Europe / Baltics +41 52 675 3777
Central Europe / Greece +41 52 675 3777
Denmark +45 80 88 1401
Finland +41 52 675 3777
France 00800 2255 4835
Germany 00800 2255 4835
Hong Kong 400 820 5835
India 000 800 650 1835
Indonesia 007 803 601 5249
Italy 00800 2255 4835
Japan 81 (3) 6714 3010
Luxembourg +41 52 675 3777
Malaysia 1 800 22 55835
Mexico, Central/South America and Caribbean 52 (55) 56 04 50 90
Middle East, Asia, and North Africa +41 52 675 3777
The Netherlands 00800 2255 4835
New Zealand 0800 800 238
Norway 800 16098
People's Republic of China 400 820 5835
Philippines 1 800 1601 0077
Poland +41 52 675 3777
Portugal 80 08 12370
Republic of Korea +82 2 6917 5000
Russia / CIS +7 (495) 6647564
Singapore 800 6011 473
South Africa +41 52 675 3777
Spain 00800 2255 4835
Sweden 00800 2255 4835
Switzerland 00800 2255 4835
Taiwan 886 (2) 2656 6688
Thailand 1 800 011 931
United Kingdom / Ireland 00800 2255 4835
USA 1 800 833 9200
Vietnam 12060128

Rev. 020916

Find more valuable resources at TEK.COM

Copyright © 2017, Tektronix. All rights reserved. Tektronix products are covered by U.S. and foreign patents, issued and pending. Information in this publication supersedes that in all previously published material. Specification and price change privileges reserved. TEKTRONIX and TEK are registered trademarks of Tektronix, Inc. All other trade names referenced are the service marks, trademarks or registered trademarks of their respective companies.

03/17 EA 2D-61077-0

