



Office of
EXECUTIVE ENGINEER, NERCHOWK DIVISION
Himachal Pradesh Public Works Department Nerchowk
Ph. 01905-243262, E-mail eepwd-nerchowk-hp@gov.in

No.PW-NCD-CB-WA/Building Safety/2026-27-1282-83. Dated:- 16/5/2026

To

The Principal,
Cambridge International School,
Lunapani, Distt. Mandi H.P.

Subject: - Regarding Building Safety Certificate.

In this connection, it is intimated that the building namely Cambridge International School Lunapani, Tehsil Balh, Distt. Mandi (H.P.) inspected by the Assistant Engineer, Chakkar Sub-Division, HPPWD Nerchowk and seen that this school is three storey building. This department neither supervised above building during construction at any stage nor foundation depth, quality of material used & cement concrete ratio used known/ checked. Moreover, no detailed structural analysis and drawings in seismic and non-seismic conditions are available to check the safety of building. However, as per submitted architectural drawings and on visual inspection, the building seems to be safe in normal condition to run the school for the academic year **2026-27** with the following terms and conditions:-

1. This certificate stands to be cancelled if any additional/alteration to school building as per the architectural drawing submitted as above are made or any other load is increased on building.
2. This department holds no responsibility regarding safety of building during natural calamity i.e. earthquake, cloud burst, floods, unequal settlement etc.
3. The maintenance of the building is to be carried out properly.

**Executive Engineer,
HPPWD Division Nerchowk,
Distt. Mandi (H.P.)**

Copy to the Assistant Engineer, Chakkar Sub-Division
HPPWD Nerchowk w.r.t his office letter No. 256-57 dated 14-05-2026 for
information.

**Executive Engineer,
HPPWD Division Nerchowk,
Distt. Mandi (H.P.)**