

HIMACHAL PRADESH JAL SHAKTI VIBHAG

SUB-DIVISIONAL LEVEL LABORATORY, BAGGI

Lab. Ref. No.

B-6-C319

REPORT ON PHYSICAL CHEMICAL & BACTERIOLOGICAL EXAMINATION OF WATER SAMPLE

Sender

AENO II Baggi

Division

Sub-Division

Section

Baggi
Private
Sample

Panchayat

Nagehala
Mandi

Village

Lunapani
Balh

Habitation

Lunapani

District

(Water samples collected and forwarded by the sender)

Name of scheme and Location of source

Cambridge International School

Type of Source

Basemell

Place of collection

at source

Date and Time of Collection

28/03/2026 at 10:50 AM

Date and Time of Collection at Laboratory

28/03/2026 at 12:15 PM

Nature of water : 1. Raw Water 2. Treated/Distribution Water 3. Hand Pump 4. Tube Well

Limits : Based upon BIS 10500-2012

(A) PHYSICAL TESTS

S.No.	Parameter	Unit	Acceptable Limit	Cause of Rejection	Result
1.	Temperature	*C	-	-	26°C
2.	Turbidity	NTU	1	5	0.41
3.	Colour	Hazen Units	5	15	3CU
4.	Odour	-	Agreeable	Agreeable	Agreeable
5.	Taste	-	Agreeable	Agreeable	Agreeable
6.	pH	-	6.5-8.5	No Relaxtion	6.74

(B) CHEMICAL TESTS

S.No.	Parameter	Unit	Acceptable Limit	Cause of Rejection	Result
1.	TDS	Mg/l	500	2000	308
2.	Residual Chlorine	Mg/l	0.2 to 0.5	1.0	0
3.	Total Hardness	Mg/l	200	600	180
4.	Total Alkalinity	Mg/l	200	600	198
5.	Chloride	Mg/l	250	1000	80.18
6.	SULPHATE	Mg/l	200	400	
7.	Nitrates	Mg/l	45	No Relaxation	
8.	Iron	Mg/l	0.3	1.0	
9.	Fluorides	Mg/l	1.0	1.5	
10.	Manganese	Mg/l	0.1	0.3	
11.	Arsenic*	Mg/l	0.01	0.05	0
12.	Magnisium	Mg/l	30	100	87.59
13.	Calcium	Mg/l	75	200	89.2

(C) BACTERIOLOGICAL TESTS

S.No.	Parameter	Unit	Acceptable Limit	Cause of Rejection	Result
1.	Total Coll forms	MPN/100 ml	Nil	Nil	Nil
2.	E-Coll	MPN/100 ml	Nil	Nil	-

Note : *Indicate Discrete Sampling. Water quality monitoring to be continued only if these are traced in drinking water sources.

Remark: Water sample conforms to IS Code IS 10500-2012 as per water sample tested above.

Assistant Chemist

Jal Shakti Sub Division No.II

Baggi

Assistant Engineer

Jal Shakti Sub Division No.II

Baggi