

## Indian Standard

### DRINKING WATER · SPECIFICATION

(Second Revision)

#### 1 SCOPE

This standard prescribes the requirements and the methods of sampling and test for drinking water.

#### 2 COMPLIANCE REQUIREMENTS

Drinking water shall be safe, clear, odorless, and free from pathogenic organisms and toxic chemicals.

#### 4 QUALITY REQUIREMENTS

Clause 4.1 Organoleptic and Physical Parameters (Table 1)

Drinking water shall conform to physical and chemical requirements specified below:

1. Total Dissolved Solids (TDS): Acceptable limit 500 mg/l; Permissible limit in absence of alternate source 2000 mg/l.
2. pH value: Acceptable limit 6.5 to 8.5; No relaxation.
3. Turbidity: Acceptable limit 1 NTU; Permissible limit 5 NTU.
4. Total Hardness (as CaCO<sub>3</sub>): Acceptable limit 200 mg/l; Permissible limit 600 mg/l.
5. Fluoride (as F): Acceptable limit 1.0 mg/l; Permissible limit 1.5 mg/l.
6. Chlorides (as Cl): Acceptable limit 250 mg/l; Permissible limit 1000 mg/l.
7. Iron (as Fe): Acceptable limit 0.3 mg/l; No relaxation.