



ENVIRONMENTAL LABORATORY

(UNIT OF MINERAL ENGINEERING SERVICES LLP)

Recognised by BIS, FSSAI, 180:45001:2018 Certified Laboratory

Recognised by MoEF&CC(CPCB) under E(P) Act 1986 recognition valid upto 23.05.2028

TEST REPORT

Name of the Client	: M/S. Birla Open Minds International School SLN Educational And Charitable Trust
Location of Sample	: School Premises, Opposite Sanganakal Hill Sirivara, Ballari, Ballari (Dt), Karnataka
Date of Sample Collection	: 29.11.2025
Date of Sample Receipt	: 29.11.2025
Nature of Sample	: RO Treated Water (Filter water)
Particulars of Sample Collected	: Drinking water
Date of Report	: 02.12.2025
Reference (IS code)	: IS 10500 (Amandment . 4 : 2021) Drinking water standards

Sl. No	Parameters	Test Method	Units	Results	Acceptable Limit
1	Colour	IS:3025 (p- 4)	Hazen Units	1	5
2	Odour	IS:3025 (p-5)	-	Agreeable	Agreeable
3	pH	IS:3025 (p-11)	0--14	6.67	6.5 to 8.5
4	Taste	IS:3025 (p-8)	-	Agreeable	Agreeable
5	Turbidity	IS:3025 (p-10)	NTU	0.4	1
6	Total Dissolved Solids (TDS)	IS:3025 (p-16)	mg/l	108	500
7	Calcium as Ca	IS:3025 (p- 40)	mg/l	9.6	75
8	Chlorides as Cl	IS:3025 (p-32)	mg/l	25	250
9	Fluoride as F	IS:3025 (p- 60)	mg/l	< 0.1	1.0
10	Iron as Fe	IS:3025 (p-53)	mg/l	< 0.05	0.3
11	Magnesium as Mg	IS:3025 (p- 46)	mg/l	8.7	30
12	Nitrates as NO ₃	IS:3025 (part 34)/APHA	mg/l	2.4	45
13	Sulphates as SO ₄	IS:3025 (p-24)	mg/l	42	200
14	Total Alkalinity as CaCO ₃	IS:3025 (p- 23)	mg/l	12	200
15	Total Hardness as CaCO ₃	IS:3025 (p21)	mg/l	60	200

Bacteriological Tests

16	Total Ciliform /100ml	IS:1622-1981	cfu/100 ml	Absent	Absent
17	E-Coli (cfu/100ml)	IS:5887 (p- 1)	cfu/100 ml	Absent	Absent

Note : 1. NTU - Nephelometric Turbidity unit

2. Sample is Fit for Drinking as per the above analysed test results

3. Sample was not drawn by Environmental Laboratory, Ballari.

4. This certificate is valid for a period of one year from the date of issue



Analyst / Authorised Signatory

