

No: KFE/B/S/16/2026

FORM B

{See section 3 (3) and rule 4 (2)}

CERTIFICATE

Certified that I/We have carried out inspection of the Fire Prevention and Life Safety Measures installed in the following building or premises, namely:

ABHIRUCHI EASTATES

SITE – “ABHIRUCHI GURUKUL SCHOOL” S.NO.24/1 (PART), DHAYARI, PUNE.

I/We further certify that these installation in the above-mentioned buildings are maintained in good repair and efficient conditions during the **period from – 01/01/2026 To - 30/06/2026**, as required under the provision of the Maharashtra Fire Prevention and Life Safety Measures Act,2006 (Mah-III of 2007). The details of the inspection and maintenance of installation carried out by me /us are mentioned as below, herewith.

Place: Pune

Date: 16/09/2026

KUBER FIRE ENGINEERS

LISENCE NO. MFS / LA / RF-80(562-old)/ RD- 74(532-old)/ P-06

SANTOSH
BALU
ZORE

Digitally signed
by SANTOSH
BALU ZORE
Date: 2026.09.16
17:54:32 +05'30'

Authorized Signatory
Mr. Santosh Zore

To,

The Divisional Fire Officer,

Fire and General Safety Measures implied for proposed project will be according to National Building Code of India. For Factory building on-

ABHIRUCHI EASTATES

SITE – “ABHIRUCHI GURUKUL SCHOOL” S.NO.24/1 (PART), DHAYARI, PUNE.

Details of Fire Safety Equipment Installed:

Sr. No	DESCRIPTION	SIZE	QTY/UNIT	MAKE
1	G.I C CLASS PIPE	150 NB	594 MTR	APOLLO
		100 NB	48 MTR	
		80 NB	78 MTR	
		65 NB	42 MTR	
		50 NB	108 MTR	
		40NB	822 MTR	
		32 NB	114 MTR	
		25 NB	516 MTR	
2	BOOSTER PUMP	(900 LPM)	2 NOS	KIRLOSKAR
3	ELECTRICAL STARTER	-	2 NOS	STD
4	BUTTERFLY VALVE	150 MM DIA	5 NOS	KARTAR/SIR
		100 MM DIA	11 NOS	
		50 MM DIA	7 NOS	
5	NON-RETURN VALVE	100 MM DIA	4 NOS	KARTAR/SIR
		80 MM DIA	1 NOS	
6	HYDRANT VALVE	63MM SINGLE	29 NOS	ARMOUR
7	FIRE HOSE BOX-	SINGLE	29 NOS	STD
8	HOSE PIPE	15 MTR	29 NOS	ARMOUR
9	BRANCH PIPE	SS ISI MARK	29 NOS	ARMOUR
10	HOSE REEL DRUM WITH BV	ISI MAKE	20 NOS	GRAP
11	TWO WAY INLET	ISI MAKE	4 NOS	SWATI
12	FOUR WAY INLET	ISI MAKE	1 NOS	SWATI
13	FIRE EXTINGUSHER	ABC- 4 KG	20 NOS	SAFTYONE
		CO2- 4.5 KG	4 NOS	SAFTYONE

14	FIRE BUCKET	SET	4 NOS	STD
15	SPRINKLERS	PENDENT	229 NOS	OMEX
16	FIRE RESISTANT DOOR	SINGLE/DOUBLE	20 SET	CBRI APPROVED
17	FIRE DETECTION SYSTEM-	PROVIDED	1SET	RAVEL
18	MAIN PUMP	1620 LPM	1 NOS	KIRLOSKAR
19	DIESEL PUMP	1680 LPM	1 NOS	
20	JOCKY PUMP	180 LPM	1 NOS	

All the mentioned fire safety measures have been inspected, tested, and found to be operational as per safety norms. The fire protection system is **maintained and functional** to ensure the safety of occupants.

This certificate is issued in compliance with the Maharashtra Fire Prevention & Life Safety Measures Act, 2006, and remains valid for **six months** from the date of issue.