



Post Box :- 520
Telephone :- 25501000

PUNE MUNICIPAL CORPORATION

SHIVAJINAGAR, PUNE – 5.

OFFICE OF THE CHIEF FIRE OFFICER

CENTRAL FIRE STATION,

MAHATMA PHULE PETH,

PUNE – 411 042. Date :-

Outward No. 2450

Date :- 16/09/2025

Appendix XII

FIRE SAFETY CERTIFICATE

Certified that the M/s. Helios International School, on S. No. 7/1B/27B, Sun City Road, Wadgaon Bk., Tal. Haveli, Dist. Pune. comprised of Ground Floor + 6 Floors have complied with the fire prevention and fire safety requirements in accordance with the rule i.e. Maharashtra Fire Prevention & Life Safety Measure Act 2006 and verified by us on dated 16/09/2025 in the presence of Ms. Divya Ray (Puri) principal in charge and that the building – premises is fit for educational occupancy in the view of fire and life safety with effect from the date of this letter up to 15/09/2026 in accordance with rule and subject to compliance if the conditions laid in the Maharashtra Fire Prevention & Life Safety Measure Act 2006.

Issued on 16.09.2025 at Pune by



Prabhakar S. Umratkar
16/09/2025
(Prabhakar S. Umratkar)

Station Duty Officer
Pune Fire Brigade
Pune Municipal Corporation

To

M/s. Helios International School, on S. No. 7/1B/27B, Sun City Road, Wadgaon Bk., Tal. Haveli,
Dist. Pune

SHREE ATHARVA ENTERPRISES

(Govt Approved License Agency)

SAE/2026-27/012

Date: - 15.07.2026

FORM B

[SEE SECTION 3(3) AND RULE 1(2)]

SIX MONTHLY CERTIFICATES TO BE GIVEN IN EVERY JANUARY AND JULY

BY THE OWNER OR THE OCCUPIER FOR COMPLIANCE OF THE FIRE

PREVENTION AND LIFE SAFETY MEASURES

CERTIFICATE

Certified that I/We have carried out inspection of the Fire Prevention and Life Safety Measures installed in the following building or premises, namely*:-

**Helios International School, Sr No – 7/1B/27B, Wadgaon Burduk, Pune.
(For Building Height 27.45 Mtrs & Total Built Up Area -7203.94 Sq. Mtrs only)**

I/We further certify that these installations in the above mentioned buildings are maintained in good repair and efficient conditions during the period **01.01.2026 to 30.06.2026** as required under the provisions of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah. III of 2007). The details of the inspection of installations carried out by me/us are mentioned in the report appended herewith.

Place: Pune

Signature and Address of the License Agency

GANESH
LAXMAN
NALAGE

Digitally signed by
GANESH LAXMAN
NALAGE
Date: 2026.07.15
16:10:59 +05'30'

Date: 15.07.2026

License No: MFS / LA / RF-317 / RD-306

SHREE ATHARVA ENTERPRISES

(Govt Approved License Agency)

Annexure to Form B – Following List of Material are tested successfully –

NO	PARTICULARS	REMARKS
1	Hydrant Valve – 20 Nos, Single Door Hose Box – 20 Nos, S. S. Branch Pipe - 20 Nos, Hose Pipe-20 Nos, Hose Reel Complete Set – 12 Nos	Necessary Servicing done, Found Ok
2	i) 2280 LPM Electrical Main Pumps – 02 Nos ii) 180 Electrical Driven Jockey Pump – 01 No iii) 450 LPM Booster Pump – 01 No iv) Main Control Panel – 01 No v) Pump Starter – 01 No	Necessary Servicing done, Found Ok
3	Automatic Sprinkler System – Upright Sprinklers – 266 Nos	Necessary Servicing done, Found Ok
4	Fire Service Inlet – 4 Way – 01 No	Necessary Servicing done, Found Ok
5	Talk Back System – 7 Units	Necessary Servicing done, Found Ok
6	Fire Extinguishers – ABC Type, 4 Kg – 18 Nos, CO2 Type 4.5 Kg – 01 No , ABC Type, 6 Kg – 06 Nos	Checked, Found Ok

Place: Pune

Signature and Address of the License Agency

GANESH
LAXMAN
NALAGE

Digitally signed by
GANESH LAXMAN
NALAGE
Date: 2026.07.15
16:09:05 +05'30'

Date: 15.07.2026

License No: MFS / LA / RF-317 / RD-306

Office No.J-308, 2nd Floor, Mega Center, Pune-Solapur Road, Hadapsar, Pune-411028.

☎ 101/ 8484003636 / 9422504471 / Email: atharvaent101@gmail.com