

**RED BANNER ALERT****mainroads**
WESTERN AUSTRALIA**SHW Serious Incident (SI) – Preliminary Notice**

Date of Incident	28 May 2024	Time of Incident	11:15am
Directorate / Region	RMO – Metropolitan	Main Roads or Contractor	Contractor
EQSafe Event Type	Near Miss	EQSafe Incident Number	40675
Actual Consequence	Minor	Potential Consequence	Major

Incident Short Description	Excavator operator struck an unidentified low voltage overhead powerline
-----------------------------------	--

What Happened

At approximately 11:15am, an excavator operated by the contractor struck an unidentified low voltage overhead powerline. The boom of the excavator made contact with the powerline.

The excavator operator immediately stopped all operations, and the area surrounding the incident was evacuated to ensure the safety of all personnel.

No injuries were reported, and there was no damage to the excavator.

A site manager contacted the local power utility company to report the incident and request an immediate power shut down to the affected line.

Once shut off, a preliminary inspection was conducted to assess for any damage and other potential hazards.

A formal ICAM investigation has commenced. Once completed, the lessons learnt will be communicated/shared through a final Grey Banner Alert as soon as practicable.



This serious potential incident aligns with the Main Roads Critical Risk profile relating to
Service Strike (Above Ground)

Distribution of Notice	Main Roads Personnel and Contracting Organisations
-------------------------------	--