

**RED BANNER ALERT****SHW Serious Incident (SI) – Preliminary Notice**

Date of Incident	16 March 2025	Time of Incident	14:30
Directorate / Region	OMTID	Main Roads or Contractor	Contractor
EQSafe Event Type	Near Miss	EQSafe Incident Number	57445
Actual Consequence	Insignificant	Potential Consequence	Major

Incident Short Description	Electrical arc flash during asset removal
-----------------------------------	---

What Happened

On the 16th March 2025 a worker was removing an existing Western Power asset, which was deemed to be redundant following recent disconnection by Western power in the area. At approximately 14:30, the worker commenced cutting the orange conduit protecting the cable asset with a reciprocating saw in preparation for a new service to be installed. During this cutting, an arc flash has occurred.

Worker was taken to hospital for examination of potential burns, no treatment was required, no shock received but precautionary ECG was undertaken. Area was isolated and Western Power notified. Western Power emergency response attended the site to isolate the asset.



A formal ICAM investigation has commenced. Once completed, the lessons learnt will be communicated/shared through a final Grey Banner Alert as soon as practicable.



This serious potential incident aligns with the Main Roads Critical Risk profile relating to
Electric Shock and Arc Flash.

Distribution of Notice	Main Roads Personnel and Contracting Organisations
-------------------------------	--