



RED BANNER ALERT



SHW Serious Incident (SI) – Preliminary Notice

Date of Incident:	31 October 2023	Time of Incident:	11:00
Directorate / Region:	IDD	Main Roads or Contractor:	Subcontractor
EQSafe Event Type:	Incident – Injury / Illness	EQSafe Incident Number:	34844
Actual Consequence:	Moderate	Potential Consequence:	Major

Incident Short Description:	Suspected contact with HV powerline by excavator caused Electric Shock to operator
------------------------------------	--

What Happened:

Whilst backfilling a trench, an excavator and kibble contacted the High Voltage Power Line in the work area. This caused the excavator to short out.

The contact with the powerline was not seen or witnessed and there was noted damage to the powerline. However, upon inspection of the excavator, there was evident scorch marks found.

The operator was taken to a medical provider for assessment. No injuries or ill effects have been reported.



Photos of the work site, showing the excavator and power line that was struck.

A formal ICAM investigation has commenced. Once completed, the lessons learnt will be communicated/shared through a final Grey Banner Alert as soon as practicable.



This serious potential incident aligns with the Main Roads Critical Risk profile relating to **Service Strike (Above and Below Ground and Electric Shock)**

Distribution of Notice:

Main Roads Personnel and Contracting Organisations