

**GOVERNMENT OF WEST BENGAL
OFFICE OF THE DIVISIONAL FIRE OFFICER
WEST BENGAL FIRE & EMERGENCY SERVICES
P.O. - Kenduadihi, P.S. - Bankura, Pin - 722102**

Memo No : IND/WB/FES/20192020/56754

DATE: 03/06/2019

From :

The Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services.

To :

St. Xavier's High School,
Damodarpur, Plot no. 88, 535/540, Kh. no. 187, J.L no. 184, 187, Near Puabagan, Dist:
Bankura, Pin - 722146.
Bankura F.S., Bankura P.S.,
Bankura - 722146 .


Sub :Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 2 storied building under group Educational, in favour of St. Xavier's High School, at the premises no.- nil, Damodarpur, Plot no. 88, 535/540, Kh. no. 187, J.L no. 184, 187, Near Puabagan, Dist: Bankura, Pin - 722146.


This is in reference to your Application No. IND/WB/FES/20192020/56754, dated 03/06/2019, regarding the Renewal of Fire Safety Certificate for the occupancy of an existing construction of G + 2 storied building under group Educational, in favour of St. Xavier's High School, at the premises no.- nil, Damodarpur, Plot no. 88, 535/540, Kh. no. 187, J.L no. 184, 187, Near Puabagan, Dist: Bankura, Pin - 722146..

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

1. Driveway must be free of any type of obstruction for easy movement of fire appliances.


PRINCIPAL
ST. XAVIER'S HIGH SCHOOL, BANKURA


Principal / K.V. Adra
(4040) / Kenduadihi (W.B.)


Manager
St. Xavier's High School

No parking will be allowed on the drive way. Basement shall not be used other than Car parking.

2.The interior finish decoration of the building shall be made low flame spread materials conforming I.S. specifications.

3.To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be strictly maintained.

4.Existing electrical wiring of the whole building shall have to be carefully checked for any were and tear in them, particularly lines above false ceiling and ducts.

5.The employees and security staff shall be conversant with installed Fire Fighting equipment's of the building and to operate in the event of Fire and Testing.

6.Mock Fire practice and evacuation drill shall be performed periodically with participation of all occupants of building.

7.Transformer and switchgear room shall be protected with automatic co2 or DCP fire extinguisher conforming I.S specification.

8.First aid firefighting system shall be provided as per I.S specification.

9.Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.

10.Fire License shall have to be obtained for storing and processing with highly combustible articles.

11.The Fire Safety Certificate is valid for a period of three years from the date of issue, and has to be renewed after three years certifying about the satisfactory services, performance of all the Life and Fire Safety arrangements installation of the building.

Divisional Fire Officer
West Bengal Fire & Emergency Services

Signature valid

Digitally signed by SUNIL
KUMAR CHAKRABORTY
Date: 2019.06.03 10:18:54 IST

PRINCIPAL
ST. XAVIER'S HIGH SCHOOL, BANKURA

Principal
के० वि० आद्रा/K.V.Adra
पुरुलिया (प०ब०)/Purulia (W.B.)

Manager
St. Xavier's High School