


FIRE SUPPRESSION GENERAL NOTES

	NEW FIRE PROTECTION PIPING		2.5" FIRE HOSE VALVE CONNECTION
	EXISTING FIRE PROTECTION PIPING TO REMAIN		2.5" FIRE HOSE VALVE IN CABINET
	FIRE PROTECTION PIPING TO BE DEMOLISHED		HOSE STATION
	RECESSED PENDENT SPRINKLER		WATER FLOW SWITCH
	CONCEALED SPRINKLER		VALVE SUPERVISORY SWITCH
	PENDENT SPRINKLER		INSPECTOR'S TEST CONNECTION
	SIDEWALL SPRINKLER		AIR COMPRESSOR
	UPRIGHT SPRINKLER		NITROGEN GENERATOR
	ELBOW		RISER MOUNTED AIR COMPRESSOR
	CAP OR PLUG		POINT OF CONNECTION
	TEE		POINT OF DISCONNECTION
	TEE DOWN		HYDRAULIC CALCULATION AREA
	ELBOW - TURNED DOWN		HYDRAULIC NODE
	PIPE CONTINUATION		FDC, WALL MOUNTED
	CONCENTRIC REDUCER		FDC, FREESTANDING
	ECCENTRIC REDUCER		PRESSURE GAUGE
	OS&Y VALVE		WATER MOTOR GONG
	CHECK VALVE		MATERIAL OR EQUIPMENT TO BE DEMOLISHED
	BUTTERFLY VALVE		MATERIAL OR EQUIPMENT EXISTING TO REMAIN
	ALARM CHECK VALVE		
	DRY PIPE VALVE		
	PRE-ACTION VALVE		
	DELUGE VALVE		
	PRESSURE REDUCING VALVE		
	PRESSURE RELIEF VALVE		
	GATE VALVE - NON RISING STEM		
	WALL MOUNTED POST INDICATOR VALVE		
	BACKFLOW PREVENTER ASSEMBLY		
	FIRE PUMP		
	JOCKEY PUMP		
	PUMP/BACKFLOW TEST CONNECTION, WALL MOUNTED		
	PUMP/BACKFLOW TEST CONNECTION, FREESTANDING		
	FIRE PUMP FLOW METER		
	ZONE CONTROL ASSEMBLY CONSISTING OF CHECK VALVE, BUTTERFLY VALVE, PRESSURE GAGE, WATER FLOW SWITCH, VALVE SUPERVISORY SWITCH, PRESSURE RELIEF VALVE, AND INSPECTOR'S TEST AND DRAIN.		

- VCCS**


3650 North Nevada Ave
Colorado Springs, CO, 80907

899 LOGAN STREET
SUITE 508
DENVER, CO 80203
303.832.3272
smithgroup.com

RIDER LEVETT BUCKNALL
COST ESTIMATOR
1675 LARIMER STREET
DENVER, CO, 80202
720-904-1480

NV5
ACOUSTICS, IT/TELECOM & SECURITY, AUDIOVISUAL
2650 18TH STREET, SUITES 201-203
DENVER, CO 80211
720-213-7550

MARTIN/MARTIN, INC.
STRUCTURAL ENGINEER
12499 WEST COLFAX AVENUE
LAKEWOOD, CO, 80215
303-431-6100

SEALS AND SIGNATURESCD
SHEET NUMBER

12654.000

FP0.1

NEPA 13 HAZARD CLASSIFICATION

	OCCUPANCY CLASSIFICATION.....	LIGHT HAZARD
	DESIGN DENSITY.....	0.10GPM/SF
	REMOTE HYDRAULIC AREA.....	1500SF

	OCCUPANCY CLASSIFICATION.....	ORDINARY HAZARD
	DESIGN DENSITY.....	0.15GPM/SF
	REMOTE HYDRAULIC AREA.....	1500SF

Diagram illustrating the components of a key note:

- SECTION NUMBER
- DRAWING NUMBER WHERE DRAWN
- DETAIL NUMBER
- DRAWING NUMBER WHERE DRAWN
- KEY NOTE

HHWS
4

RISER DESIGNATION (TYPE AS INDICATED)

4 DEMO KEY NOTE