PROJECT CODE SUMMARY (NORTH AND SOUTH BUILDINGS)

APPLICABLE CODES/CRITERIA/DESIGN POLICY:

AUTHORITY HAVING JURISDICTION:
Office of the State Architect of Colorado

INTERNATIONAL BUILDING CODES

(IBC)	INTERNATIONAL BUILDING CODE	2018
(IEBC)	INTERNATIONAL REHABILITATION CODE	2018
(IECC)	INTERNATIONAL ENERGY CONSERVATION CODE	2018
(IFC)	INTERNATIONAL FIRE CODE	2018
(IMC)	INTERNATIONAL MECHANICAL CODE	2018
(IPC)	INTERNATIONAL PLUMBING CODE	2018

NATIONAL FIRE PROTECTION ASSOCIATION

NFPA 3	STANDARD FOR COMMISSIONING OF FIRE PROTECTION AND LIFE SAFETY SYSTEMS	2015
NFPA 4	STANDARD FOR INTEGRATED FIRE PROTECTION AND LIFE SAFETY SYSTEM TESTING	2015
NFPA 10	STANDARD FOR PORTABLE FIRE EXTINGUISHERS	2012
NFPA 13	INSTALLATION OF SPRINKLER SYSTEMS	2013
NFPA 14	STANDARD FOR THE INSTALLATION OF STANDPIPE AND HOSE SYSTEMS	2013
NFPA 70	NATIONAL ELECTRICAL CODE	2017
NFPA 72	NATIONAL FIRE ALARM AND SIGNALING CODE	2013
NFPA 85	BOILER AND COMBUSTION SYSTEMS HAZARDS CODE	2015
NFPA 101	LIFE SAFETY CODE	2012

ACCESSIBILITY GUIDELINES

ICC/ANSI 117.1	ACCESSIBLE AND USABLE BUILDINGS AND FACILITIES	2015

MINIMUM FIRE-RESISTANCE REQUIREMENTS:

FIRE-RESISTIVE RATING REQUIREMENTS FOR BUILDING ELEMENTS :
[PER IBC TABLE 601]

TYPE OF CONSTRUCTION: *IIB*

PRIMARY STRUCTURAL FRAME :	*0 HOURS*
BEARING WALLS (EXT) :	*0 HOURS*
BEARING WALLS (INTR) :	*0 HOURS*
NON-BRG WALLS AND PARTITIONS (EXT) *PER IBC TABLE 601:*	*0 HOURS*
NON-BRG WALLS AND PARTITIONS (INTR) :	*0 HOURS*
FLOOR CONSTR AND SECONDARY MEMBERS :	*0 HOURS*
ROOF CONSTR AND SECONDARY MEMBERS :	*0 HOURS*

FIRE-RESISTANCE RATING FOR EXTERIOR WALLS BASED ON FIRE SEPARATION DISTANCE {X} : *[PER IBC TABLE 602]*

CONSTRUCTION TYPE / OCCUPANCY	*IIB / B*
X < 5 FT	*1 HOURS*
5 FT < X < 10 FT	*1 HOURS*
10 FT < X < 30 FT	*0 HOURS*
X > 30 FT	*0 HOURS*

MAXIMUM AREA OF EXTERIOR WALL OPENINGS BASED ON FIRE SEPARATION DISTANCE: *[PER IBC TABLE 705.8]*

FIRE SEPARATION DISTANCE	DEGREE OF PROTECTION (UP, NS)	(UP, S)	(P)
0 < 3 FT	NP	NP	NP
3 < 5 FT	NP	15%	15%
5 < 10 FT	10%	25%	25%
10 < 15 FT	15%	45%	45%
15 < 20 FT	25%	75%	75%
20 < 25 FT	45%	NL	NL
25 < 30 FT	70%	NL	NL
30 FT >	NL	NR	NR

ADDITIONAL FIRE-RESISTIVE RATINGS :

DESCRIPTION	CODE SECTION	RATING (HR)
SHAFT ENCLOSURES	*IBC 713.4*	
FOUR STORIES OR MORE :		*2*
LESS THAN FOUR STORIES:		*1*
EXIT ENCLOSURES	*IBC 1022.1*	
FOUR STORIES OR MORE :		*2*
LESS THAN FOUR STORIES:		*1*
EXIT PASSAGEWAYS :	*IBC 1024.3*	*1*
HOISTWAY ENCLOSURES :	*IBC 3002.1*	*2*
ELEVATOR MACHINE ROOMS :	*IBC 3005.4*	*2*

CORRIDORS: *[IBC TABLE 1020.1]* SPRINKLERED: ●
OCCUPANCY: *B* OCC LOAD SERVED: *>30* RATING (HR): *0*
OCCUPANCY: *A* OCC LOAD SERVED: *>30* RATING (HR): *0*

NOTE: ALL SHAFT ENCLOSURES THAT PENETRATE FLOORS RATED FOR 2 OR MORE HOURS SHALL BE 2-HOUR RATED SHAFTS
FIRE DOOR AND FIRE SHUTTER FIRE PROTECTION RATINGS (hours):
[PER IBC TABLE 716.1(2)]

TYPE OF ASSEMBLY	REQ'D ASSEMBLY RATING	MIN. FIRE DOOR AND FIRE SHUTTER ASSEMBLY RATING
Fire walls and fire barriers having a required fire-resistance rating greater than 1 hour	4 3 2 1 1/2	3 3 1 1/2 1 1/2
Fire barriers having a required fire-resistance rating of 1 hour Shaft, exit enclosure and exit passageway walls: Other fire barriers:	1 1	1 3/4
Fire partitions Corridor walls: Other fire partitions:	1 0.5 1 0.5	1/3 1/3 3/4 1/3
Exterior Walls	3 2 1	1 1/2 1 1/2 3/4
Smoke Barriers	1	1/3

MEANS OF EGRESS:
*REFER TO THE LIFE SAFETY PLANS FOR ACTUAL MEASURED DISTANCES.
DOORS :
[PER IBC 1008.1.1]
THE MINIMUM CLEAR WIDTH AND HEIGHT OF A DOOR SHALL NOT BE LESS THAN 32 INCHES AND 80 INCHES RESPECTIVELY.

[PER IBC 1008.1.2]
DOORS SHALL SWING IN THE DIRECTION OF EGRESS TRAVEL, WHERE SERVING AN OCCUPANT LOAD OF 50 OR MORE PERSONS OR A GROUP H OCCUPANCY.

COMMON PATH OF EGRESS TRAVEL (IBC 1006.2.1)

OCCUPANCY	SPRINKLERED	MAX. DISTANCE
A-3	YES	75' - 0"
B, S-1	YES	100' - 0"

EXIT ACCESS TRAVEL DISTANCE (IBC TABLE 1017.2)

OCCUPANCY	SPRINKLERED	MAX. DISTANCE
B	YES	300' - 0"
A-3, S-1	YES	250' - 0"

DEAD ENDS (IBC 1020.4)

OCCUPANCY	SPRINKLERED	MAX. DISTANCE
A-3	YES	20' - 0"
B, S-1	YES	50' - 0"

MIN. NUMBER OF EXITS FOR OCCUPANT LOAD (IBC TABLE 1006.3.2)

OCCUPANT LOAD	MIN. # OF EXITS PER STORY
1-500	2
501-1,000	3
MORE THAN 1,000	4

EXIT CAPACITY FACTORS:
[PER IBC 1005.1]

MINIMUM REQUIRED EGRESS WIDTH :		
STAIRWAYS	*0.3*	● SPRINKLERED
OTHER EGRESS COMPONENTS	*0.2*	○ EMERGENCY VOICE/ALARM COMMUNICATION SYSTEM

*REFER TO THE LIFE SAFETY PLANS FOR COMPLIANCE WITH MEANS OF EGRESS WIDTH REQUIREMENTS.

LIFE SAFETY SYSTEMS:
(PER IBC AND IFC CHAPTER 9)

AUTOMATIC SPRINKLER SYSTEM :	● PROVIDED PER NFPA 13
ALTERNATIVE AUTOMATIC FIRE-EXTINGUISHING SYSTEMS :	○ PROVIDED - REFER TO FIRE PROTECTION DRAWINGS
STANDPIPE SYSTEM :	○ PROVIDED PER NFPA 14: CLASS I
PORTABLE FIRE EXTINGUISHERS :	● PROVIDED PER NFPA 10
FIRE ALARM SYSTEM :	● PROVIDED PER NFPA 72

NORTH BUILDING

CODE COMPLIANCE APPROACH

CODE COMPLIANCE APPROACH:
THE UCCS CYBERSECURITY AND SPACE ECOSYSTEM EXPANSION PROJECT IS COMPRISED OF INTERIOR RENOVATIONS TO TWO EXISTING BUILDINGS IDENTIFIED AS NORTH AND SOUTH BUILDINGS.

THE RENOVATION IN THE NORTH BUILDING IS APPROXIMATELY 20,500 GSF COMPRISED OF OFFICES, TRAINING, CLASSROOM, CAFE, OPEN COLLABORATION SPACE, RESEARCH LABORATORIES AND SUPPORT SPACE. THE LABORATORIES DO NOT UTILIZE ANY HAZADOUS MATERIALS AND ARE LIMITED TO GRADUATE RESEARCH PROGRAMS.

THE NORTH BUILDING WILL BE CLASSIFIED AS MIXED-USE, (SEPARATED) COMPRISED OF GROUP A-3, AND GROUPS B/S-1 OCCUPANCIES.

THE EXISTING NORTH AND SOUTH BUILDINGS ARE ONE-STORY, SPRINKLERED, TYPE II-B CONSTRUCTION WITH AN EXISTING 2-HOUR HORIZONTAL EXIT WITH 90-MINUTE DOORS BETWEEN BUILDINGS. THIS EXISTING ASSEMBLY WILL BE MAINTAINED IN THIS PROJECTS RENOVATION. THE NORTH AND SPACE BUILDING ARE SEPARATED WITH AN EXISTING 2-HOUR FIRE WALL THAT WILL BE MAINTAINED.

THE NORTH AND SOUTH BUILDINGS WILL BE PROTECTED THROUGH-OUT WITH NFPA 13 AUTOMATIC SPRINKLER SYSTEM. ACCESSIBILITY REQUIREMENTS ARE BASED ON THE 2015 ICC/ANSI A117.1 STANDARDS FOR ACCESSIBLE DESIGN.

BUILDING CLASSIFICATION

BUILDING CLASSIFICATION:
OCCUPANCY CLASSIFICATION AND CONSTRUCTION TYPES PER IBC CHAPTERS 3, 4, 5, AND 6

BASIC OCCUPANCY GROUP(S) :*[PER IBC CHAPTER 3]*

○ GROUP A-1	○ GROUP A-2	● GROUP A-3
○ GROUP A-4	○ GROUP A-5	● GROUP B
○ GROUP E	○ GROUP F-1	○ GROUP F-2
○ GROUP H-1	○ GROUP H-2	○ GROUP H-3
○ GROUP H-4	○ GROUP H-5	○ GROUP I-1
○ GROUP I-2	○ GROUP I-3	○ GROUP I-4
○ GROUP M	○ GROUP R-1	○ GROUP R-2
○ GROUP R-3	○ GROUP R-4	● GROUP S-1
○ GROUP S-2	○ GROUP U	

MIXED USE AND OCCUPANCY : *[PER IBC SECTION 508 & 509]*

● ACCESSORY OCCUPANCIES *[IBC 508.2]*
[Accessory Occupancies <10% of Story]
○ INCIDENTAL USES *[IBC SECTION 509]*
○ NONSEPARATED OCCUPANCIES* *[IBC 508.3]*
● SEPARATED OCCUPANCIES *[IBC 508.4]*

*REFER TO FIRE AND LIFE SAFETY PLANS FOR SEPARATION REQUIREMENTS

TYPE(S) OF CONSTRUCTION : *[PER IBC CHAPTER 6]*

TYPE I :	○A	○B
TYPE II :	○A	●B
TYPE III :	○A	○B
TYPE IV :	○HT	
TYPE V :	○A	○B

SPECIAL DETAILED REQUIREMENTS :
○ HIGH-RISE BUILDING *[PER IBC SECTION 403]*
○ ATRIUM *[PER IBC SECTION 404]*
○ OPEN PARKING GARAGE *[PER IBC SECTION 406.5]*
○ GROUP I-2: *[PER IBC SECTION 407]*
- SMOKE COMPARTMENTS
- REFUGE AREA
○ HAZARDOUS MATERIALS: *[PER IBC SECTION 414]*
- CONTROL AREAS
○ MEZZANINE *[PER IBC SECTION 505]*
○ EQUIPMENT PLATFORM *[PER IBC SECTION 505]*

BUILDING AREA CALCULATIONS

BUILDING AREA CALCULATIONS:
PER IBC CHAPTER 5
○ UNLIMITED AREA ALLOWED *(PER IBC TABLE 503)*
○ UNLIMITED HEIGHT ALLOWED

○ UNLIMITED AREA BUILDING *(PER IBC SECTION 507)*
○ NONSPRINKLERED, ONE-STORY, 60 FOOT YARDS
○ SPRINKLERED, ONE-STORY ABOVE GRADE PLANE, 60' YARDS
○ SPRINKLERED, TWO STORIES ABOVE GRADE PLANE, 60' YARDS

○ AUTOMATIC SPRINKLER SYSTEM INCREASE USED FOR ALLOWABLE HEIGHT MODIFICATION *(PER IBC 504.1)*
○ 20 FEET AND ONE STORY

○ NO ALLOWABLE HEIGHT OR AREA MODIFICATIONS USED

○ ALLOWABLE AREA MODIFICATIONS USED PER THE ALLOWABLE AREA CALCULATIONS ON THIS SHEET:
○ BUILDING AREA MODIFICATIONS *(PER IBC EQUATION 5-2)*
○ FRONTAGE INCREASE *(PER IBC EQUATION 5-5)*

BUILDING OCCUPANCY SUMMARY

OCCUPANCY CLASSIFICATION	AREA	P/SF	GSF/NSF /FIXED	OCC LOAD	AREA COUNT	NOTES
North Building						
A-3, Assembly Unconcentrated, Over 49 Occupants	1872 SF	15	NSF	126	2	
A-3, Assembly Unconcentrated, Over 49 Occupants	1024 SF	20	NSF	52	1	
B, Assembly Unconcentrated, Less Than 750 SF or 50 Occupants	1792 SF	15	NSF	124	9	
B, Business	3559 SF	150	GSF	26	4	
B, Business Concentrated	236 SF	50	GSF	6	2	
B, Classroom, Less Than 50 Occupants	3038 SF	20	NSF	153	2	
S-1, Storage/Accessory	319 SF	300	GSF	3	3	
	11840 SF			490		

MINIMUM PLUMBING FACILITIES

REQUIRED OCCUPANTS: 490 + 138 (EXISTING S-1) = 628

OCCUPANTS: 326	(163 MALE 163 FEMALE)						
OCCUPANCY: BUSINESS - B	WATER CLOSET		LAVATORIES		BATHTUBS OR SHOWERS	DRINKING FOUNTAINS	OTHER
	MALE	FEMALE	MALE	FEMALE			
RATIO:	1:25 FIRST 50 1:50 REMAIN		1:40 FIRST 80 1:80 REMAIN			1:100	
REQUIRED:	4.26	4.26	3.04	3.04	–	3.26	NOTE 1

OCCUPANTS: 302	(151 MALE 151 FEMALE)						
OCCUPANCY: ASSEMBLY - A-3 (AUDITORIUMS, ETC.)	WATER CLOSET		LAVATORIES		BATHTUBS OR SHOWERS	DRINKING FOUNTAINS	OTHER
	MALE	FEMALE	MALE	FEMALE			
RATIO:	1:125	1:65	1:200	1:200		1:500	
REQUIRED:	1.21	2.32	0.76	0.76	–	0.60	NOTE 1

THE NORTH BUILDING HAS PROVIDED MORE THAN THE MINIMUM NUMBER OF PLUMBING FACILITIES. THE 50% SPLIT FOR PLUMBING FIXTURES BETWEEN URINALS AND WATER CLOSETS IS MET BASED ON THE REQUIRED NUMBER OF PLUMBING FIXTURES. THE ADDITIONAL FIXTURES ARE PROVIDED AS EXTRA BENEFIT TO THE BUILDING OCCUPANTS.

PROVIDED

OVERALL BUILDING SUMMARY	WATER CLOSET		LAVATORIES		BATHTUBS OR SHOWERS	DRINKING FOUNTAINS	OTHER
	MALE	FEMALE	MALE	FEMALE			
SUBTOTAL REQUIRED:	5.47	6.58	3.80	3.80	0	3.86	1 SERVICE SINK
TOTAL REQUIRED:	6	7	4	4	0	4	1 SERVICE SINK
WC PROVIDED:	5	25	--	--	--	--	--
LAV PROVIDED:	--	--	8	10	--	--	--
URINALS PROVIDED: *(NOTE 2)*	9	--	--	--	--	--	--
DF PROVIDED: *(NOTE 6)*	--	--	--	--	--	4	--
TOTAL PROVIDED:	14	25	8	10	0	4	2 SERVICE SINKS

SINGLE-OCCUPANT RESTROOMS INCLUDED IN THE ABOVE TOTALS *(NOTE 3)*: 0
FAMILY RESTROOMS PROVIDED IN ADDITION TO ABOVE TOTALS *(NOTE 4)*: 1
FAMILY BATHING ROOMS PROVIDED IN ADDITION TO ABOVE TOTALS *(NOTE 5)*: 0

NOTE 1:
THE CODE REQUIRES ONLY (1) SERVICE SINK PER BUILDING IF ALL OCCUPANCIES HAVE ACCESS TO THE SERVICE SINK AT ALL TIMES.

NOTE 2:
IN 'A' AND 'E' OCCUPANCIES: URINALS SHALL NOT BE SUBSTITUTED FOR MORE THAN 67% OF THE REQ'D WC. IN ALL OTHER OCCUPANCIES: URINALS SHALL NOT BE SUBSTITUTED FOR MORE THAN 50% OF THE REQ'D WC.

NOTE 3:
SINGLE-OCCUPANT RESTROOM = (1) WC AND (1) LAV PROVIDED FIXTURES DISTRIBUTED AMONGST EACH SEX

NOTE 4:
FAMILY OR ASSISTED-USE TOILET ROOMS = (1) WC AND (1) LAV PROVIDED

NOTE 5:
FAMILY OR ASSISTED-USE BATHING ROOMS = (1) WC AND (1) LAV PROVIDED AND (1) SHOWER OR (1) BATH

NOTE 6:
WATER COOLERS OR BOTTLED WATER DISPENSERS SHALL BE PERMITTED TO BE SUBSTITUTED FOR NOT MORE THAN 50 PERCENT OF THE REQUIRED DRINKING FOUNTAINS.

SOUTH BUILDING

CODE COMPLIANCE APPROACH

CODE COMPLIANCE APPROACH:
THE UCCS CYBERSECURITY AND SPACE ECOSYSTEM EXPANSION PROJECT IS COMPRISED OF INTERIOR RENOVATIONS TO TWO EXISTING BUILDINGS IDENTIFIED AS NORTH AND SOUTH BUILDINGS.

THE RENOVATION IN THE SOUTH BUILDING IS APPROXIMATELY 6,000 GSF COMPRISED OF OFFICE, COLLABORATION SPACE AND CYBER VULNERABILITY LABORATORY.

THE SOUTH BUILDING WILL BE CLASSIFIED AS MIXED-USE, (NON-SEPARATED) COMPRISED OF GROUP B/S-1 OCCUPANCIES.

THE EXISTING NORTH AND SOUTH BUILDINGS ARE ONE-STORY, SPRINKLERED, TYPE II-B CONSTRUCTION WITH AN EXISTING 2-HOUR HORIZONTAL EXIT WITH 90-MINUTE DOORS BETWEEN BUILDINGS. THIS EXISTING ASSEMBLY WILL BE MAINTAINED IN THIS PROJECTS RENOVATION.

THE NORTH AND SOUTH BUILDINGS WILL BE PROTECTED THROUGH-OUT WITH NFPA 13 AUTOMATIC SPRINKLER SYSTEM. ACCESSIBILITY REQUIREMENTS ARE BASED ON THE 2015 ICC/ANSI A117.1 STANDARDS FOR ACCESSIBLE DESIGN.

BUILDING CLASSIFICATION

BUILDING CLASSIFICATION:
OCCUPANCY CLASSIFICATION AND CONSTRUCTION TYPES PER IBC CHAPTERS 3, 4, 5, AND 6

BASIC OCCUPANCY GROUP(S) :*[PER IBC CHAPTER 3]*

○ GROUP A-1	○ GROUP A-2	○ GROUP A-3
○ GROUP A-4	○ GROUP A-5	● GROUP B
○ GROUP E	○ GROUP F-1	○ GROUP F-2
○ GROUP H-1	○ GROUP H-2	○ GROUP H-3
○ GROUP H-4	○ GROUP H-5	○ GROUP I-1
○ GROUP I-2	○ GROUP I-3	○ GROUP I-4
○ GROUP M	○ GROUP R-1	○ GROUP R-2
○ GROUP R-3	○ GROUP R-4	● GROUP S-1
○ GROUP S-2	○ GROUP U	

MIXED USE AND OCCUPANCY : *[PER IBC SECTION 508 & 509]*

● ACCESSORY OCCUPANCIES *[IBC 508.2]*
[Accessory Occupancies <10% of Story]
○ INCIDENTAL USES *[IBC SECTION 509]*
● NONSEPARATED OCCUPANCIES* *[IBC 508.3]*
○ SEPARATED OCCUPANCIES *[IBC 508.4]*

*REFER TO FIRE AND LIFE SAFETY PLANS FOR SEPARATION REQUIREMENTS

TYPE(S) OF CONSTRUCTION : *[PER IBC CHAPTER 6]*

TYPE I :	○A	○B
TYPE II :	○A	●B
TYPE III :	○A	○B
TYPE IV :	○HT	
TYPE V :	○A	○B

SPECIAL DETAILED REQUIREMENTS :
○ HIGH-RISE BUILDING *[PER IBC SECTION 403]*
○ ATRIUM *[PER IBC SECTION 404]*
○ OPEN PARKING GARAGE *[PER IBC SECTION 406.5]*
○ GROUP I-2: *[PER IBC SECTION 407]*
- SMOKE COMPARTMENTS
- REFUGE AREA
○ HAZARDOUS MATERIALS: *[PER IBC SECTION 414]*
- CONTROL AREAS
○ MEZZANINE *[PER IBC SECTION 505]*
○ EQUIPMENT PLATFORM *[PER IBC SECTION 505]*

BUILDING AREA CALCULATIONS

BUILDING AREA CALCULATIONS:
PER IBC CHAPTER 5
○ UNLIMITED AREA ALLOWED *(PER IBC TABLE 503)*
○ UNLIMITED HEIGHT ALLOWED

○ UNLIMITED AREA BUILDING *(PER IBC SECTION 507)*
○ NONSPRINKLERED, ONE-STORY, 60 FOOT YARDS
○ SPRINKLERED, ONE-STORY ABOVE GRADE PLANE, 60' YARDS
○ SPRINKLERED, TWO STORIES ABOVE GRADE PLANE, 60' YARDS

○ AUTOMATIC SPRINKLER SYSTEM INCREASE USED FOR ALLOWABLE HEIGHT MODIFICATION *(PER IBC 504.1)*
○ 20 FEET AND ONE STORY

○ NO ALLOWABLE HEIGHT OR AREA MODIFICATIONS USED

○ ALLOWABLE AREA MODIFICATIONS USED PER THE ALLOWABLE AREA CALCULATIONS ON THIS SHEET:
○ BUILDING AREA MODIFICATIONS *(PER IBC EQUATION 5-2)*
○ FRONTAGE INCREASE *(PER IBC EQUATION 5-5)*

BUILDING OCCUPANCY SUMMARY

OCCUPANCY CLASSIFICATION	AREA	P/SF	GSF/NSF /FIXED	OCC LOAD	AREA COUNT	NOTES
South Building						
B, Assembly Unconcentrated, Less Than 750 SF or 50 Occupants	416 SF	15	NSF	29	2	
B, Business	2294 SF	150	GSF	17	2	
B, Business Concentrated	2587 SF	50	GSF	53	2	
S-1, Storage/Accessory	119 SF	300	GSF	1	1	
	5416 SF			100		

MINIMUM PLUMBING FACILITIES

REQUIRED OCCUPANTS: 100 + 148 (EXISTING S-1) + 96 (EXISTING B) = 344

OCCUPANTS: 166	(83 MALE 83 FEMALE)						
OCCUPANCY: BUSINESS - B	WATER CLOSET		LAVATORIES		BATHTUBS OR SHOWERS	DRINKING FOUNTAINS	OTHER
	MALE	FEMALE	MALE	FEMALE			
RATIO:	1:25 FIRST 50 1:50 REMAIN		1:40 FIRST 80 1:80 REMAIN			1:100	
REQUIRED:	2.66	2.66	2.04	2.04	–	1.66	NOTE 1

OCCUPANTS: 149	(75 MALE 75 FEMALE)						
OCCUPANCY: STORAGE - S-1, S-2	WATER CLOSET		LAVATORIES		BATHTUBS OR SHOWERS	DRINKING FOUNTAINS	OTHER
	MALE	FEMALE	MALE	FEMALE			
RATIO:	1:100		1:100			1:1,000	
REQUIRED:	0.75	0.75	0.75	0.75	[a]	0.15	NOTE 1

NOTE [a]: EMERGENCY SHOWERS AND EYEWASH STATIONS SHALL CONFORM TO ISEA Z358.1

OCCUPANTS: 29	(15 MALE 15 FEMALE)						
OCCUPANCY: ASSEMBLY - A-3 (AUDITORIUMS, ETC.)	WATER CLOSET		LAVATORIES		BATHTUBS OR SHOWERS	DRINKING FOUNTAINS	OTHER
	MALE	FEMALE	MALE	FEMALE			
RATIO:	1:125	1:65	1:200	1:200		1:500	
REQUIRED:	0.12	0.23	0.08	0.08	–	0.06	NOTE 1

PROVIDED

OVERALL BUILDING SUMMARY	WATER CLOSET		LAVATORIES		BATHTUBS OR SHOWERS	DRINKING FOUNTAINS	OTHER
	MALE	FEMALE	MALE	FEMALE			
SUBTOTAL REQUIRED:	3.53	3.64	2.87	2.87	0	1.87	1 SERVICE SINK
TOTAL REQUIRED:	4	4	3	3	0	2	1 SERVICE SINK
WC PROVIDED:	8	10	--	--	--	--	--
LAV PROVIDED:	--	--	6	6	--	--	--
URINALS PROVIDED: *(NOTE 2)*	3	--	--	--	--	--	--
DF PROVIDED: *(NOTE 6)*	--	--	--	--	--	2	--
TOTAL PROVIDED:	11	10	6	6	0	2	2

SINGLE-OCCUPANT RESTROOMS INCLUDED IN THE ABOVE TOTALS *(NOTE 3)*: 1
FAMILY RESTROOMS PROVIDED IN ADDITION TO ABOVE TOTALS *(NOTE 4)*: 0
FAMILY BATHING ROOMS PROVIDED IN ADDITION TO ABOVE TOTALS *(NOTE 5)*: 0

NOTE 1:
THE CODE REQUIRES ONLY (1) SERVICE SINK PER BUILDING IF ALL OCCUPANCIES HAVE ACCESS TO THE SERVICE SINK AT ALL TIMES.

NOTE 2:
IN 'A' AND 'E' OCCUPANCIES: URINALS SHALL NOT BE SUBSTITUTED FOR MORE THAN 67% OF THE REQ'D WC. IN ALL OTHER OCCUPANCIES: URINALS SHALL NOT BE SUBSTITUTED FOR MORE THAN 50% OF THE REQ'D WC.

NOTE 3:
SINGLE-OCCUPANT RESTROOM = (1) WC AND (1) LAV PROVIDED FIXTURES DISTRIBUTED AMONGST EACH SEX

NOTE 4:
FAMILY OR ASSISTED-USE TOILET ROOMS = (1) WC AND (1) LAV PROVIDED

NOTE 5:
FAMILY OR ASSISTED-USE BATHING ROOMS = (1) WC AND (1) LAV PROVIDED AND (1) SHOWER OR (1) BATH

NOTE 6:
WATER COOLERS OR BOTTLED WATER DISPENSERS SHALL BE PERMITTED TO BE SUBSTITUTED FOR NOT MORE THAN 50 PERCENT OF THE REQUIRED DRINKING FOUNTAINS.

GRAPHIC LEGEND

PROJECT CODE SUMMARY SYMBOLS

○ ITEM NOT SELECTED
● ITEM SELECTED

GENERAL FIRE AND LIFE SAFETY SHEET NOTES

A. THE PURPOSE OF THE FIRE AND LIFE SAFETY DRAWINGS IS TO ILLUSTRATE IN SCHEMATIC FASHION, THE APPLICABLE EXITING, FIRE-RESISTANCE, AND LIFE SAFETY CONCEPTS UTILIZED BY THIS PROJECT; INCLUDING, BUT NOT LIMITED TO:
- OCCUPANCY CLASSIFICATIONS
- OCCUPANCY LOAD FACTORS
- EXIT LOCATIONS, EXIT PATHS & CAPACITY - FUNCTION OF SPACE
- FIRE-RESISTANCE RATED CONSTRUCTION
- AND OTHER STRATEGIES RELATED TO THE CODE COMPLIANCE APPROACH OF THIS PROJECT.

B. ADDITIONAL DETAILED REQUIREMENTS APPLY TO THE CONSTRUCTION OF PARTITIONS, FIRE RATED DOOR ASSEMBLIES, INTERIOR GLAZED OPENINGS, DUCTS, SMOKE AND FIRE DAMPERS AND THROUGH PENETRATION FIRE STOPPING. REFER TO THE DRAWINGS OF EACH DISCIPLINE AND THE SPECIFICATIONS FOR THESE REQUIREMENTS.

C. ADDITIONAL DETAILED REQUIREMENTS SHOWN ELSEWHERE MAY REQUIRE CONSTRUCTION HAVING GREATER FIRE RATINGS, MORE EXTENSIVE FIRE-RATED CONSTRUCTION,OR MORE COMPLEX ASSEMBLIES THAN INDICATED BY THE DIAGRAMS ON THIS SHEET. WHEN PROVIDED, THE ADDITIONAL DETAILED REQUIREMENTS SHALL GOVERN.

D. FIRE BARRIERS SHALL EXTEND FROM THE TOP OF THE FOUNDATION OR FLOOR/CEILING ASSEMBLY BELOW TO THE UNDERSIDE OF THE FLOOR OR ROOF SHEATHING, SLAB OR DECK ABOVE AND SHALL BE SECURELY ATTACHED THERETO. SUCH FIRE BARRIERS SHALL BE CONTINUOUS THROUGH CONCEALED SPACES.

E. SHAFT ENCLOSURES SHALL BE CONSTRUCTED AS FIRE BARRIERS.

F. FIRE PARTITIONS SHALL EXTEND FROM THE TOP OF THE FOUNDATION OR FLOOR/CEILING ASSEMBLY BELOW TO THE UNDERSIDE OF THE FLOOR OR ROOF SHEATHING, SLAB OR DECK ABOVE OR TO THE FIRE-RESISTANCE-RATED FLOOR/CEILING OR ROOF/CEILING ASSEMBLY ABOVE, AND SHALL BE SECURELY ATTACHED THERETO.

G. SMOKE BARRIERS SHALL FORM AN EFFECTIVE MEMBRANE CONTINUOUS FROM OUTSIDE WALL TO OUTSIDE WALL AND FROM THE TOP OF THE FOUNDATION OR FLOOR/CEILING ASSEMBLY BELOW TO THE UNDERSIDE OF THE FLOOR OR ROOF SHEATHING, DECK OR SLAB ABOVE, INCLUDING CONTINUITY THROUGH CONCEALED SPACES.

H. SMOKE PARTITIONS SHALL EXTEND FROM THE TOP OF THE FOUNDATION OR FLOOR BELOW TO THE UNDERSIDE OF THE FLOOR OR ROOF SHEATHING, DECK OR SLAB ABOVE OR TO THE UNDERSIDE OF THE CEILING ABOVE WHERE THE CEILING MEMBRANE IS CONSTRUCTED TO LIMIT THE TRANSFER OF SMOKE.

PROJECT FIRE AND LIFE SAFETY SHEET NOTES

A. INTERIOR WALL & CEILING FINISHES SHALL HAVE A FLAME SPREAD INDEX RATING OF NO MORE THAN CLASS B AT VERTICAL EXITS & EXIT PASSAGEWAYS AND EXIT ACCESS CORRIDORS AND OTHER EXITWAYS.

B. INTERIOR WALL & CEILING FINISHES SHALL HAVE A FLAME SPREAD INDEX RATING OF NO MORE THAN CLASS C AT ROOMS AND ENCLOSED SPACES.

C. ALL MATERIALS EXPOSED WITHIN DUCTS OR PLENUMS SHALL HAVE A FLAME SPREAD RATING INDEX NOT MORE THAN 25 AND A SMOKE DEVELOPED RATING OF NOT MORE THAN 50.

D. FIRE EXTINGUISHERS SHALL BE LOCATED SUCH THAT A MAXIMUM TRAVEL DISTANCE OF 75' SHALL NOT BE EXCEEDED (WHERE REQUIRED BY CODE).

E. LEVEL/ AREA MAIN OCCUPANCY EXIT SIGN LOCATIONS MAY NOT BE SHOWN. REFERENCE ELECTRICAL SHEETS FOR ALL EXIT SIGN LOCATIONS.

F. FIRE RESISTIVE ASSEMBLY DETAILS, IF APPLICABLE, ARE LOCATED ELSEWHERE IN THIS DRAWING SET PER THE SHEET INDEX.

G. ELEVATOR HOISTWAY OPENINGS SHALL BE PROTECTED AS REQUIRED BY THE CODE, CORRESPONDING TO THE RATING OF THE HOISTWAY.

H. EVERY ASSEMBLY OCCUPANCY ROOM OR SPACE SHALL HAVE THE OCCUPANT LOAD POSTED IN A CONSPICUOUS PLACE.

DEFERRED SUBMITTALS

ANTICIPATED DEFERRED SUBMITTALS

A. FIRE PROTECTION DESIGN
B. FIRE ALARM DESIGN
C. PARTITION STRUCTURE DESIGN

UCCS

UCCS CYBERSECURITY AND SPACE ECOSYSTEM EXPANSION
3650 NORTH NEVADA AVE
COLORADO SPRINGS, CO, 80907

SMITHGROUP
899 LOGAN STREET
SUITE 508
DENVER, CO 80203
303.832.3272
smithgroup.com

RIDER LEVETT BUCKNALL
COST ESTIMATOR
1675 LARIMER STREET
DENVER, CO, 80202
720-904-1480

NV5
ACOUSTICS, IT/TELECOM & SECURITY, AUDIOVISUAL
2650 18TH STREET, SUITES 201-203
DENVER, CO 80211
720-213-7550

MARTIN/MARTIN, INC.
STRUCTURAL ENGINEER
12499 WEST COLFAX AVENUE
LAKEWOOD, CO, 80215
303-431-6100

ISSUED FOR	REV	DATE
BID SET		04MAY2021
CONSTRUCTION DOCUMENTS		15APR2021
DESIGN DEVELOPMENT		23DEC2020
SCHEMATIC DESIGN		19OCT2020

SEALS AND SIGNATURES

COLORADO LICENSED ARCHITECT
MECAYLA COBB
404736
05/04/2021

SHEET TITLE
BUILDING CODE SUMMARY

12654.000
PROJECT NUMBER

CD **G2.1.1**
SHEET NUMBER

Plot Date: 5/4/2021 10:19:25 AM Author