

LAKESHORE PROFESSIONAL CENTER · TENANT IMPROVEMENT

PROJECT NO. 24-118 ISSUED FOR PERMIT · MARCH 14, 2026

SHEET M-101 · Mechanical

MECHANICAL DUCTWORK NOTES

1.1 Supply ductwork DS-6 within Corridor 210 shall maintain a minimum clearance of 9 feet 6 inches above finished floor to the bottom of duct insulation.

1.2 Return ductwork DS-9 within Corridor 214 shall maintain a minimum clearance of 8 feet 6 inches above finished floor to the bottom of duct insulation.

1.3 All ductwork shall be insulated per the mechanical specification, minimum R-6 for supply air serving conditioned spaces.

1.4 Provide fire/smoke dampers at all duct penetrations through rated corridor walls, per the life safety plan.

1.5 All mechanical equipment shall be supported independently of the ductwork it serves.