

LAKESHORE PROFESSIONAL CENTER · TENANT IMPROVEMENT

PROJECT NO. 24-118 ISSUED FOR PERMIT · MARCH 14, 2026

SHEET S-101 · Structural

STRUCTURAL FRAMING NOTES

1.1 Structural steel beam B-12 provides a minimum clear height of 9 feet 0 inches above finished floor within Corridor 210.

1.2 Structural steel beam B-15 provides a minimum clear height of 14 feet 0 inches above finished floor within Corridor 214.

1.3 Slab-on-grade at the ground floor is designed for a minimum live load of 100 pounds per square foot, typical office occupancy.

1.4 Foundation footings bear on undisturbed soil with a minimum allowable bearing pressure of 3,000 pounds per square foot.

1.5 All structural steel shall be fabricated and erected in accordance with AISC 360 and the project specifications.