

Private Water Well	Top	Bottom
sand	0	30
gray shale	30	34
broken limestone & gray shale	34	90
broken limestone	90	130
Total Depth		130
Casing: 6" A53B 18.97 from 0' to 44'		
5" A53B 14.62 from 40' to 100'		
Grout: BENTONITE SLRY from 0 to 44.		
Size hole below casing: 5"		
Water from broken limestone at 100' to 130'.		
Static level 20' below casing top which is 3' above GL		
Pumping level 100' when pumping at 50 gpm for 4 hours		
Owner Address: 4895 Bonita Beach Road #606 Bonita Springs, FL		
Address of well: 320th St. N		
Hillsdale, IL		
Location source: Location from permit		

Permit Date: February 21, 1996

Permit #:

COMPANY Timmerman, Tom

FARM Strafford, Don

DATE DRILLED March 22, 1996

NO.

ELEVATION 0

COUNTY NO. 23241

LOCATION NW NE NW

LATITUDE 41.583718

LONGITUDE -90.19894

COUNTY Rock Island

API 121612324100

6 - 18N - 3E

