

Private Water Well	Top	Bottom
black dirt	0	4
gray clay	4	8
10-12 slot sand	8	39
12-15 slot sand	39	48
10 slot sand	48	57
gray sticky clay	57	81
fine sand	81	92
10 slot sand	92	104
10-12 slot sand	104	125
12-15 slot sand	125	143
Total Depth		143
Casing: 5" PVC SDR 21 from 0' to 138'		
3" SCREEN from 139' to 143'		
Screen: 4' of 3" diameter 12 slot		
Grout: BENTONITE from 0 to 100.		
Grout: #1 MUSCATINE from 100 to 143.		
Water from sand at 125' to 143'.		
Static level 21' below casing top which is 2' above GL		
Pumping level 35' when pumping at 35 gpm for 1 hour		
Permanent pump installed at 85'		
on June 17, 2015, with a capacity of 10 gpm		
Remarks: Driller's Estimated Well Yield 35 gpm		
Owner Address: PO Box 143 Tampico, IL		
Address of well: 29704 600 E. St.		
Tampico, IL 61283		
Location source: Global Positioning System verified		

Permit Date: April 8, 2015 Permit #: 011-004

COMPANY Albrecht, Harold Dean

FARM Wetzell, Brad

DATE DRILLED April 28, 2015

NO.

ELEVATION

COUNTY NO. 23569

LOCATION NW SW NW

LATITUDE 41.579806

LONGITUDE -89.735306

COUNTY Bureau

API 120112356900

6 - 18N - 7E

