$_{\mathtt{Page}-1}$ ILLINOIS STATE GEOLOGICAL SURVEY

Private Water Well	Top	Bottom
yellow sand	0	125
white limestone	125	275
Total Depth Casing: 6" SDR 21 from -1' to 140' 4.5" SDR 17 SOL-PVC from 135' to 155' 4.5" SCH40 SLO-PVC from 155' to 275'		275
Grout: BENSEAL from 0 to 140.		
Water from limestone at 160' to 275'. Static level 40' below casing top which is 2' above GI Pumping level 120' when pumping at 30 gpm for 2 hours		
Remarks: Driller's Estimated Well Yield 30 gpm Owner Address: ,		
Address of well: 25723 E 2200th St.		
Prophetstown, IL 61277		
Location source: Global Positioning System verified		
Image viewing help: New users please read this. GET FILE Related File -		

Permit Date: April 30, 2015 **Permit #:** 073-015

COMPANY Gingerich, Corwin
FARM Olson, Duane

DATE DRILLED May 18, 2015 NO.

ELEVATION COUNTY NO. 23975

LOCATION SE NE NW

LATITUDE 41.52168 **LONGITUDE** -90.026345

COUNTY Henry API 120732397500 27 - 18N - 4E