$_{\mathtt{Page}-1}$ ILLINOIS STATE GEOLOGICAL SURVEY

Private Water Well	Top	Bottom
clay	0	18
clay, gravel	18	43
shale	43	65
shale & limestone	65	150
gray limestone	150	298
Total Depth Casing: 6" WT STEEL 19.45 from -1' to 177' Grout: BENTONITE from 0 to 176.		298
Size hole below casing: 6"		
Water from limestone at 177' to 298'. Static level 26' below casing top which is 0' above GL Pumping level 150' when pumping at 30 gpm for 4 hours		
Owner Address: 1822 1st Ave. Sterling, IL Address of well: Fulfs Rd. Location source: Location from permit		

Permit Date: February 22, 1991 Permit #:

COMPANY Martin, Jonas Willard

FARM Thomaschefsey, Mark H.

DATE DRILLED April 15, 1991 NO.

ELEVATION 683GL COUNTY NO. 21852

LOCATION SE SE SE

LATITUDE 41.844783 **LONGITUDE** -89.650048

COUNTY Whiteside API 121952185200 35 - 22N - 7E