

Private Water Well	Top	Bottom
clay	0	17
coarse sand	17	30
white rock	30	140
<b>Total Depth</b>		<b>140</b>
Casing: 6" PVC from -1' to 45'		
Grout: BENTONITE from 0 to 45.		
Water from rock at 30' to 140'.		
Static level 10' below casing top which is 1' above GL		
Pumping level 60' when pumping at 35 gpm for 1 hour		
Permanent pump installed at 40'		
on October 12, 2007, with a capacity of 19 gpm		
Remarks: Driller's Estimated Well Yield 35 gpm		
Owner Address: 10723 Kings Ln Berrien Springs, MI		
Address of well: 29850 Ropp Rd		
Hillsdale, IL 61257		
Location source: Location from permit		

Permit Date: September 7, 2007

Permit #: 073-043

COMPANY Latta, Kirk Stephen

FARM Ropp, Bill

DATE DRILLED September 13, 2007

NO.

ELEVATION

COUNTY NO. 23609

LOCATION NE SE NE

LATITUDE 41.580947

LONGITUDE -90.146041

COUNTY Henry

API 120732360900

4 - 18N - 3E

