

| Private Water Well | Top | Bottom |
|--|-----|------------|
| sand | 0 | 20 |
| gray shale | 20 | 95 |
| broken limestone | 95 | 160 |
| Total Depth | | 160 |
| Casing: 6" A53B 18.97 from 0' to 108' | | |
| 5" A53B 14.62 from 100' to 140' | | |
| Grout: BENTONITE SLRY from 0 to 108. | | |
| Size hole below casing: 5" | | |
| Water from broken limestone at 120' to 160'. | | |
| Static level 30' below casing top which is 1' above GL | | |
| Pumping level 80' when pumping at 10 gpm for 4 hours | | |
| Owner Address: 10250 Olson Rd. Erie, IL | | |
| Address of well: 10146 Olson Rd. | | |
| Location source: Location from permit | | |

Permit Date: October 2, 1995

Permit #:

COMPANY Timmerman, Tom

FARM Ryan, Stephen & Ann

DATE DRILLED March 5, 1996

NO.

ELEVATION 0

COUNTY NO. 22065

LOCATION SE SW SW

LATITUDE 41.599281

LONGITUDE -90.051857

COUNTY Whiteside

API 121952206500

28 - 19N - 4E

