

Private Water Well	Top	Bottom
sand	0	19
fractured tan & white limestone	19	84
white shale w/tan limestone	84	95
tan & white limestone	95	157
Total Depth		157
Casing: 5" PVC from 0' to 96'		
Grout: BENTONITE GROUT 9.5# from 0 to 96.		
Water from rock at 95' to 157'.		
Static level 20' below casing top which is 2' above GL		
Pumping level 35' when pumping at 25 gpm for 1 hour		
Remarks: Driller's Est Yield 25 gpm w/air		
Owner Address: 10270 Lyman Rd / 1318 6th Ave Erie, IL		
Address of well: 10276 Lyman Rd		
Erie, IL		
Location source: Location from permit Verified by: GPS on .		

Permit Date: November 15, 2010

Permit #: 195-10-

COMPANY Albrecht, Harold Dean

FARM Wilkins, Mike

DATE DRILLED December 20, 2010

NO.

ELEVATION

COUNTY NO. 24126

LOCATION NE SW SW

LATITUDE 41.630517

LONGITUDE -90.049433

COUNTY Whiteside

API 121952412600

16 - 19N - 4E

