

Irrigation Well	Top	Bottom
top	0	2
clay/sand	2	16
clay	16	108
sand fine	108	134
sand, fine some medium	134	138
sand, fine	138	145
sand, fine medium	145	150
sand, fine medium some coarse	150	164
sand, medium coarse	164	175
sand, medium coarse fine gravel	175	194
Total Depth		194
Casing: 10" SDR 26 from 1' to 164'		
10" SCREEN from 164' to 194'		
Screen: 30' of 10" diameter .05 slot		
Grout: BENTONITE from 0 to 60.		
Grout: MINUS 1/8 from 60 to 194.		
Permanent pump installed at 100'		
on July 6, 2013, with a capacity of 750 gpm		
Owner Address: 209 Pittman Court Manlius, IL		
Address of well:		
Sheffield, IL		
Location source: Global Positioning System verified		
<div>Image viewing help: New users please read this.</div> <div> <div>GET FILE</div> <div>IL State Water Survey Document</div> </div> <div> <div>GET FILE</div> <div>IL State Water Survey Document</div> </div>		

Permit Date: November 26, 2012 Permit #: 011-065

COMPANY Henry, John
FARM Rasmussen, Glenn
DATE DRILLED July 2, 2013


NO.

ELEVATION COUNTY NO. 23500

LOCATION NE SW NE

LATITUDE 41.448326 LONGITUDE -89.768184

COUNTY Bureau API 120112350000 23 - 17N - 6E



GET FILE	IL State Water Survey Document
GET FILE	IL State Water Survey Document

Henry, John

Rasmussen, Glen

COUNTY Bureau

API 120112350000 23 - 17N - 6E