

Irrigation Well	Top	Bottom
12-20 slot sand	0	53
gray clay	53	78
coarse gravel 1/4"-2" w/20-60 slot	78	96
12-15 slot sand w/25% 20 slot	96	101
coarse sand & gvl 1/4"-2" w/20-60 slot s	101	113
Total Depth		113
Casing: 14" PVC from 0' to 93'		
Grout: BENTONITE GROUT 9.5# from 55 to 78.		
Grout: #2 GRAVEL PACK from 78 to 113.		
Water from sand at 78' to 113'.		
Static level 13' below casing top which is 2' above GL		
Pumping level 40' when pumping at 700 gpm for 1 hour		
Owner Address: 5111 Coleta Tampico, IL		
Address of well: 6812 Tampico Rd		
Tampico, IL		
Location source: Location from permit		

Permit Date: March 13, 2008

Permit #: 195-08-

COMPANY Albrecht, Harold Dean

FARM Wetzell, Mark

DATE DRILLED April 23, 2008

NO.

ELEVATION

COUNTY NO. 23905

LOCATION SW NE NW

LATITUDE 41.68195

LONGITUDE -89.781767

COUNTY Whiteside

API 121952390500

35 - 20N - 6E

