

Irrigation Well	Top	Bottom
fine sand	0	40
15-40 slot sand	40	52
fine sand	52	80
gray clay	80	100
10-12 slot sand	100	150
12-15 slot sand	150	165
15-20 slot sand	165	173
12-15 slot sand with 25% 20 slot	173	198
Total Depth		198
Casing: 14" PVC from 0' to 175'		
12" STAINLESS STL SCREEN from 175' to 195'		
Screen: 20' of 12" diameter 60 slot		
Grout: BENTONITE SLURRY from 0 to 100.		
Grout: #2 NORTHERN GRAVEL from 100 to 195.		
Water from sand at 173' to 198'.		
Static level 31' below casing top which is 2' above GL		
Pumping level 55' when pumping at 1000 gpm for 1 hour		
Permanent pump installed at 70'		
on June 14, 2006, with a capacity of 800 gpm		
Remarks: Driller's Estimated Well Yield 1000 gpm		
Owner Address: 331 East Liberty St. Walnut, IL		
Address of well: Freeport Rd.		
Deer Grove, IL		
Location source: Location from permit		

Permit Date: October 18, 2005

Permit #: 195-05-

COMPANY Harold Dean Albrecht

FARM Matthews, Donald (Gordon)

DATE DRILLED April 28, 2006

NO.

ELEVATION

COUNTY NO. 23731

LOCATION SW NE SW

LATITUDE 41.618292

LONGITUDE -89.664265

COUNTY Whiteside

API 121952373100

23 - 19N - 7E

