

Private Water Well	Top	Bottom
tan clay	0	17
gray clay	17	233
sand	233	237
gray clay	237	316
fine sand	316	331
green clay	331	335
sand 12-20 slot w/limestone	335	357
<b>Total Depth</b>		<b>357</b>
Casing: 4" STEEL from 0' to 350'		
2.5" STAINLESS STL SCREEN from 353' to 357'		
Screen: 4' of 2.5" diameter 12 slot		
Grout: BENTONITE from 0 to 200.		
Grout: #1 MUSCATINE from 200 to 357.		
Water from sand at 335' to 357'.		
Static level 230' below casing top which is 2' above GL		
Pumping level 250' when pumping at 5 gpm for 1 hour		
Remarks: Driller's Estimated Well Yield 5 gpm		
Owner Address: 2355 Shady Oaks Rd West Brooklyn, IL		
Address of well: same as above		
Location source: Location from permit		

Permit Date: May 14, 2007

Permit #: 103-029

COMPANY Albrecht, Harold Dean

FARM Maxwell, Gary

DATE DRILLED July 3, 2007

NO.

ELEVATION

COUNTY NO. 23809

LOCATION NE NW NE

LATITUDE 41.67072

LONGITUDE -89.173528

COUNTY Lee

API 121032380900

1 - 19N - 11E

