

Livestock Watering Well	Top	Bottom
sand & clay	0	3
yellow sand	3	27
brown clay	27	52
sand & gravel	52	54
brown clay	54	62
sand & gravel	62	68
sandy clay	68	71
brown clay	71	83
gray brown clay	83	98
limestone	98	455
limestone w/25 sulfur	455	468
limestone	468	557
Total Depth		557
Casing: 6" PVC from 0' to 118'		
" ST STL LINER from 118' to 557'		
Grout: 20% BENTONITE from 0 to 118.		
Grout: MUSCATINE from 118 to 557.		
Water from sand at 54' to 557'.		
Static level 265' below casing top which is 1' above GL		
Pumping level ' when pumping at 75 gpm for 1 hour		
Permanent pump installed at 360'		
on July 9, 2008, with a capacity of 55 gpm		
Remarks: Driller's Estimated Well Yield 75 gpm		
Owner Address: 11632 900 N Ave Buda, IL		
Address of well: 1100 E St		
Buda, IL		
Location source: Location from permit		

Permit Date: April 4, 2008

Permit #: 011-007

COMPANY Jet Hall/Lutes H2o Well Drlg.

FARM Ehnle, Gary

DATE DRILLED April 18, 2008

NO.

ELEVATION

COUNTY NO. 23286

LOCATION SW NW SW


LATITUDE 41.28206

LONGITUDE -89.644429

COUNTY Bureau

API 120112328600

13 - 15N - 7E



[Image viewing help: New users please read this.](#)

[GET FILE](#) IL State Water Survey Document

Jet Hall/Lutes H2o Well Drlg.

Ehnle, Gary

COUNTY Bureau

API 120112328600 13 - 15N - 7E