

Private Water Well	Top	Bottom
topsoil	0	1
yellow sandy clay	1	12
blue sandy clay	12	60
sand	60	75
gravel	75	100
blue clay	100	117
Niagara	117	150
Total Depth		150
Casing: 6" STEEL T&C from 0' to 133'		
Grout: BENTONITE from 0 to 133.		
Water from Niagara at 117' to 150'.		
Static level 30' below casing top which is 1' above GL		
Pumping level 80' when pumping at 25 gpm for 2 hours		
Remarks: well yield 25 gpm		
Owner Address: 1320 2nd St. S Cordova, IL		
Address of well: Springhill Rd.		
Location source: Location from permit		

Permit Date: June 21, 1999

Permit #: 195-99-

COMPANY Lyons, Larry

FARM Verkruysse, Kenneth

DATE DRILLED June 24, 1999

NO. 1

ELEVATION 0

COUNTY NO. 22529

LOCATION SW SW SE

LATITUDE 41.613562

LONGITUDE -90.044369

COUNTY Whiteside

API 121952252900

21 - 19N - 4E

