

Irrigation Well	Top	Bottom
silt and clay	0	26
sand	26	65
clay	65	108
fine sand	108	165
medium sand	165	200
<b>Total Depth</b>		<b>200</b>
Casing: 6" PVC from -1' to 180'		
6" PVC SCREEN from 180' to 200'		
Screen: 20' of 6" diameter .02 slot		
Grout: BENTONITE from 0 to 180.		
Water from sand at 165' to 200'.		
Static level 60' below casing top which is 1' above GL		
Pumping level 100' when pumping at 200 gpm for 1 hour		
Permanent pump installed at 80'		
on April 21, 2015, with a capacity of 85 gpm		
Remarks: Driller's Estimated Well Yield 200 gpm		
Owner Address: 3949 1945 N. Ave. Sheffield, IL		
Address of well: same as above		
Location source: Global Positioning System verified		

Permit Date: September 29, 2013 Permit #: 011-033

COMPANY White, Matt

FARM Gripp, Chad R.

DATE DRILLED August 26, 2014

NO.

ELEVATION

COUNTY NO. 23578

LOCATION NE NE SE

LATITUDE 41.428756

LONGITUDE -89.781761

COUNTY Bureau

API 120112357800

27 - 17N - 6E

