

Private Water Well	Top	Bottom
yellow clay	0	8
sand	8	17
gray clay	17	27
blue clay	27	92
sand	92	94
clay	94	102
sand	102	103
clay	103	105
sand	105	107
clay	107	111
sand	111	115
clay	115	121
sand & wood	121	124
clay	124	159
gray clay	159	166
fine Sankoty, wet @ 220'	166	220
med sand	220	230
coarse Sankoty	230	240
Total Depth		240
Casing: 4" SCH 40 PVC JET STRM from -1' to 236'		
Screen: 4' of 4" diameter 15 slot		
Grout: BENT CLAY SLRY from 0 to 230.		
Size hole below casing: 4"		
Water from Sankoty at 236' to 240'.		
Static level 109' below casing top which is 1' above GL		

Permit Date: June 21, 1995

Permit #:

COMPANY Thiery, Keith

FARM Hurley, Robert

DATE DRILLED July 21, 1995

NO.

ELEVATION 0

COUNTY NO. 22288

LOCATION NE NW NE


LATITUDE 41.423029

LONGITUDE -89.652021

COUNTY Bureau

API 120112228800

35 - 17N - 7E



Pumping level 111' when pumping at 0 gpm for 15 hours
Permanent pump installed at 148'

on July 24, 1995, with a capacity of 15 gpm

Remarks: old well sealed 7/25/1995

Owner Address: R.R. #1, Box #159 Wyanet, IL

Address of well: Co Rd #1900N

Location source: Location from permit

Thiery, Keith

Hurley, Robert

COUNTY Bureau

API 120112228800 35 - 17N - 7E