


Private Water Well	Top	Bottom
sand	0	24
gray sandy clay	24	42
10 slot sand	42	62
fine sand	62	109
sandy clay	109	137
fine sand	137	140
10 slot sand	140	146
<b>Total Depth</b>		<b>146</b>
Casing: 5" PVC SDR 21 from 0' to 140'		
3" SCREEN from 142' to 146'		
Screen: 4' of 3" diameter 10 slot		
Grout: BENTONITE 9.5#/GAL from 0 to 40.		
Grout: #1 MUSCATINE from 40 to 146.		
Water from sand at 137' to 146'.		
Static level 89' below casing top which is 2' above GL		
Pumping level 130' when pumping at 15 gpm for 1 hour		
Permanent pump installed at 134'		
on August 2, 2012, with a capacity of 10 gpm		
Remarks: Driller's Estimated Well Yield 15 gpm		
Owner Address: 10631 1400 N. Ave. Buda, IL		
Address of well: same as above		
Location source: Global Positioning System verified		
<div>Image viewing help: New users please read this.</div> <div> <div>GET FILE</div> <div>IL State Water Survey Document</div> </div> <div> <div>GET FILE</div> <div>IL State Water Survey Document</div> </div> <div> <div>GET FILE</div> <div>IL State Water Survey Document</div> </div> <div> <div>GET FILE</div> <div>IL State Water Survey Document</div> </div>		

Permit Date: July 30, 2012 Permit #: 011-038

COMPANY	Albrecht, Harold Dean			
FARM	Drawyer, Howard			
DATE DRILLED	July 31, 2012			
ELEVATION	COUNTY NO. 23466			
LOCATION	SW SW SE			
LATITUDE	41.352	LONGITUDE	-89.651167	
COUNTY	Bureau	API	120112346600	23 - 16N - 7E