Project: Municipal Recreation Courts, Four-Court Pickleball Facility with Three-Court Bid Alternate A-1. Project No. DP-001. Issued: October 20, 2026. Owner: Fictional Municipal Owner (demonstration only).

This Addendum modifies the Bidding Documents and Contract Documents. Where it conflicts with the Drawings, the Specifications or the Special Conditions, this Addendum governs. Acknowledge receipt on the Bid Schedules (Sheet C102).

ITEM 1 GATE G2 REVISED

1.1 Revise Gate G2 from a 6'-0" clear opening, single leaf, to a 12'-0" clear opening, double leaf (two 6'-0" leaves). Clear opening is face of gate post to face of gate post.

1.2 Make this revision on Sheet F502 Detail 2, the Sheet F502 Gate Schedule, Sheet C101 Keynote 6, Section 32 31 13 paragraph 2.5 and the Special Conditions.

1.3 Revise bid item 13 in the Special Conditions and on the Bid Schedules to read GATE G2, 144" WIDE (DOUBLE LEAF), 84" TALL. Measurement and payment are unchanged: per each.

1.4 Provide a center drop rod with ground sockets and a fork latch on the active leaf. Hinges are three per leaf. Provide one hold-back per leaf.

1.5 Gate post size and footing are unchanged: 2.875 in OD post with the terminal / gate footing, Detail 3/F501. Frame size and fabric are unchanged.

1.6 Gate G2 quantity is unchanged: two locations per option.

ITEM 2 QUESTIONS AND REQUESTS FOR INFORMATION

2.1 The question deadline remains 4:00 PM Central Time on October 23, 2026. The bid date remains 2:00 PM Central Time on October 30, 2026.

2.2 Responses to requests for information received to date will be issued by a later Addendum. This Addendum does not establish the clear opening width of Gate G3.

ITEM 3 WINDSCREEN

3.1 No change. The Owner will select the windscreen color after award.

END OF ADDENDUM NO. 01

FICTIONAL SYNTHETIC DEMONSTRATION - NOT FOR CONSTRUCTION. Issued for Bid (Synthetic). Prepared by IFI Labs / Synthetic CAD.