A Blockchain-Enabled Zero Trust Architecture for Industrial IoT Identity Management: Tiered Continuous Authorization and Quorum-Governed Revocation

Author Name[1], Author Name[2]
[1]Department of Computer Science, University Name, City, Country
[2]Department of Computer Science, University Name, City, Country
,

Abstract

Industrial plants combine long-lived devices, brownfield equipment that cannot hold cryptographic keys, several organizations with a stake in every asset, and requests whose consequences range from reading a temperature to rewriting a controller's program. Identity systems built on one certificate authority, session tokens or periodically refreshed revocation lists fit this setting poorly: a revoked device keeps working until a token expires or a list is refreshed, no single party is trusted by all to revoke it, and one trust threshold serves every request. This paper presents a blockchain-enabled Zero Trust architecture for Industrial IoT identity management. Three smart contracts on a permissioned proof-of-authority ledger hold device identities and status, a tiered access policy, and a quorum-voting revocation governance. The policy ties the evidence required to the criticality of the resource through per-resource thresholds, an anomaly hard gate and a strict mode for safety-relevant writes. Zone gateways decide routine requests locally against replicated ledger state and anchor Merkle roots of their decision logs, while high-consequence requests are decided on-chain; batch revocation supports firmware recalls. We prove immediate revocation on the on-chain path, a bounded exposure on the fast path, replay resistance, attestation unforgeability, key-reuse prevention and governance safety and liveness, and characterize exactly when a spoofing attacker is accepted. Measured on an Ethereum Virtual Machine, registration costs about 215k gas, an on-chain decision about 70k, anchoring 54 gas per decision, and a quorum revocation 313k–800k gas for 5–21 voters; batching lowers recall gas by about 40%. On a synthetic industrial fleet the on-chain path accepted no request after revocation, against 33–147 for token and list baselines, and the gate and strict mode cut full-spoof acceptance to zero at the two most critical tiers at the price of 2.2–5.2% of legitimate requests, while a stealthy mimic was still accepted in 60.9% and 13.6% of cases. Results are compute-bound, exclude network and consensus delay, and rest on synthetic signals. Code and data are released.

Index Terms—Industrial IoT, Zero Trust Architecture, Blockchain, Decentralized Identifiers, Identity Management, Smart Contracts, Revocation Governance, Operational Technology.

1 Introduction

1.1 Motivation

An industrial plant is a poor fit for the assumptions behind most identity systems. Its devices live for fifteen or twenty years, speak protocols that predate public-key cryptography, sit behind process-critical networks that cannot be rebooted at will, and are administered by several organizations at once: the operator who runs the line, the original manufacturer who ships firmware, an integrator who commissioned the cell, and sometimes an outside maintenance contractor. Guidance for operational technology (OT) security is explicit that availability and safety, not confidentiality, usually dominate the design space, and that a control that interrupts a process can be worse than the attack it prevents [1]. At the same time the attack surface has widened, because IT–OT convergence connects field assets to analytics, remote support and cloud services. Zero Trust, which drops trust based on network location and demands that every access be authenticated, authorized and re-evaluated [2, 3, 4], is a natural response, and early proposals adapt it to critical OT systems [5, 6].

Identity is where the difficulty concentrates. A conventional public-key infrastructure gives each device a certificate and relies on revocation lists or short certificate lifetimes to withdraw it. In a multi-party plant, however, there is rarely one party that every other party is willing to let revoke a controller, and the delay between the decision to withdraw a device and the moment every gateway honours it is exactly the window in which a compromised or recalled device keeps working. Blockchain-based identity management addresses the first problem by anchoring identifiers, keys and status on a tamper-evident ledger that several organizations operate together, following the decentralized-identifier (DID) model [7, 8, 9, 10]. Recent industrial work builds authentication on this foundation [11], and surveys of blockchain for Industrial IoT (IIoT) catalogue its promise and its open problems [12]. Studies that combine blockchain with Zero Trust have followed [13, 14, 15, 16, 17, 18, 19].

1.2 Problem Statement and Gap

Reading this literature with an operator's eye, three things are missing. First, most blockchain-IoT identity schemes still authenticate once and then treat the session as trusted, which is

precisely what Zero Trust is meant to remove [20, 21]; and the Zero Trust proposals for industrial settings generally assume one organization owns the policy decision point [22, 6]. Second, a single trust threshold is applied to every request, although reading a temperature and rewriting a safety-controller setpoint carry very different consequences; and, as we show analytically and experimentally, a fixed threshold on a weighted score can be unreachable by an attacker who spoofs most of the signals. Third, nearly all of these designs implicitly place every decision on the ledger, which cannot meet the rates and latency of plant networks, and none of them says how a manufacturer's firmware recall, a legacy device that cannot hold a key, or a lost connection to the ledger should be handled. We therefore ask:

How can a consortium-operated blockchain identity registry be combined with continuous, consequence-aware authorization so that (i) revocation, including large-scale firmware recalls, takes effect without a token or list-refresh window and without any single party being able to impose it, (ii) the strength of verification scales with the criticality of the resource, and (iii) the enforcement path stays fast, available and auditable on industrial networks?

1.3 Contributions

This paper makes the following contributions.

- **Architecture.** A zone-aware design (Section 4) with three smart contracts (identity registry, Zero Trust access policy, quorum revocation governance), a tiered policy model that ties the required trust to the criticality of the target resource, an anomaly hard gate and a strict mode for safety-relevant writes, a protocol-gateway identity proxy for legacy devices, and batch revocation and quarantine for firmware recalls.
- **Hybrid enforcement.** A two-path decision model: a fast path in which a zone gateway decides locally against replicated ledger state and anchors a Merkle root of its decision log, and an audited path in which high-consequence requests are decided by the contract itself (Section 4.5).
- **Analysis.** A threat model for plant environments and six proved properties, including a bound on how long a revoked device can still be accepted on the fast path and a result that exactly characterizes what the anomaly gate does and does not stop (Sections 3–5).
- **Open implementation and measurement.** Solidity 0.8.24 contracts executed on an EVM with measured gas for every operation, including recall and anchoring, plus a Python testbed using real Ed25519 signatures. Experiments report confidence intervals, a revocation-exposure comparison against token and CRL baselines, per-tier attack and false-denial rates, a gate sensitivity study, quorum-governance behaviour for 5–21 voters and recall capacity (Section 7). We state plainly which results are compute-bound and synthetic.

2 Related Work

2.1 Zero Trust for Industrial and OT Systems

Zero Trust architecture is by now well surveyed for IoT. Azad et al. cover continuous verification and micro-segmentation [23], James et al. review authentication and authorization schemes specifically under a Zero Trust model [21], and Nahar et al. examine the 6G setting, where device density sharpens per-request overhead concerns [24]. Fernández and Brazhuk caution that "Zero Trust" is sometimes a label without a falsifiable architecture behind it [3], and Phiayura and Teerakanok supply a migration framework with a maturity model [4]. For OT in particular, Song et al. propose a Zero Trust architecture for critical operational technology systems [5], Zanasi et al. a flexible architecture for IIoT [6], and Kumar and Sharma integrate blockchain with dynamic access control for Industry 4.0 without a DID-anchored registry [22]. These works establish the principles; they leave open who owns revocation in a multi-party plant and how a decision should be audited afterwards.

2.2 Blockchain Identity and Authentication for IIoT

Surveys of blockchain-based decentralized identification note limits around revocation latency and interoperability [8], and a broad review of blockchain in IIoT discusses security and privacy opportunities alongside scalability and integration costs [12]. Aguru and Erukala propose a blockchain self-sovereign-identity framework for standardized IoT identification [9], Folino et al. tie identity to a physically unclonable function as a hardware root of trust [10], and Ren et al. combine self-sovereign identity with Zero Trust for AIoT using selective-disclosure credentials [25]. On the industrial authentication side, Zhai et al. design a lightweight scheme for IIoT that combines blockchain with Chebyshev chaotic maps to suit constrained devices [11]. DAXiot shows that DID challenge–response for MQTT can run without a blockchain at about 21% connection overhead over mutual TLS, but then has no shared revocation ledger [26]. For revocation itself, Mazzocca et al. propose EVOKE, a cryptographic-accumulator mechanism with about 1.5 KB of per-device state that spreads revocation epidemically among devices [27]; it complements an on-chain status check rather than replacing it. Kumar et al. run a privacy-preserving identity system on a private Ethereum proof-of-authority (PoA) chain in which a decentralized voter group governs identity updates and revocations, and report roughly 3–4 s for registration and under 5 s for revocation on the live network [28]; it is the closest published precedent for our governance contract and the only live-chain figure we compare against.

2.3 Blockchain–Zero Trust Combinations

Nie et al. pair smart-contract policy enforcement with inner-product encryption for fine-grained access in 6G IoT [14]. Salim et al. propose ZT-BlocIoT with dynamic trusted gateways and reinforcement-learning-driven sharding, reporting 2,500 transactions per second on 700 nodes at 42 ms latency [15]. Wang et al. observe that even Zero Trust–inspired schemes for medical IoT typically authenticate once and then trust the session, and propose blockchain-backed continuous authentication [20]; the same gap is what motivates our per-request design in industry. Mukta et al. delegate Zero Trust access control through a blockchain, which is close to our policy layer but concerns delegation rather than the device identity lifecycle [16]. For smart factories, Farhan et al. describe a conceptual Zero Trust framework on a consortium chain [18],

and Potturi et al. combine AI risk scoring with blockchain-anchored federated identity across cloud, edge and IoT [19]. Jamwal et al. conclude that blockchain-enabled Zero Trust is still mostly proposed at survey level rather than delivered as benchmarked open code [17], and a bibliometric analysis finds blockchain with Zero Trust identity management to be one of the field's most active clusters [13]. Usama et al. add decentralized identity, zero-knowledge proofs and Byzantine-resilient federated learning against AI-driven identity attacks [29]. Federated learning is also studied as a way to share threat intelligence across industrial sites without exposing raw data [30]; we do not use it, but it is a plausible source for the anomaly signal in Section 4.4.

2.4 Off-Chain Dependencies, Cost and Oracles

Because on-chain controls rest on off-chain facts, the reliability of the data that reaches a contract matters. Shujaa et al. stress that device attestation, secure boot and key custody remain off-chain dependencies of any blockchain-IoT security design [31], and Hassan et al. survey the oracle problem, that is, how to bring trustworthy external data to a contract [32]; our trust oracle is an instance of it, and Section 8 discusses its single-key weakness. Smart-contract defects are another risk, reviewed by Wei et al. [33]. On cost, gas has been studied for Ethereum smart contracts [34] and for IoT access control [35], DPoS and PBFT-based consensus choices have been proposed for IoT and clinical settings [36, 37], and gasless relaying can spare constrained devices from paying fees [38]. Ren et al. show for vehicular networks that published trust values can themselves link pseudonyms and propose differential privacy to prevent it [39], which matters for any design that exposes scores on a shared ledger.

2.5 Positioning

Table 1 compares the most relevant systems on five properties that matter in a plant: on-chain revocation, continuous per-request authorization, consequence-aware (tiered) policy, handling of legacy and recall scenarios, and a released artifact. The assessments rest on the abstracts and the parts of the full texts we could read; "not stated" means we found no statement, not that the property is absent. To our knowledge none of the reviewed systems reports all five.

3 Industrial Requirements, System and Threat Model

3.1 Requirements Specific to Industrial Settings

Translating the generic Zero Trust and blockchain-identity goals into a plant yields six requirements that drive the design; they are our reading of OT security guidance [1] and of the identity literature surveyed above, not a standard.

- **R1 Multi-party authority.** No single organization (operator, manufacturer, integrator) should be able to unilaterally revoke or reinstate a device.
- **R2 Consequence-aware verification.** The evidence required before a request is accepted must grow with the consequence of the target resource: reading telemetry is not rewriting a controller's program.
- **R3 Predictable, available enforcement.** The common-case decision must be fast and must not depend on the ledger being reachable; consensus latency is acceptable only for rare, high-consequence actions.
- **R4 Brownfield coexistence.** Devices that cannot hold a key or run a signature scheme must be representable without weakening the identities of those that can.
- **R5 Recall at fleet scale.** Withdrawing a vulnerable firmware generation must be possible for thousands of devices in a bounded number of blocks.
- **R6 Auditability.** Every decision, including those taken locally for speed, must be attributable and tamper-evident after the fact.

Scope. We target the supervisory, engineering and maintenance plane: historian writes, setpoint changes, program and firmware downloads, and telemetry reads. Hard real-time cyclic I/O between a controller and its field devices, with millisecond or microsecond determinism, is outside the scope: per-message authorization there would be inappropriate, and such traffic remains protected by segmentation and by device-level mechanisms that this architecture only complements.

3.2 System Model and Assumptions

Devices $\mathcal{D}$ hold signing keys (sk_i, pk_i) generated at commissioning, except for a *legacy* subset that is represented by a protocol gateway holding a proxy identity. Zone gateways act as Policy Enforcement Points (PEPs). A trust oracle $\mathcal{O}$ with key $sk_{\mathcal{O}}$ attests the context signals. A registrar role is held by a provisioning service, and an optional set of N voters (for example the manufacturer, the operator and an auditor) governs revocation. A consortium of V validators runs a permissioned PoA chain. We assume:

- **A1 (ledger integrity).** Fewer than half of the validators are Byzantine, so finalized state is immutable and visible to subsequent contract calls.
- **A2 (cryptography).** Ed25519 and ECDSA over secp256k1 are existentially unforgeable under chosen-message attack (EUF-CMA); SHA-256 and Keccak-256 are collision resistant.
- **A3 (key custody).** A device key stays secret until the adversary compromises that device. Attestation, secure boot and key custody are off-chain dependencies the ledger cannot enforce [31].
- **A4 (role keys).** The policy-administrator and oracle keys are uncompromised, and at most $q - 1$ voter keys are compromised.
- **A5 (replica freshness).** A zone replica applies each finalized registry event within Δ seconds of finality. Δ is an operational parameter (for example the block interval plus a polling or subscription delay), not a protocol guarantee.

3.3 Adversary Model and Security Goals

The adversary controls the network between devices and PEPs (observe, replay, drop, inject), may compromise a bounded set of devices and obtain their keys, may enrol devices of its own,

Table 1: Comparison of representative blockchain and Zero Trust systems for (I)IoT identity

System	Core mechanism	On-chain revocation	Per-request authZ	Tiered policy	Legacy / recall	Open artifact
Zhai et al. 2025 [11]	Blockchain + Chebyshev-map authentication (IIoT)	Not stated	Not stated	Not stated	Lightweight devices	Not stated
Song et al. 2025 [5]	ZTA for critical OT	Not stated	Not stated	Not stated	Not stated	Not stated
Zanasi et al. 2024 [6]	Flexible IIoT ZTA	No	Yes	Partial	Not stated	Not stated
Kumar & Sharma 2024 [22]	Blockchain + dynamic access control (Industry 4.0)	Not stated	Yes	Not stated	Not stated	Not stated
Farhan et al. 2026 [18]	ZT on consortium chain (smart factory)	Conceptual	Conceptual	Not stated	Not stated	Not stated
Potturi et al. 2026 [19]	AI risk score + chain-anchored identity	Yes	Yes	Not stated	Not stated	Not stated
Salim et al. 2026 [15]	ZT-BlocIoT (trust + DRL sharding)	Yes	Yes	Not stated	Not stated	Not stated
Nie et al. 2025 [14]	ZT + inner-product encryption (6G)	Yes	Yes	Fine-grained attributes	Not stated	Not stated
Wang et al. 2026 [20]	Blockchain continuous auth. (medical IoT)	Yes	Yes	No	Not stated	Not stated
Kumar et al. 2026 [28]	Private PoA identity + voter group	Yes (voter group)	Not stated	No	Not stated	Not stated
This work	**DID registry, tiered ZT contracts, quorum governance, hybrid enforcement**	**Yes (quorum-governed, batch)**	**Yes (every call)**	**Yes (4 tiers, gate, strict)**	**Proxy identity; batch recall; outage mode**	**Yes (Solidity + Python)**

Table 2: Threat model: adversary actions, mitigations and evidence

Threat	Mitigation	Evidence
T1 Replay	Nonce set (audited) or monotonic counter (fast path)	Prop. 3; Sec. 7.9
T2 Impersonation / forgery	Signature checked against on-chain key	Sec. 7.9
T3 Use after revocation	Status first on every call; terminal REVOKED	Props. 1, 2; Sec. 7.7
T4 Re-enrolment of a revoked key	Key-hash blacklist	Prop. 5
T5 Self-declared trust or tampered anomaly value	Oracle signature over $(\mathrm{did}, \mathrm{res}, T, A, \mathrm{nonce})$	Prop. 4
T6 Signal spoofing / mimicry	Bounded signal weights, anomaly gate, strict tiers	Prop. 7; Secs. 7.5, 7.6
T7 Insider revokes or reinstates at will	Quorum governance	Prop. 6; Sec. 7.10
T8 Legacy device impersonated behind a gateway	Proxy identity limited to low tiers	Sec. 4.3
T9 Ledger or replica outage	Tier-dependent degraded mode	Sec. 4.8
T10 Validator collusion, oracle compromise	Out of scope (A1, A4)	Sec. 8

and controls the context signals reported by a device it has compromised. It cannot break A1–A5. In addition, we consider an *insider*: a single organization that holds the registrar role and tries to revoke or reinstate devices for its own advantage. Table 2 maps threats to mitigations and evidence.

The goals are: **G1** no request is accepted from a revoked, suspended or unknown identity, immediately on the audited path and within Δ on the fast path; **G2** each request is accepted at most once; **G3** a device cannot raise its own trust or lower its own anomaly value; **G4** a compromised key cannot be reused under a new identity; **G5** the effect of any single context signal, and the conditions under which a spoofing attacker is accepted, are known exactly; **G6** fewer than q voters cannot revoke a device, and fewer than $N - q + 1$ cannot block a revocation that q voters approve; and **G7** every decision, including fast-path ones, is covered by an anchored commitment.

4 Proposed Architecture

4.1 Overview

Figure 1 shows the design. Devices and a protocol gateway sit in the field zone; the zone PEP enforces decisions; the trust engine (policy decision point, PDP), trust oracle and a local replica of the chain state sit in the site operations zone; and the three contracts are operated by the consortium. The PEP/PDP split follows the classical Zero Trust reference model [2, 3], but the policy store and the identity registry are held by the consortium rather than by one site, so that no gateway can edit another stakeholder's view of a device.

4.2 Identity Lifecycle and the Registry

A device derives a DID from its public key in the style of the W3C data model [7], $\mathrm{did} = \texttt{did:iot:}\,\mathrm{H}(pk)[0{:}32]$, with SHA-256 in the testbed and Keccak-256 in the Solidity track. Commissioning submits pk (or its hash), a device class, and a hash of the declared attributes (firmware version, vendor, location), signed by sk so that the record proves key possession without exposing the attributes. The registry is a state machine:

$$\text{UNKNOWN} \xrightarrow{\text{register}} \text{ACTIVE}$$

$$\text{ACTIVE} \xrightarrow{\text{suspend}} \text{SUSPENDED} \xrightarrow{\text{reinstate}} \text{ACTIVE}$$

$$\text{ACTIVE or SUSPENDED} \xrightarrow{\text{revoke}} \text{REVOKED (terminal)}$$

REVOKED is terminal, and revocation also blacklists the key hash, so the same key cannot be enrolled under a new DID. Suspension is the reversible quarantine used while an advisory is assessed. All transitions are restricted to the registrar role and emit indexed events, which zone replicas and security monitoring consume.

4.3 Legacy Devices Behind a Protocol Gateway

Brownfield equipment often cannot sign requests. We represent each such device by a DID derived from the *gateway's* key and the device's local address, registered with the class `legacy`. The gateway signs on its behalf and supplies weaker posture evidence (the testbed draws legacy posture from a




Figure 1: Architecture of the blockchain-enabled Zero Trust system for Industrial IoT identity management, organized by plant zone.

Table 3: Criticality tiers used in the evaluation

Tier	Example resource	θ	m	g	Classes
T0	telemetry.read	0.50	0.10	1.00	all, incl. legacy
T1	historian.write	0.55	0.10	0.60	all but HMI
T2	plc.setpoint.write†	0.70	0.05	0.30	HMI, PLC, robot
T3	plc.firmware.update†	0.78	0.04	0.20	PLC, robot

† strict: borderline scores are denied rather than stepped up.

lower range than native devices). Two rules keep this from lowering the security of the whole plant: the class check admits `legacy` identities only to low-consequence resources (tiers T0–T1 in our policy), and revoking the gateway key revokes every proxied identity at once. The trade-off is explicit: a compromised gateway can speak for every legacy device behind it, which is why this class never reaches the strict tiers.

4.4 Tiered Zero Trust Policy

Each resource has a policy $\pi = (\theta, m, g, s, \mathcal{C}, \tau_{\max})$: a minimum trust θ, a step-up margin m, an anomaly hard gate g, a strict flag s, a set of permitted device classes $\mathcal{C}$ and a maximum idle time $\tau_{\max}$. Table 3 lists the four tiers used in our evaluation. The parameters are illustrative and tuned by hand to our synthetic signal ranges; a real plant would set them from its own telemetry and risk assessment.

The trust score combines four signals in $[0, 1]$: device posture P (attested firmware and configuration state), behavioural anomaly A, network context N and historical reliability R (mean of the last ten scores, 0.6 for a new device),

$$T = w_p P + w_b(1 - A) + w_n N + w_r R, \qquad (1)$$

with default weights $(w_p, w_b, w_n, w_r) = (0.30, 0.30, 0.20, 0.20)$. The signals come from the PEP and from monitoring that the plant already operates; in practice A could be produced by process-aware anomaly detection, possibly trained across sites without sharing raw data [30]. We treat their production as an input and evaluate only how the policy handles them. The oracle signs $(\text{did}, \text{res}, T, A, \text{nonce})$; including A in the signed message is what lets a contract enforce the gate without trusting the device's own report.

Algorithm 1 `evaluateAccess(did, res, class, T, A, nonce, sig)`

1. **if** status(did) $\neq$ ACTIVE **or** no policy for res **then return** DENY
2. **if** (did, nonce) already used **then return** DENY; mark it used
3. **if** class $\notin \mathcal{C}$ **then return** DENY
4. **if** oracle signature over (did, res, T, A, nonce) is invalid **then return** DENY
5. **if** $A > g$ **then return** DENY *(anomaly gate)*
6. **if** $T < \theta$ **then return** DENY
7. **if** $T < \theta + m$ **then return** (**if** strict **then** DENY **else** STEP_UP)
8. **return** ALLOW

The gate and the strict flag address a specific weakness of weighted scores that Proposition 7 makes precise: because the score is linear, an attacker who spoofs posture, network and reliability can hold T high no matter how abnormal its behaviour is, so for consequential resources the anomaly signal must be able to veto independently of the sum. For a step-up, we leave the second-factor mechanism to the plant (for example a local operator confirmation); STEP_UP is never returned for strict resources.

4.5 Hybrid Enforcement: Fast Path and Audited Path

Running Algorithm 1 on the chain for every request would cap throughput at what a block can carry and would couple plant operations to consensus latency. We therefore split enforcement by tier.

- **Fast path (T0, T1).** The zone PEP decides locally against its replica: status and key from the registry events, a per-device monotonic counter in place of the nonce set, the device's request signature, the oracle's attestation and the tier policy. Each decision appends a leaf to a log; every B decisions the PEP computes a Merkle root and anchors it with `anchorDecisions(root, count)`, which only authorized PEP addresses may call. An auditor can later check any single logged decision against the anchored root.
- **Audited path (T2, T3).** The request is decided by `evaluateAccess` on the chain, so the decision, its in-

puts and its outcome are themselves on the ledger. These resources are written rarely and under operator control, which is what makes the cost acceptable; if a plant's setpoint writes are frequent, this assumption fails and the tiers must be recut.

The price of the fast path is the replica lag Δ of assumption A5: a device revoked just before a request may still be accepted for tier T0–T1 resources until the replica catches up (Proposition 2). The audited path has no such window.

4.6 Firmware Recall and Quarantine

When a vulnerability is disclosed in a firmware generation, the manufacturer needs to withdraw every affected device quickly. `revokeBatch(dids, reason)` revokes many devices in one transaction, skips unknown or already-revoked entries rather than reverting (so one stale entry cannot block a recall), blacklists each key and emits one event per device; `suspendBatch` quarantines them reversibly. The batch is limited by the block gas limit, and Section 7.8 measures its per-device gas and the number of blocks needed for fleets of 10^3–5×10^4 devices.

4.7 Decentralized Revocation Governance

A single registrar can deny service to legitimate devices, or reinstate a dangerous one. `RevocationGovernance` mediates `revokeDevice()` through threshold voting among N independent voters, in the spirit of the voter group of [28]. A voter calls `propose(did, reason)`; each voter casts one `castVote(id, approve)`. The proposal executes the revocation as soon as approvals reach $q = \lfloor N/2 \rfloor + 1$, and is finalized as rejected once denials exceed $N - q$. The governance contract holds the registrar role on the registry; time-critical actions that a signed vendor bulletin pre-authorizes may use the direct path, so the two paths coexist. Votes are non-transferable, one per voter, and DENY votes never count toward approval.

4.8 Degraded Operation During an Outage

If a PEP loses its replica feed, it must pick between availability and safety. Our policy is tier-dependent: T0–T1 requests continue against the last known state (accepting that a device revoked during the outage is not yet known), while audited-path requests (T2–T3) are *denied*, because their decision needs the chain. This is fail-closed for consequential writes and fail-operational for reads; whether an operator accepts that trade is a plant decision, and Section 7.11 quantifies it for a simple scenario.

5 Security Analysis

The contracts are deterministic state machines, so the proofs are short; they establish that the logic meets goals G1–G7 under A1–A5, not that a deployment is secure.

5.1 Security Properties

Proposition 1 (Immediate revocation on the audited path, G1)**.** *If `revokeDevice(did)` (or `revokeBatch` containing `did`) is in a finalized block, every later call to `evaluateAccess` for `did` returns DENY.*

Proof. By A1 the call sees finalized state with $\mathrm{status}(\mathrm{did}) =$ REVOKED. No function leaves REVOKED, and step 1 of Algorithm 1 runs before every other check and denies all non-ACTIVE statuses. □

Proposition 2 (Bounded exposure on the fast path, G1)**.** *Let a revocation finalize at time t_f and let a PEP satisfy A5. A fast-path request evaluated at time $\tau \geq t_f + \Delta$ is denied. If the device submits at most ρ accepted requests per second, at most $\rho\Delta$ requests are accepted after t_f.*

Proof. By A5 the replica shows status REVOKED from $t_f + \Delta$ on, and the fast path denies non-ACTIVE devices before any other check. Requests accepted after t_f therefore fall in $[t_f, t_f + \Delta)$, which holds at most $\rho\Delta$ of them. □

Proposition 3 (Replay resistance, G2)**.** *For a single PEP and any (did, c) with c a nonce (audited) or counter value (fast path), at most one evaluation returns ALLOW or STEP_UP.*

Proof. Audited path: the test-and-set of the used-nonce flag is one transaction and transactions execute serially, so a second evaluation sees the flag and denies at step 2. Fast path: the PEP accepts only counters greater than the stored maximum and then stores the new value, so a repeated or older counter is denied. In a multi-PEP zone, the PEP identity must be bound into the signed message so that a request captured at one PEP is useless at another; our testbed exercises a single PEP. □

Proposition 4 (Attestation unforgeability, G3)**.** *A PPT adversary without $sk_{\mathcal{O}}$ obtains ALLOW or STEP_UP for a pair (T, A) not attested by $\mathcal{O}$ for that request only with negligible probability.*

Proof. Steps 5–8 are reached only after the signature over $(\mathrm{did}, \mathrm{res}, T, A, \mathrm{nonce})$ verifies under $pk_{\mathcal{O}}$. Producing a different (T, A) with a valid signature is an EUF-CMA forgery (A2). The nonce is inside the message, so an attestation cannot be moved to another request. Changing only A (for example, reporting a lower anomaly) changes the signed message, which the contract tests demonstrate. □

Proposition 5 (Key-reuse prevention, G4)**.** *After a finalized revocation, `registerDevice` with the same key hash reverts.*

Proof. Revocation sets $\mathrm{revokedKey}[\mathrm{H}(pk)]$, and registration reverts on that flag. Since the DID is a function of $\mathrm{H}(pk)$, a new identity needs a new key, which the adversary lacks unless it compromised another device. □

Proposition 6 (Governance safety and liveness, G6)**.** *With N voters and quorum q: (a) a revocation executes only if at least q distinct voters approved; (b) a set of at most $N - q$ voters cannot stop a proposal that the other q approve; (c) a coalition of at most $q - 1$ voters cannot execute a revocation.*

Proof. (a) `hasVoted` blocks repeats and `isVoter` blocks outsiders; the approval counter reaches q only with q distinct approvals, and only then is `revokeDevice` called. (b) Denials end a proposal only when they exceed $N - q$, which at most $N - q$ dissenters cannot, so the q approvers can always complete. (c) Fewer than q approvals never trigger execution. Safety additionally requires that no other registrar path exists for the affected devices. □

Proposition 7 (Spoofing, the gate and strictness, G5)**.** *(a) If scores T, T' differ only in signal s_j with weight w_j, then $|T - T'| \le w_j$. (b) On a resource with gate g, every ALLOW satisfies $A \le g$. (c) On a strict resource, every ALLOW satisfies $T \ge \theta + m$. (d) For an attacker with $P = N = R = 1$, $T = 1 - w_b A$, and it is accepted on a strict resource if and only if $A \le \min\{g, (1 - \theta - m)/w_b\}$.*

Proof. (a) $T - T' = w_j(s_j - s'_j)$ and $|s_j - s'_j| \le 1$. (b) and (c) are steps 5 and 7 of Algorithm 1. (d) Substituting gives $T = 0.3 + 0.3(1 - A) + 0.2 + 0.2 = 1 - 0.3A$, and ALLOW needs $A \le g$ and $T \ge \theta + m$. □

Corollary (what a fixed threshold cannot do). With the default weights a fully spoofing attacker has $T \ge 0.70$ even at $A = 1$. Hence on a non-strict resource with $\theta = 0.55$ and no gate, *no* anomaly value gets such an attacker denied, and for the tiers of Table 3 the bound $(1-\theta-m)/w_b$ is 0.83 (T2) and 0.60 (T3), above the gates 0.30 and 0.20; the *gate*, not the score, is what stops the attacker, and the residual risk is exactly the set of attackers who keep $A \le g$. The experiments of Section 7.6 measure how that residual behaves.

5.2 Residual Risks

The properties say nothing about (i) compromised validators or oracle keys (A1, A4); (ii) a stolen key used by an attacker who behaves like the owner until revoked, which no continuous scheme separates from the owner except by behaviour; (iii) side-channel extraction of keys; or (iv) smart-contract defects, for which the quality-assurance literature recommends testing, verification and audit [33]. Also, the trust oracle is a trusted data source, which is the blockchain-oracle problem in a specific form [32]; a threshold-signed oracle would reduce it (Section 8). Finally, the nonce set costs one storage slot per accepted audited request and needs epoch-based pruning in a long-lived deployment.

6 Prototype Implementation

6.1 Two Tracks

Track A – Solidity on an EVM. `IdentityRegistry.sol`, `ZeroTrustAccess.sol` and `RevocationGovernance.sol` (Solidity 0.8.24, optimizer 200 runs) implement Section 4: the status machine, Algorithm 1 with anomaly gate and strict mode, `revokeBatch`/`suspendBatch`, PEP-authorized root anchoring, and quorum voting. They are compiled with solc-js and executed on the Hardhat in-process EVM. A Mocha/Chai suite of 13 tests passes; besides the registry, replay, revocation and governance cases it covers the industrial additions: the gate denies a high composite score when $A > g$, a tampered anomaly value invalidates the oracle signature, strict resources never step up, batch revocation skips unknown entries and blocks later access, and only authorized PEPs can anchor. Scripts measure gas for every operation. This track gives real gas but *not* multi-node consensus or network latency, and the device's request signature is verified by the PEP rather than on-chain.

Track B – Python testbed. A Python implementation of the same state machine uses real Ed25519 (the `cryptography` library), SHA-256 and a Merkle root. Besides the contract model it contains the `FastPathPEP`, which verifies the device signature and the oracle attestation (two Ed25519 verifications), applies the per-device counter and tier policy, and logs decisions in Merkle-rooted batches. It is used for scale, statistical, baseline, tier and governance experiments. The host is a 2-vCPU Linux container (Python 3.13, Hardhat 2.22); all seeds derive from 20261004. Track B uses Ed25519 whereas Track A uses secp256k1 ECDSA, so their timings are not comparable.

6.2 Industrial Fleet and Signal Model

The synthetic fleet has six classes with proportions sensor 40%, PLC 15%, HMI 8%, robot 7%, gateway 15% and legacy 15%. Native devices draw posture in $[0.75, 1]$, anomaly in $[0, 0.15]$ and network context in $[0.7, 1]$; legacy devices draw posture in $[0.55, 0.75]$, anomaly in $[0, 0.20]$ and network in $[0.6, 0.9]$. To mimic process upsets, a fraction of legitimate requests (5% by default; 0, 5 and 15% in the sensitivity study) draws anomaly from $[0.15, 0.45]$. Four attack populations are used: *naive compromise* (all signals degraded), *partial mimicry* (posture and network legitimate, $A \in [0.3, 0.7]$), *stealthy mimicry* ($A \in [0.15, 0.40]$) and *full spoof* ($P = N = 1$, $A \in [0.3, 0.7]$); each starts from three clean prior requests. The legacy gateway of Section 4.3 is modelled through the class `legacy` and its weaker signals; deriving proxy DIDs from the gateway key is a design element we did not implement. All distributions are our assumptions, not field measurements, and the attack and legitimate ranges overlap by construction, so the experiments show how the policy responds to such overlap rather than how well a detector would perform in a plant.

6.3 Experiment Scenarios and Reproducibility

Carried over from the base design: (S1) scaling over $n \in \{50, \ldots, 1600\}$; (S2) 500 trials per basic attack; (S3) 30 repeated runs at $n = 400$; (S4) baseline revocation exposure for 60 devices at 1 request/s over 600 logical seconds with revocation times from $U(100, 500)$ s; (S5) governance with 200 trials per $N \in \{5, \ldots, 21\}$ under cooperation, maximal dissent and forced revocation; and a trust-signal ablation. *Industrial additions:* (X1) tiered policy on the mixed fleet, 4,000 requests per population; (X2) anomaly-gate sweep; (X3) fast path versus modelled on-chain path, 10 runs of 2,000 requests over 300 PLC and robot devices; (X4) recall capacity from measured gas; and (X5) outage scenario. The commands are `python -m sim.benchmark`, `sim.experiments_extra`, `sim.experiments_governance`, `sim.experiments_iiot` and `hardhat run scripts/measure_gas.js`, `measure_governance_gas.js`, `measure_iiot_gas.js`; `paper/gen_tables.py` regenerates every table from the resulting JSON files.

7 Experimental Evaluation

7.1 Methodology and What the Numbers Mean

We report decision latency and throughput, on-chain gas, revocation exposure (requests accepted after the revocation instant), per-tier acceptance of legitimate and attacking requests, quo-

Table 4: Scaling results, one run per fleet size (latency in ms, throughput in ops/s)

n	Reg. lat.	AuthZ lat.	AuthZ p95	Reg. tput	AuthZ tput
50	0.286	0.184	0.216	3,477	3,812
100	0.282	0.197	0.236	3,539	3,679
200	0.256	0.125	0.148	3,906	5,909
400	0.173	0.120	0.143	5,755	6,159
800	0.177	0.127	0.162	5,645	5,804
1,600	0.175	0.126	0.153	5,693	5,879

rum behaviour, recall capacity and a degraded-mode scenario. Latencies are wall-clock times from a monotonic timer. Three limits apply throughout. (i) Testbed numbers are *compute-bound*: they exclude network, block time and multi-node consensus. (ii) Devices, signals and attacks are *synthetic*, so detection-type results characterize policy mechanics under the stated overlaps, not accuracy on real plants. (iii) One two-vCPU host was used.

7.2 Testbed Performance and Repeated-Run Statistics

Table 4 gives one run per fleet size. Mean authorization latency is 0.120–0.197 ms and registration 0.173–0.286 ms; the two smallest fleets are slower (0.184 and 0.197 ms against 0.120–0.127 ms for $n \geq 200$), probably from warm-up, which we did not isolate. Beyond $n = 200$ latency is flat as the fleet grows eightfold, consistent with constant per-request cost dominated by one Ed25519 verification. Throughput is 3,700–6,200 decisions/s. Repeating $n = 400$ thirty times gives a mean authorization latency of 0.133 ± 0.013 ms (95% CI 0.128–0.138) and registration 0.184 ± 0.019 ms; over 20,000 sequential decisions the percentiles are p50 0.124, p95 0.188, p99 0.247 and p99.9 0.932 ms, with a 4.3 ms maximum attributable to scheduling or garbage collection. Intervals assume roughly normal run means and apply to this host.

7.3 On-Chain Cost: Measured EVM Gas

Table 5 lists gas measured over 50 devices on the Hardhat EVM; gas is deterministic given the state path (s.d. below 10). Registration costs about 215k gas and a full audited decision about 70k, of which one `ecrecover` and one new nonce slot are the main parts. Requests denied for replay (41.5k) or against a revoked device (39.3k) are cheaper because they exit early, while denials that occur after the oracle check cost as much as an allow. The industrial additions cost nothing visible: an ALLOW on a strict resource (70.4k), an anomaly-gate denial (70.2k), a strict-borderline denial (70.4k) and a below-threshold denial (70.2k) are all within 0.3% of the base decision, since the extra checks are cheap comparisons. Anchoring a decision-log root costs 70.8k gas for the first anchor and 53.7k in steady state, which is 54 gas per decision at $B = 1000$ decisions per root, about three orders of magnitude below the 70.4k of deciding each of them on-chain.

For capacity planning, a 30M-gas block (a typical default; PoA operators choose their own) holds at most $\lfloor 30\text{M}/70{,}369 \rfloor = 426$ audited decisions or 139 registrations. This ceiling, not a measured throughput, is the reason why only T2–T3 are decided on-chain. The in-process call latency including client-side signing was about 3 ms per decision, an upper bound on pure EVM execution that says nothing about network or consensus delay.

Table 5: Measured gas per operation (Hardhat EVM, solc 0.8.24, 50 devices)

Operation	**Mean gas**	**Std.**
`registerDevice`	214,888	9.6
`suspendDevice`	32,709	4.2
`reinstateDevice`	32,901	4.2
`revokeDevice`	58,824	4.2
`evaluateAccess` (ALLOW)	70,369	8.5
`evaluateAccess` (STEP_UP)	70,413	6.4
`evaluateAccess` (DENY, bad oracle sig.)	70,141	8.1
`evaluateAccess` (DENY, replay)	41,527	8.5
`evaluateAccess` (DENY, revoked)	39,310	8.0
Deploy `IdentityRegistry`	1,327,399	–
Deploy `ZeroTrustAccess`	1,078,477	–
`definePolicy` (2 classes)	97,805	–

Table 6: Per-tier results: legitimate requests allowed and attacker requests accepted (%), threshold alone → full policy (θ min. trust, g anomaly gate)

Resource	θ	g	Legit.	Stealthy	Spoof
telemetry.read (T0)	0.50	1.00	100.0→100.0	100.0→100.0	100.0→100.0
historian.write (T1)	0.55	0.60	100.0→100.0	100.0→100.0	100.0→74.7
plc.setpoint.write (T2)	0.70	0.30	99.9→97.8	98.5→60.9	100.0→0.0
plc.firmware.update (T3)	0.78	0.20	96.0→94.8	52.2→13.6	52.4→0.0

7.4 Hybrid Enforcement: Cost of the Fast Path

We compare the contract model, which verifies one signature per decision (Track B), with the fast-path PEP, which verifies the device signature and the oracle attestation. Over 10 runs of 2,000 mixed T0/T2 requests, the contract model takes 0.134 ± 0.020 ms (95% CI 0.119–0.148) and the fast path 0.261 ± 0.022 ms (CI 0.245–0.277). The fast path is therefore about twice as expensive *in compute*, which is the expected cost of two verifications; it sustains roughly 3,800 decisions/s on one core. Its benefit is elsewhere: it needs no transaction, no gas and no block, and it keeps working when the ledger is slow. The compute comparison is thus a cost, not a gain, and the real advantage depends on the network and consensus latency that we did not measure.

7.5 Tiered Policy: Legitimate Acceptance and Attack Acceptance

Table 6 runs 4,000 legitimate requests (5% with a process upset) and 4,000 requests of each attack population through the four tiers, first with threshold alone and then with the full policy (gate and strict mode); eligibility is by device class, so the legitimate denominators shrink with the tier (4,000, 3,713, 1,145, 858). Fig. 2(a) shows the same data graphically.

Four observations follow. First, naive compromise is denied everywhere (0% accepted at all tiers), so it does not test the design. Second, at T0 an attacker that spoofs signals is accepted 100% of the time under any policy: this is by design, since T0 is read-only telemetry and we chose not to spend verification effort there, but it means T0 data can be read by a compromised device that keeps looking normal. Third, the gate and strict mode matter exactly where consequences are high: at T2 the full-spoof attacker falls from 100% to 0% accepted and the stealthy attacker from 98.5% to 60.9%; at T3 from 52.4% to 0% and from 52.2% to 13.6%. Fourth, this has a price. Legit-

imate allowance drops from 99.9% to 97.8% at T2 and from 96.0% to 94.8% at T3 (and 5.2% of legitimate T3 requests are denied outright), because upset requests exceed the gate and strict mode refuses borderline scores. A plant would decide whether those denials are acceptable for setpoint and firmware writes, where a second confirmation is usually welcome, and the next experiment shows the trade-off.

A short ablation of the trust signals, run in the base design, adds that the full score separates partial and stealthy mimicry with AUC 0.993 and 0.895 whereas dropping the behavioural signal leaves both at AUC 0.499–0.500, so the behavioural signal is the only one that separates mimicry from legitimate traffic in this setup; posture and network are drawn from the same ranges for both populations in the synthetic fleet, so removing them *raises* AUC, which argues for adaptive rather than fixed weighting and should not be read as evidence that real posture is uninformative.

7.6 Sensitivity to the Anomaly Gate

Fig. 2(b) sweeps the gate level from 0.15 to 0.60 for legitimate upset rates of 5% and 15% (0% gives no false denials by construction). Under a 5% upset rate, a gate of 0.30 blocks 40.1% of stealthy mimicry and 100% of full spoofing while denying 2.3% of legitimate requests. Tightening to 0.25 and 0.20 raises the stealthy block rate to 60.4% and 80.4% at 3.1% and 3.8% legitimate denials, and 0.15 blocks all of it at 4.6%. Loosening to 0.40 blocks no stealthy attacker and lets 25% of full spoofing through, rising to 74% at 0.60. At a 15% upset rate the same gates deny 7.4% (0.30) and 12.2% (0.20) of legitimate requests. The gate is thus a genuine trade-off whose operating point depends on how noisy legitimate behaviour is, and because the attack range $[0.15, 0.40]$ is built to overlap legitimate upsets, no gate separates them completely; an attacker who keeps its anomaly below the gate is accepted, as Proposition 7(d) predicts.

7.7 Baseline Comparison: Revocation Exposure

On a shared logical clock we compare the per-request design with a session token (HMAC bearer token, TTL 60 or 300 s) and PKI with a CRL refreshed every 60 or 300 s, for 60 devices at 1 request/s with revocation times drawn from $U(100, 500)$ s. Table 7 shows that the audited design accepts no request after revocation, as Proposition 1 predicts, whereas the baselines accept on average 33 and 147 requests for the 60 s and 300 s windows (worst cases 59–299). The mechanism implies this result; the experiment quantifies it. Token validation is the cheapest per request (an HMAC, no public-key operation) and our design costs more per accepted request, which we do not hide. The fast path trades the zero for a bounded exposure of at most $\rho\Delta$ requests (Proposition 2): for example, with $\Delta = 5$ s and one request per second the bound is 5 requests, still far below the 33–147 of token and CRL schemes.

7.8 Firmware Recall Capacity

Table 8 reports gas for revoking k devices with one transaction each and with `revokeBatch` on the EVM; `suspendBatch` is shown for quarantine. For a single device the batch call is 1.7% more expensive because of the loop and array overhead, but from ten devices on it saves 36.5–40.5%, approaching about 35k gas per device against 58.9k. Taking a 30M-gas block, recalling 10^4 devices needs about 20 blocks with individual transactions and 12 with batches, and 5×10^4 devices need 99 and 59 blocks (derived from the measured per-device gas; other traffic and block interval are not modelled, so at a 2 s block time the larger recall would take on the order of two minutes at best). Revoking the highest-criticality devices first is therefore worth doing: devices revoked in later blocks stay exposed until their block.

Table 7: Revocation exposure (requests accepted after revocation; 60 devices, 1 req/s) and mean decision latency

Scheme	Mean exp.	Max exp.	Lat. (ms)
Session token (TTL 60 s)	32.5	59	0.005
Session token (TTL 300 s)	146.5	299	0.006
PKI+CRL (refresh 60 s)	33.5	60	0.074
PKI+CRL (refresh 300 s)	146.5	299	0.094
Proposed (per-request)	0.0	0	0.070

Table 8: Gas for recalling devices: one transaction per device versus `revokeBatch`, and `suspendBatch`

Devices	One tx each	`revokeBatch`	Saving	`suspendBatch`
1	58,862	59,885	-1.7%	31,626
10	588,584	373,727	36.5%	98,895
50	2,943,016	1,768,639	39.9%	397,963
100	5,886,008	3,512,255	40.3%	771,729
200	11,772,196	6,999,571	40.5%	1,519,225

7.9 Attack Detection

Four basic attacks were run in 500 independent trials each: replay, forged signature, use after revocation and probing with unregistered DIDs. All were denied in every trial. With 500 trials and no failure the one-sided 95% upper bound on the failure probability is $3/500 = 0.6\%$ (rule of three). This validates the state-machine logic against the implemented attacks; it is not evidence of unconditional security.

7.10 Decentralized Revocation Governance

Table 9 evaluates `RevocationGovernance` for $N \in \{5, 7, 9, 11, 15, 21\}$ with 200 trials per size. Mean quorum latency on the testbed grows roughly linearly, from 0.56 ms ($N = 5$) to 1.91 ms ($N = 21$) for a cooperative group and from 0.93 to 3.67 ms under maximal tolerated dissent ($N - q$ DENY voters), with 95% CI half-widths of at most 0.10 ms. Across all 1,200 trials the dissenting minority never prevented approval, and in 1,200 forced-revocation attempts with only $q - 1$ approvals no revocation executed, consistent with Proposition 6. On the EVM a proposal costs 72k gas, each vote 78k, and the final vote that triggers revocation 102k, so a quorum revocation costs 313k ($N = 5$) to 800k gas ($N = 21$): the governance cost grows with q, not with the fleet. Kumar et al. report 3–4 s for registration and under 5 s for revocation on a live PoA chain [28]; our figures are two to three orders of magnitude lower but measure compute only and are not comparable like for like. In a deployment each vote is a transaction, so revocation takes about q block confirmations when votes are sequential, or one to two blocks if voters submit in parallel.




Figure 2: Industrial extensions: (a) attacker requests accepted per criticality tier under threshold-only and full policy; (b) anomaly-gate trade-off for 5% and 15% legitimate process-upset rates; (c) gas to recall devices with one transaction per device versus `revokeBatch`.

Table 9: Governance: mean testbed latency (ms) cooperative and under maximal dissent; % trials where maximal dissent still reached quorum (Appr.); % where a $q-1$ coalition executed a revocation (Forced); EVM gas for one quorum revocation

N	q	Coop.	Dissent	Appr.%	Forced%	Total gas
5	3	0.562	0.926	100	0	313,402
7	4	0.667	1.166	100	0	374,232
9	5	0.803	1.440	100	0	435,062
11	6	0.946	1.729	100	0	495,892
15	8	1.299	2.438	100	0	617,552
21	11	1.909	3.665	100	0	800,042

Table 10: Outage scenario (policy-defined, 400 devices, 1 req/s): availability of legitimate requests and unsafe accepts

Outage (s)	Revoked devices	Avail. (%) closed	Avail. (%) degr.	Unsafe accepts	T2–T3 denied
10	43	98.3	99.9	155	100%
30	40	94.9	99.7	456	100%
60	36	89.9	99.4	962	100%
120	44	79.7	99.0	2,149	100%
300	30	50.4	97.0	4,398	100%

7.11 Degraded Operation During an Outage

Table 10 applies the policy of Section 4.8 to a scenario with 400 devices, one request per second each, a quarter of the devices acting as T2 clients that issue a T2 request every fourth second, and 10% of the devices revoked at random times during an outage that starts at $t = 200$ s of 600 s. A fully fail-closed PEP stops serving everyone for the whole outage, so availability falls to 89.9% for a 60 s outage and 50.4% for 300 s. The degraded policy keeps T0–T1 running (99.4% and 97.0%) but denies every T2 request during the outage and accepts requests from devices revoked while it was blind (962 requests for 60 s, 4,398 for 300 s). This scenario follows directly from the stated policy and is deterministic given its parameters, so it is an illustration of the trade-off, not an empirical result; its use is to show that the operator chooses between unsafe acceptances and lost availability, and that the choice is explicit.

8 Discussion

8.1 What the Design Buys and What It Costs

Compared with tokens and CRLs, the central gain is the removal of an implicit-trust window: on the audited path a revoked device loses access at the next call, and on the fast path within the replica lag, a bound the operator can set and measure (Propositions 1 and 2; 33–147 accepted requests for the baselines against none or $\rho\Delta$). Quorum governance removes the single-registrar insider (T7) at a gas cost that scales with the voter group rather than the fleet. The tiered policy concentrates verification effort where a wrong decision hurts: at T2–T3 the gate and strict mode cut a spoofing attacker's acceptance from about 100% to 0% and from about half to zero, and the cost is a few percent of legitimate requests denied when the process is upset. In contrast to schemes that authenticate once and trust the session [20], nothing here is trusted by default; in contrast to conceptual smart-factory designs [18], the policy is an executable contract with measured cost.

The costs are equally concrete. The fast path doubles per-request compute (two signature checks), the audited path is bounded by block gas (about 426 decisions per 30M-gas block), recall of very large fleets takes tens of blocks, and the whole design adds a consortium chain, a replica and an oracle to operate. For a plant that has one owner and a good internal PKI, this is probably unjustified; the argument for it is multi-party plants in which revocation authority and audit trails must be shared.

8.2 Deployment Guidance

Tier assignment. Tiers should follow consequence, not protocol: any action whose misuse could damage equipment or product, or alter safety-relevant logic, belongs on the audited, strict path; high-rate reads belong on the fast path. *Gate calibration.* The anomaly gate should be set from a plant's own distribution of legitimate deviations, including start-up and batch changes; Section 7.6 shows the operating point moves substantially with the upset rate. *Replica lag.* Δ should be measured, monitored and alarmed, since Proposition 2 is only as good as A5. *Recall rehearsal.* Batch revocation should be rehearsed with quarantine (`suspendBatch`) first, because REVOKED

is terminal and a mistaken revocation requires re-enrolment with a new key. *Gas economics.* On a private PoA network gas can be zero-priced, so the figures above indicate capacity and relative cost rather than money; gasless relaying can hide fees from constrained devices [38].

8.3 Threats to Validity

Internal validity. Devices, signal ranges and attacks are synthetic and chosen by us, and the legitimate and attacking anomaly ranges overlap by construction. The gate and tier results therefore show how the policy behaves under that overlap; they are not detection rates for a real plant. The baselines are minimal re-implementations: a production PKI with OCSP stapling or short-lived certificates would behave differently. The outage result is policy-defined. *External validity.* Everything ran on one two-vCPU container with the two tracks using different signature schemes; no measurement was made on a microcontroller, on a live multi-node chain or on industrial protocols. *Construct validity.* Revocation exposure is counted on a logical clock and ignores propagation and finality time. *Conclusion validity.* Intervals come from 10–30 runs on one host; the 500-trial attack tests have a 0.6% rule-of-three bound.

8.4 Limitations and Future Work

First, a multi-node PoA deployment (for example Hyperledger Besu) should be used to measure end-to-end latency, finality and Δ in practice. Second, the PEP is trusted for request-signature checking in Track A, and a single oracle and registrar remain single points of compromise (A4); a threshold-signed oracle [32] and a quorum registrar set would remove them. Third, our legacy-device proxy is a design with a modelled class, not an implemented gateway, and no real fieldbus or OPC-style protocol was exercised. Fourth, trust scores and anomaly values appear in transaction data and are visible to consortium members; differential-privacy protection of exposed scores [39] is not implemented. Fifth, adversarial-AI mimicry is richer than our populations [29], and the signal producers (attestation, process-aware anomaly detection, possibly cross-site learning [30]) are inputs we assume. Sixth, multi-PEP zones require binding the PEP identity into requests (Proposition 3). Seventh, the policy parameters were hand-tuned, and learning them from plant data [15] is open. Finally, the contracts are research code that has been unit-tested but not audited, and the literature on smart-contract quality assurance [33] should be followed before any production use.

9 Conclusion

This paper proposed a blockchain-enabled Zero Trust architecture for identity management in Industrial IoT, built around the observation that a plant needs multi-party revocation authority, verification proportional to consequence, and an enforcement path that does not wait for consensus. Three smart contracts anchor identity, tiered policy and quorum-governed revocation; a fast path decides locally against replicated state and anchors Merkle roots of its decisions, while resources whose misuse is costly are decided on-chain with an anomaly gate and a strict mode; and batch revocation supports firmware recalls. We proved immediate revocation on the audited path, a $\rho\Delta$ exposure bound on the fast path, replay resistance, attestation unforgeability, key-reuse prevention and governance safety and liveness, and showed exactly when a spoofing attacker is accepted.

On a synthetic industrial fleet, the audited design accepted no request after revocation where token and CRL baselines accepted 33–147 on average; the gate and strict mode reduced full-spoof acceptance at the two most critical tiers to 0% and stealthy-mimicry acceptance to 60.9% and 13.6%, at a cost of 2.2–5.2% denied legitimate requests; batch revocation saved about 40% of gas, with about 35k gas per device; anchoring cost 54 gas per decision at 1,000 decisions per root; and quorum revocation for 5–21 voters cost 313k–800k gas, with no coalition below quorum succeeding in 1,200 attempts. These numbers are compute-bound and synthetic, and an attacker that keeps its behaviour within normal variation remains accepted at every tier. Whether the approach holds up in a real plant is a question for deployment on a multi-node chain with real protocols, devices and telemetry, which we regard as the next step together with threshold-signed oracles and privacy protection for exposed scores. Code, data and generation scripts are released with the paper.

References

[1] K. Stouffer *et al.*, "Guide to Operational Technology (OT) Security," NIST Special Publication 800-82 Rev. 3, National Institute of Standards and Technology, Sep. 2023. [Online]

[2] S. Rose, O. Borchert, S. Mitchell, and S. Connelly, "Zero Trust Architecture," NIST Special Publication 800-207, National Institute of Standards and Technology, 2020. [Online]

[3] E. B. Fernandez and A. Brazhuk, "A critical analysis of zero trust architecture (ZTA)," *Computer Standards & Interfaces*, vol. 89, Art. no. 103832, 2024. [Online]

[4] P. Phiayura and S. Teerakanok, "A comprehensive framework for migrating to zero trust architecture," *IEEE Access*, vol. 11, pp. 19487–19511, 2023. [Online]

[5] M. W. Song, T. Nguyen, and C. Irvine, "A zero trust architecture for critical operational technology systems," in *Proc. 58th Hawaii Int. Conf. Syst. Sci. (HICSS)*, 2025. [Online]

[6] C. Zanasi, S. Russo, and M. Colajanni, "Flexible zero trust architecture for the cybersecurity of industrial IoT infrastructures," *Ad Hoc Networks*, vol. 156, Art. no. 103414, 2024. [Online]

[7] M. Sporny *et al.*, "Decentralized Identifiers (DIDs) v1.0," W3C Recommendation, Jul. 2022. [Online]

[8] S. M. Hosseini, J. Ferreira, and P. C. Bartolomeu, "Blockchain-based decentralized identification in IoT: an overview of existing frameworks and their limitations," *Electronics*, vol. 12, no. 6, p. 1283, 2023. [Online]

[9] A. D. Aguru and S. B. Erukala, "A blockchain-based self-sovereign identity management framework for Internet of Things," in *Recent Trends in Intelligent Systems and Next Generation Wireless Communication (IIWCS 2024)*, Lecture Notes in Networks and Systems, vol. 1329. Singapore: Springer, 2025, pp. 299–309. [Online]

[10] G. Folino, A. Forestiero, and G. Papuzzo, "Self-sovereign identification of IoT devices by using physically unclonable functions and blockchain," in *Numerical Computations: Theory and Algorithms (NUMTA 2023)*, Lecture Notes in Computer Science, vol. 14478. Cham: Springer, 2025. [Online]

[11] Z. Zhai *et al.*, "A lightweight authentication method for Industrial Internet of Things based on blockchain and Chebyshev chaotic maps," *Future Internet*, vol. 17, no. 8, Art. no. 338, 2025. [Online]

[12] M. Essaid and H. Ju, "Blockchain solutions for enhancing security and privacy in Industrial IoT," *Applied Sciences*, vol. 15, no. 12, Art. no. 6835, 2025. [Online]

[13] C. Liu, R. Tan, Y. Wu, Y. Feng, Z. Jin, F. Zhang, Y. Liu, and Q. Liu, "Dissecting zero trust: research landscape and its implementation in IoT," *Cybersecurity*, vol. 7, no. 1, Art. no. 20, 2024. [Online]

[14] S. Nie, J. Ren, R. Wu, P. Han, Z. Han, and W. Wan, "Zero-trust access control mechanism based on blockchain and inner-product encryption in the Internet of Things in a 6G environment," *Sensors*, vol. 25, no. 2, p. 550, 2025. [Online]

[15] M. M. Salim, M. Kim, S. K. Singh, and J. H. Park, "Zero-trust blockchain-enabled framework for scalable and secure IoT networks (ZT-BlocIoT)," *Future Generation Computer Systems*, vol. 175, Art. no. 108093, 2026. [Online]

[16] R. Mukta, S. Pal, K. Chowdhury, M. Hitchens, H. Paik, and S. S. Kanhere, "Zero trust-driven access control delegation using blockchain," *Blockchain: Research and Applications*, vol. 7, no. 1, Art. no. 100319, 2026. [Online]

[17] E. Jamwal, P. Srivastava, and P. S. Chakraborty, "Blockchain-enabled zero-trust framework for secure cloud data sharing: survey," in *Proc. 2026 Int. Conf. Intell. Syst. Eng., Secured Syst. Cybersecurity (ICISESSC)*, 2026. [Online]

[18] M. Farhan *et al.*, "ZTF-SF: a zero-trust blockchain-enabled IIoT framework for secure smart factories," in *Proc. 2026 2nd Int. Conf. Comput. Intell. Approaches Appl. (ICCIAA)*, 2026. [Online]

[19] K. Potturi, B. Gautam, C. S. Pareek, A. Gupta, S. C. Chava, and B. S. Katta, "A hybrid AI and blockchain-enabled zero-trust security framework for cloud, edge, and IoT systems," in *Proc. 2026 Int. Conf. Comput. Theory Wireless Commun. (ICCTWC)*, 2026. [Online]

[20] Z. Wang, Y. Guo, and Y. Guo, "Blockchain-based zero-trust continuous authentication scheme for medical IoT," *Journal of Parallel and Distributed Computing*, vol. 217, Art. no. 105333, 2026. [Online]

[21] M. James, T. Newe, D. O'Shea, and G. D. O'Mahony, "Authentication and authorization in zero trust IoT: A survey," in *Proc. Irish Signals and Systems Conf. (ISSC)*, 2024. [Online]

[22] R. Kumar and R. Sharma, "A comprehensive approach to industry 4.0 security: blockchain and dynamic access control integration," in *Proc. 2024 6th Int. Conf. Computational Intelligence and Communication Technologies (CCICT)*, 2024, pp. 477–484. [Online]

[23] M. A. Azad, S. Abdullah, J. Arshad, H. Lallie, and Y. H. Ahmed, "Verify and trust: a multidimensional survey of zero-trust security in the age of IoT," *Internet of Things*, vol. 27, Art. no. 101227, 2024. [Online]

[24] N. Nahar, K. Andersson, O. Schelén, and S. Saguna, "A survey on zero trust architecture: applications and challenges of 6G networks," *IEEE Access*, vol. 12, pp. 94753–94764, 2024. [Online]

[25] J. Ren, J. Zhang, Y. Ren, and J. Xu, "Blockchain-based self-sovereign identity management mechanism in AIoT environments," *Electronics*, vol. 14, no. 19, p. 3954, 2025. [Online]

[26] A. Philipp and A. Küpper, "DAXiot: A decentralized authentication and authorization scheme for dynamic IoT networks," arXiv:2307.06919, 2023. [Online]

[27] C. Mazzocca, A. Acar, S. Uluagac, and R. Montanari, "EVOKE: Efficient revocation of verifiable credentials in IoT networks," in *Proc. 33rd USENIX Security Symp.*, Philadelphia, PA, USA, Aug. 2024, pp. 1279–1295. [Online]

[28] A. Kumar, B. Sharma, R. K. Kaushal, and I. Ben Dhaou, "Privacy-preserving identity management system leveraging blockchain technology," in *Proc. 15th IEEE Int. Conf. Commun. Syst. Netw. Technol. (CSNT)*, 2026, p. 625 ff. [Online]

[29] M. Usama, A. Aziz, N. Alasbali, N. Alturki, M. Hanif, and M. Ur Rehman, "Blockchain-enabled identity management for IoT: a multi-layered defense against adversarial AI," *Scientific Reports*, vol. 16, Art. no. 4371, 2026. [Online]

[30] A. K. Tom, A. Khraisat, T. Jan, M. Whaiduzzaman, T. D. Nguyen, and A. Alazab, "Survey of federated learning for cyber threat intelligence in Industrial IoT: Techniques, applications and deployment models," *Future Internet*, vol. 17, no. 9, Art. no. 409, 2025. [Online]

[31] W. Shujaa, M. Alanzi, and S. Sankaranarayanan, "Enhancing IoT security through blockchain integration," *Frontiers in Computer Science*, vol. 7, Art. no. 1670473, 2025. [Online]

[32] A. Hassan, I. Makhdoom, W. Iqbal, A. Ahmad, and A. Raza, "From trust to truth: Advancements in mitigating the blockchain oracle problem," *J. Netw. Comput. Appl.*, vol. 217, Art. no. 103672, 2023. [Online]

[33] Z. Wei *et al.*, "Survey on quality assurance of smart contracts," *ACM Comput. Surv.*, vol. 57, no. 2, Art. no. 32, 2024. [Online]

[34] M. T. Ta and T. Q. Do, "A study on gas cost of Ethereum smart contracts and performance of blockchain on simulation tool," *Peer-to-Peer Networking and Applications*, vol. 17, no. 1, pp. 200–212, 2024. [Online]

[35] M. R. Hasan, A. Alazab, S. B. Joy, M. N. Uddin, M. A. Uddin, A. Khraisat, I. Gondal, W. F. Urmi, and M. A. Talukder, "Smart contract-based access control framework for Internet of Things devices," *Computers*, vol. 12, no. 11, Art. no. 240, 2023. [Online]

[36] E. U. Haque, A. Shah, J. Iqbal, S. S. Ullah, R. Alroobaea, and S. Hussain, "A scalable blockchain based framework for efficient IoT data management using lightweight consensus," *Scientific Reports*, vol. 14, Art. no. 7841, 2024. [Online]

[37] A. K. Peepliwal, H. M. Pandey, S. Prakash, A. A. Mahajan, S. S. Chowhan, V. Kumar, and R. Sharma, "A prototype model of zero trust architecture blockchain with EigenTrust-based practical Byzantine fault tolerance protocol to manage decentralized clinical trials," *Digital Communications and Networks*, 2024. [Online]

[38] Y. Madhwal *et al.*, "Empowering autonomous IoT devices in blockchain through gasless transactions," *Blockchain: Research and Applications*, vol. 6, no. 2, Art. no. 100257, 2025. [Online]

[39] L. Ren, H. Li, Y. Liu, D. Liao, M. Zhang, and H. Jin, "Identity trust management based on differential privacy for internet of vehicles," *Scientific Reports*, vol. 16, Art. no. 20921, 2026. [Online]