Water Quality
AQUATEC
ENGINEERING
THE WATER SPECIALIST
PT. AQUATEK ENGINEERING

+ 62 811 3037 533
aquatek.bryan@gmail.com
Ruko Bandar Mas Blok E No. 10

Chemical Compatibility and Impact Analysis of HYTREAT 5300 and Sulfuric Acid

Potential Reactions

1. Acid-Induced Collapse of Multicomponent Inhibitor System

HYTREAT 5300 is formulated as a balanced corrosion and scale control system comprising phosphonates, polymers, zinc salts, and azole inhibitors, all of which are designed to function within a controlled pH window. The introduction of concentrated sulphuric acid forces the system far outside this operational range, causing simultaneous protonation of phosphonates, destabilization of polymer chains, and disruption of zinc coordination chemistry. This abrupt pH shock collapses the multi-component inhibition strategy, leaving the formulation chemically present but functionally inactive.

2. Rapid Precipitation and Solid Phase Generation

Under highly acidic conditions created by sulphuric acid, several components of HYTREAT 5300 lose solubility. Phosphonate species, zinc salts, and polymer-associated complexes may undergo rapid precipitation, forming dense inorganic–organic solids. This solid phase formation converts the liquid formulation into a heterogeneous suspension or sludge, which poses a severe risk of clogging injection lines, fouling storage tanks, and permanently damaging metering equipment.

3. Intensified Corrosive Environment and Metal Attack

Sulphuric acid classified as H290 (corrosive to metals) dramatically increases the corrosivity of the mixed solution. The protective films normally formed by phosphonates, zinc, and azole inhibitors are either chemically destroyed or prevented from forming under extreme acidity. As a result, metallic surfaces are exposed to direct acid attack, accelerating uniform corrosion and increasing susceptibility to localized pitting, especially on carbon steel, copper alloys, and mixed-metal systems.

4. Escalation of Safety and Environmental Hazards

The mixture exhibits a hazard profile significantly more severe than either substance alone. The combination of strong mineral acid, dissolved metals, and destabilized organic inhibitors increases the risk of chemical burns, acid mist inhalation, and environmental contamination. In the event of a spill or discharge, the low pH and elevated metal content can overwhelm wastewater treatment systems and cause acute toxicity to aquatic organisms, creating regulatory and environmental liabilities.

Mandatory Control Measures

1. Immediate Isolation and Process Shutdown

+ 62 811 3037 533
aquatek.bryan@gmail.com
Ruko Bandar Mas Blok E No. 10

If accidental mixing occurs, the affected tank or dosing system must be immediately isolated from the main process. All feed pumps and automated dosing controls shall be shut down to prevent propagation of the acidic mixture into downstream piping, heat exchangers, or cooling circuits.

2. Restricted Access and Use of Acid-Resistant PPE

Access to the affected area must be limited to trained personnel equipped with appropriate acid-resistant personal protective equipment. This includes chemical-resistant suits, gloves, face protection, and respiratory protection as required. The risk of acid splashes and corrosive vapors necessitates strict adherence to high-level PPE standards.

3. Controlled Neutralization Under Thermal Monitoring

Stabilization of the mixture shall be performed through controlled neutralization using suitable alkaline agents. Neutralization must proceed gradually, with continuous monitoring of temperature and pH to prevent excessive heat release or secondary precipitation events. Direct dilution with water is not recommended due to the risk of violent exothermic reactions.

4. Removal and Management of Precipitated Solids

Any solids formed as a result of acidification must be mechanically removed using filtration, settling, or vacuum extraction methods. These solids shall be treated as hazardous waste due to their acidic nature and metal content and must not be reintroduced into the system or disposed of through conventional drainage.

5. Post-Incident Inspection and Preventive System Redesign

Following cleanup, a detailed inspection of all affected equipment shall be conducted to assess corrosion damage, seal degradation, and potential blockages. Damaged components must be replaced, and procedural safeguards—such as physical separation of acid handling systems and inhibitor storage should be implemented to prevent recurrence.