



Our Ref: APPBCA-2022-22

Date: 01 December 2022

For enquiries, please contact:  
Building Plan Management Group (#10-01)  
Tel : 1800 3425 222 (1800DIALBCA)  
or use our Online Feedback Form at:  
<https://www.bca.gov.sg/feedbackform/>

See **Distribution List**

Dear Sir / Madam

## **JOINT BCA/ACES/IES CIRCULAR 2022**

### **GUIDELINES ON CFD SIMULATION AND REPORT FOR ADOPTION OF JET FANS AS ALTERNATIVE SOLUTION IN-LIEU OF DUCTWORK FOR MECHANICAL VENTILATION IN CARPARKS**

#### **Objective**

This circular is to inform the industry of a set of guidelines on Computational Fluid Dynamics (CFD) simulation and the report to be submitted to the Commissioner of Building Control (CBC) for approval for the adoption of jet fans as an Alternative Solution in-lieu of ductwork for mechanical ventilation (MV) in carparks.

#### **Background**

2. Jet fans are commonly used in carparks for MV systems of vehicular exhaust. Currently, projects using jet fans in the MV system design will require the submission of Alternative Solution to the CBC for the adoption of jet fans as an alternative to conventional ductwork of MV systems for carpark as specified in Singapore Standard SS553: Code of Practice for Air-conditioning and Mechanical Ventilation in Buildings. To establish the effectiveness of the jet fans in dissipating the vehicular exhaust, an appointed Professional Engineer in the branch of Mechanical Engineering (PE(Mech)) will conduct CFD simulations for the project. The results obtained from the CFD simulations would be used

to justify the PE(Mech)'s assessment on the sufficiency of the jet fan design in the application for approval of Alternative Solution (AS) from the CBC in-lieu of MV ductwork in the carpark.

3. Today, there is differing industry practice in carrying out CFD simulation (e.g. values to be adopted for critical parameters). BCA has thus collaborated with Association of Consulting Engineers Singapore (ACES) and Institution of Engineers Singapore (IES) and in consultation with CFD and jet fans specialists, a set of guidelines to standardise the key aspects of the CFD simulation and necessary content was developed.

### **Guidelines**

4. The guidelines on the CFD simulation and CFD report for the adoption of jet fans as an AS in-lieu of ductwork for MV in carparks are detailed in [Annex A](#). Notwithstanding, as design and expected operations of a development vary, the PE(Mech), being a specialist in the alternative solution, should assess the suitability of the adoption of the guidelines for the CFD simulation to guide their design of the jet fan system for the development. The PE(Mech) should provide details of the design and expected operating conditions of the development and indicate any scenarios which may require more stringent assumptions in the CFD simulations in the report. Should there be any deviation from the recommended parameters in the guidelines, it should be supported with sufficient justification.

5. In addition, PEs(Mech) are reminded of their duty under section 9(3) of the Building Control Act 1989 to take all reasonable steps and exercise due diligence to ensure that the alternative solution satisfies the objectives and performance requirements that are prescribed in the building regulations in respect of ventilation, before issuing the certification of supervision for the jet fans system.

### **Effective Date**

6. It is recommended that the guidelines in Annex A be adopted with immediate effect in respect of the CFD simulation and the report submitted to the CBC on the adoption of jet fans as an AS in-lieu of ductwork for MV in carparks.

### **For clarification**

7. We would appreciate it if you could convey the contents of this Circular to the relevant members of your respective organisations. If you or your members have any queries concerning this Circular, please submit your enquiry through BCA's Online Feedback Form at <https://www.bca.gov.sg/feedbackform/>.

Thank you.



---

AR. ONG YU ZI JANE  
DIRECTOR  
BUILDING PLAN & MANAGEMENT GROUP  
BUILDING AND CONSTRUCTION AUTHORITY  
For COMMISSIONER OF BUILDING CONTROL



---

ER. CHUCK KHO  
PRESIDENT  
ASSOCIATION OF CONSULTING ENGINEERS  
SINGAPORE (ACES)



---

MR. DALSON CHUNG  
PRESIDENT  
THE INSTITUTION OF ENGINEERS  
SINGAPORE (IES)



## ANNEX A

### Guidelines for CFD Simulation and Report

Part 1: CFD Simulation		Part 2: Report
Criteria	Guideline	
<b>Software</b>	Follow BCA's GM Guideline on CFD Simulation under Green Mark 2021	<ol style="list-style-type: none"> <li>For each of the criteria, the report shall clearly state the provision and assumption. For example, <ol style="list-style-type: none"> <li>Write up of the software and simulation methodology indicating provision and compliance with each of the guideline</li> <li>Building plans showing location and size of natural ventilation openings</li> <li>Information of MV and jet fans system including air-change rate (ACH), flowrate, model, quantity and plans showing location of system. The PE for ACMV shall confirm that MV system (fresh air and exhaust fans) is provided as per SS553.</li> <li>Calculation of exhaust emission from vehicles and any references made in the calculation</li> </ol> </li> <li>The report shall clearly demonstrate and explain how the CFD results demonstrates the below. Where applicable to demonstrate the below, there shall be CFD results at different timeframes (e.g. every 400s) furnished in the report. <ol style="list-style-type: none"> <li>steady state condition achieved</li> <li>performance of the system in meeting the acceptance criteria</li> </ol> </li> <li>Where there is deviation from the suggested default conditions, for example if the QP/Specialist assessed that occupancy of lower values may be adopted, supporting information and data for such development shall be provided in the report.</li> <li>Similarly, should there be a need to adopt higher values due to different operating conditions, the assumed value shall be stated.</li> </ol>
<b>Simulation Methodology and Boundary Conditions</b>	<ul style="list-style-type: none"> <li>RANS or LES is acceptable (minimally k-e turbulence model for RANS)</li> <li>Standard wall function</li> <li>Ambient CO concentration level = 0ppm</li> <li>No wind</li> <li>MV system in continuous operation</li> </ul>	
<b>Discretization Schemes and Convergence Criteria</b>	Follow BCA's GM Guideline on CFD Simulation on Discretization Schemes and Convergence Criteria	
<b>Grid size and mesh</b>	Follow BCA's GM Guideline on CFD Simulation on Grid size and Mesh	
<b>Building Model and MV system</b>	<p>Accurate model of:</p> <ol style="list-style-type: none"> <li>building layout and openings In line with SCDF, any down-stand beams and other obstructions that are of depths of more than 1/10 of the car park floor to ceiling height shall be considered.</li> <li>MV system in continuous operation</li> <li>Maximum expected number of vehicles parked in the carpark</li> </ol>	

<b>Cars in operation and exhaust rate</b>	<p>As a default, assume 25% of vehicles (evenly distributed) are cruising at 10km/hr in the carpark, continuously emitting exhaust as below. Should there be areas where built-up of cars may be expected, CFD simulation shall be based on the expected operating scenario.</p> <p><u>Exhaust Emission of Carbon Monoxide (CO)</u></p> <ul style="list-style-type: none"> <li>• Petrol-driven vehicles – <b>Euro VI</b> (1.0g/km)</li> <li>• Diesel-driven vehicles – <b>Euro IV</b> (3.5 tonnes or below: 0.74g/km, greater than 3.5 tonnes: 1.5g/kWh)</li> <li>• Motorcycles – <b>Euro III</b> (2.0g/km)</li> </ul> <p>Note:</p> <ul style="list-style-type: none"> <li>• For the modelling of the exhaust from the vehicles, detailed modelling of the exhaust pipe is not required. Emission from a grid is acceptable.</li> <li>• For ease of assumption, unless the use of the carpark is distinctly different, you may assume vehicles in carpark of office/commercial buildings/shopping centers are petrol-driven vehicles such as passenger cars.</li> </ul>	
<b>Acceptance criteria</b>	<p>No hotspot of CO more than 25ppm should be observed on the CFD result at height of 0.5m and 1.7m at steady state</p>	

**DISTRIBUTION (via e-mail):**

President  
Singapore Institute of Architects (SIA)  
79 Neil Road  
Singapore 088904

President  
Association of Consulting Engineers, Singapore (ACES)  
18 Sin Ming Lane  
#06-01 Midview City  
Singapore 573960

President  
Institution of Engineers, Singapore (IES)  
70 Bukit Tinggi Road  
Singapore 289758

President  
Real Estate Developers Association of Singapore (REDAS)  
190 Clemenceau Avenue  
#07-01 Singapore Shopping Centre  
Singapore 239924

President  
Singapore Contractors Association Limited (SCAL)  
1 Bukit Merah Lane 2  
Construction House  
Singapore 159760

President  
Singapore Green Building Council (SGBC)  
200 Braddell Road  
Block H, Level 2 BCA Braddell Campus  
Singapore 579700

President  
Singapore Institute of Building Limited (SIBL)  
9 Ah Hood Road  
#02-04  
Singapore 329975

President  
Singapore Institute of Surveyors & Valuers (SISV)  
110 Middle Road  
#09-00, Chiat Hong Building  
Singapore 188968

President  
Association of Property & Facility Managers (APFM)  
110 Middle Road  
#09-00, Chiat Hong Building  
Singapore 188968

President  
International Facility Management Association, Singapore Chapter (IFMA)  
Killiney Road Post Office  
P.O. Box 2104  
Singapore 912352  
President  
Society of Project Managers (SPM)  
Macpherson Road P.O. Box 1083  
Singapore 913412

Registrar  
Board of Architects (BOA)  
5 Maxwell Road 1st Storey  
Tower Block, MND Complex  
Singapore 069110

Registrar  
Professional Engineers Board, Singapore (PEB)  
52 Jurong Gateway Road #07-03  
Singapore 608550

Director  
Building and Infrastructure  
Defence Science & Technology Agency (DSTA)  
1 Depot Road  
Defence Technology Tower A  
Singapore 109679

Deputy Chief Executive Officer  
Building  
Housing & Development Board (HDB)  
480 Lorong 6 Toa Payoh  
HDB Hub  
Singapore 310480

Deputy Chief Executive  
Infrastructure & Development  
Land Transport Authority (LTA)  
1 Hampshire Road  
Block 8 Level 1  
Singapore 219428

Director  
Land Planning Division  
JTC Corporation (JTC)  
8 Jurong Town Hall Road  
The JTC Summit  
Singapore 609434

Director of Infrastructure  
School Campus Department  
Ministry of Education (MOE)  
1 North Buona Vista Drive  
Office Tower Level 9  
Singapore 138675

Chief  
Healthcare Infrastructure Project  
MOH Holdings Pte Ltd (MOHH)  
1 Maritime Square  
#11-25, Harbourfront Centre  
Singapore 099253

Chief Engineer  
Development Control Department  
National Environment Agency (NEA)  
40 Scotts Road  
Environment Building  
Singapore 228231

Group Director  
Policy & Planning Division  
National Parks Board (NPARKS)  
Singapore Botanic Gardens  
1 Cluny Road  
Singapore 259569



Senior Director (Building & Estates Management)  
People's Association (PA)  
9 King George's Avenue  
Singapore 208581

Deputy Director  
Centralised Service Department, Building Plan  
Public Utilities Board (PUB)  
40 Scotts Road  
Environment Building  
Singapore 228231

Senior Director  
Fire Safety Department  
Singapore Civil Defence Force (SCDF)  
HQ Singapore Civil Defence Force  
91 Ubi Avenue 4  
Singapore 408827

Deputy Chief Executive Officer  
Sentosa Development Corporation (SDC)  
33 Allanbrooke Road, Sentosa  
Singapore 099981

Chief  
Sport Infrastructure Group  
Sport Singapore (SportSG)  
3 Stadium Drive  
Singapore 397630

Assistant Chief Executive  
Policy & Planning Group  
Singapore Tourism Board (STB)  
1 Orchard Spring Lane  
Tourism Court  
Singapore 247729

Chief Executive Officer  
Urban Redevelopment Authority (URA)  
45 Maxwell Road  
The URA Centre  
Singapore 069118

**All CORENET e-Info subscribers**