

SEGO INDUSTRIAL WATER - FIELD SERVICE RECORD

SITE: UINTA INJECTION MOLDING, OREM

DATE: 6/11/26 TECH: D HARDY

MOLD TEMP LOOP (SYS-0030): PH 9.1 NITRITE 1000 COND 2675 ALL NORMAL

TOWER (SYS-0031): COND 1720 PH 8.7 HARD 25 GR INHIB 11 OK

DOSED PER SHEET. POT FEEDER VALVE STICKY, FREED IT.

SAME DAY TIMP BEV PM STOP. SEE SEPARATE SHEET.

NO FOLLOW UP NEEDED.