

Narrative Report Template

Formatted: Centered

Activity: Fire Extinguisher Awareness Interview

Submitted by: KURT JEFFERSON LANDOY & KOBE MARTIN

Submitted to: NESE JOYCE DAPUSIN

Date: 01/24/2026

1. Introduction

- Name: UNI-OIL ESTABLISHMENT
- Purpose of Activity:

The Fire Extinguisher Awareness Interview at the gasoline station focuses on proper extinguisher use and emergency response in a high-risk environment involving flammable fuels.

2. Interview Questions and Answers

Question:

Answer:

1. Do you have a fire extinguisher on the premises?

“Yes, fire extinguishers are available on the premises and are accessible for emergency use.”

2. Where is it located?

“The fire extinguishers are located at each of the three pumping stations and in the service car area to ensure immediate access during emergencies.”

3. Are the staff trained to use it?

“Yes, the staff have been trained by the Bureau of Fire Protection (BFP) on proper fire extinguisher use and fire safety procedures.”

4. When was it last inspected or serviced?

“The fire extinguishers were last inspected in November 2025 and are serviced annually, including the replacement of the chemical contents. Each unit also has an inspection tag to document and verify regular maintenance.”

5. Are P.A.S.S. procedures (Pull, Aim, Squeeze, Sweep) known to staff?

“Yes, P.A.S.S. procedures are posted on each fire extinguisher.”

3. Observations

The gasoline station demonstrates good fire safety awareness, as fire extinguishers are strategically located at pumping stations and the service car area, regularly inspected, and supported by visible P.A.S.S. procedure guides. Staff training by the Bureau of Fire Protection further enhances preparedness in this high-risk environment involving flammable fuels.

4. Reflection

• Fire Safety Awareness in the Establishment:

The Fire Extinguisher Awareness Interview showed that the gasoline station has well-placed fire extinguishers, inspection tags, and P.A.S.S. guides, with staff trained by the Bureau of Fire Protection. This demonstrates good safety practices in a high-risk environment involving flammable fuels.

• Suggested Improvements (if any):

The station should conduct refresher training for all staff on proper fire extinguisher use and fire safety measures. This will reinforce knowledge, improve emergency response, and ensure continued safety in both the pumping stations and car service area. Regular checks of inspection tags and equipment should also be maintained to uphold safety standards.

5. Pictures

