

# ENVIRO CONTROL ASSOCIATES (I) PVT. LTD.



**PROJECT : BANGALORE WATER SUPPLY AND SEWERAGE  
SEWAGE TREATMENT PLANTS AT HEBBAL**

**CLIENT : BANGALORE WATER SUPPLY AND SEWERAGE BOARD**

**CONSULTANT: NJS ENGINEERS INDIA PVT. LTD.**



**DOCUMENT TITLE: Datasheet & G.A. Detail of Manual Screen for TSPS**

**ECAIPL DOC No.: ECAIPL/BWSSB/STP/HEB/M/01**

**Rev No.: 0**

## NJSEI / BWSSB DRAWING / DOCUMENT REVIEW STATUS

Date of Receipt.....

- A. Approved, manufacture/construction may commence.
- B. Acceptable subject to changes indicated. Resubmit for approval but manufacture/ construction may commence.
- C. Amend as comments indicated and resubmit for approval.
- D. comments noted in latter/memo attached to forwarding transmittal Nr.....dated.....  
Amend as comments indicated and resubmit for approval.
- E. Amend as comments indicated and resubmit for record.
- F. Comments noted in latter/memo attached to forwarding transmittal Nr.....dated.....  
Amend as comments indicated and resubmit for Approval.
- G. Drawing of this category is for information and hence not required to be approved.
- H. Return without review.

Approval of drawing/documents dose not absolve Contractor/vendor from any responsibilities for their accuracy or for the design, performance and safety of the plant/work or any other obligations under the contract and Indian Statutory Laws nor dose it limit the employer's rights under the Contract.

For NJSEI Verified by ..... Date .....

For BWSSB Checked by ..... Date .....

Reviewed by ..... Date .....


Approved by Chief Engineer (WWM) ..... Date .....

0	08-02-18	FOR APPROVAL	H.A.P.	T.H.M.	A.N.V.
Rev No	Date	Description	Prepared	Checked	Approved

## DOCUMENT INDEX

SR. NO.	DESCRIPTION	ECAIPL Doc. No.	Vendor Doc. No.	Rev. No.	Sheet
1	Technical Data Sheet			0	1
2	Hydraulic Calculation for loss through Screen			0	1
3	GA Drawing of Screen		GA-B-MK2-2267004-00	0	1
4	QAP for Screen			0	1

# TECHNICAL DATASHEET

		<b>TECHNICAL DATA SHEET</b> <b>Manual Screen</b>	R-19
<b>Customer</b>	M/s Enviro Control Associates (I) Pvt. Ltd.		
<b>Project</b>	100 MLD STP at Hebbal	<b>Date</b>	
<b>Offer/PO Ref</b>	JEL/MK-CZ-101/KV/2017-18 Rev-1	09/Feb/18	
<b><u>Specified / Considered Data</u></b>			
Avg flow of the plant	62.50 MLD		
Peak Factor	2		
Peak flow per screen	125.00 MLD		
No of Working screen	1		
Avg flow per screen	62.50 MLD		
Peak flow per screen	125.00 MLD		
Channel width	1500 mm		
Channel depth	2550 mm		
Max. Water depth	1500 mm		
Avg Bar spacing	20 mm		
Bar Thickness	10 mm		
Inclination	75 °		
Material of Construction	AISI 316L		
<b><u>Screen Dimensions</u></b>			
Proposed Screen Model	<b>MS-2680-1480-20-M3-S1</b>		
Effective Width of Screen	1480 mm		
Inclined length of the screen ( Approx )	2680 mm		
No of Bars	50		
<b><u>Hydraulic Results</u></b>			
Head loss through the screen clogging at	50%	248 mm	

# **HYDRAULIC CALCULATION FOR LOSS THROUGH SCREEN**

## HYDRAULIC CALCULATION

Customer **M/s Enviro Control Associates (I) Pvt. Ltd.**

Date

Project **100 MLD STP at Hebbal****30 Dec /17****SPECIFIED / CONSIDERED VALUES**

Avg flow per screen	Qa=	<b>62.5</b>	MLD
		<b>0.723</b>	m3/sec
Peak flow per screen	Qp=	<b>125</b>	MLD
		<b>1.447</b>	m3/sec
Max.Water depth	WD=	<b>1500</b>	mm
Bar Spacing	BS=	<b>20</b>	mm
Bar Thickness	BT=	<b>10</b>	mm
Screen Inclination	$\theta$ =	<b>75</b>	°
Channel width	CW=	<b>1500</b>	mm
Clogging Factor	CF=	<b>50%</b>	
Headloss through clogged screen desired		<b>300</b>	mm

**HYDRAULIC CALCULATION**

Inside/ Screen field width of screen provided	IW=	<b>1480</b>	mm
Velocity in the channel at Avg flow	$V_a = Q_a / (CW \times WD)$	<b>0.32</b>	m/Sec
Velocity in the channel at Peak flow	$V_p = Q_p / (CW \times WD)$	<b>0.64</b>	m/Sec
Velocity through the screen at Peak flow	$V_{c1} = Q_p / (WD \times IW \times BS) / (BS + BT)$	<b>0.98</b>	m/Sec

**Head loss calculation as per Bernoulli Eqn.**

Head loss through the clean screen	$h_{L1} = \{1/Cx2gx(V_{c1}^2 - V_p^2)\}$	<b>39</b>	mm
------------------------------------	--	-----------	----

Where C=Coefficient of Discharge=0.7

g=Acceleration due to gravity=9.81

Velocity through the clogged screen at Peak flow at Clogging	<b>50%</b> $V_{c2} = V_{c1} / (1 - CF)$	<b>1.955</b>	m/Sec
--	---	--------------	-------

Head loss through the clogged screen	$h_{L2} = \{1/Cx2gx(V_{c2}^2 - V_p^2)\}$	<b>248</b>	mm
--------------------------------------	--	------------	----

Where C=Coefficient of Discharge=0.7

g=Acceleration due to gravity=9.81

**Head loss with in specified limits**


## **G.A. DRAWING OF SCREEN**





**QAP FOR SCREEN**

## QUALITY ASSURANCE PLAN FOR JASH “MANUAL SCREEN “

<b>MANUFACTURER</b>  	<b>: JASH ENGINEERING LIMITED UNIT-II</b> Survey no. 74 Gram Bardari Nr Sanwer Road, Tehsil Sanwer Indore (M.P.) INDIA	<b>CLIENT</b>	BANGALORE WATER SUPPLY AND SEWERAGE BOARD
		<b>CONTRACTOR</b>	M/s ENVIRO CONTROL ASSO. (I) PVT. LTD.
		<b>PROJECT</b>	100 MLD STP AT HEBBAL FOR BWSSB
		<b>G.A. DRG. NO.</b>	GA-B-MK2-2267004-00-R1
		<b>QAP NO. &amp; DTD.</b>	JEL/QAP/MS/'MK2- 2267 -R1 DTD. 09/02/2018

Sr. No.	Component & Operation	Characteristics	Reference Document	Quantum of Check	Acceptance norm	Format record	SCOPE	
							JASH	CLIENT / TPI

### (1) MATERIAL TESTS:


a)	Bottom Plate	Chemical Composition	Approved G.A. Drawing	One per Lot	Approved G.A. Drawing	Test Certificate	Review / Perform	Review
b)	Screen Bars	Chemical Composition				Test Certificate	Review / Perform	Review

### (2) SHOP TESTS :

a)	Dimensional Check	Dimensional	Approved G.A. Drawing	100%	Approved G.A. Drawing	JASH Inspection Report	Perform	Witness
----	-------------------	-------------	-----------------------	------	-----------------------	------------------------	---------	---------

#### NOTE : -

- 1) We do not undertake additional testing other than above stated tests.
- 2) TPI – Third party Inspection Agency.
- 3) PMI test shall be carried out for SS parts

		Clients Comments if Any:
Prepared By : JASH Engineering Ltd.	Approved By :	