

TIA-942-B Telecommunications Infrastructure Standard for Data Centers

Clause 5.3 Electrical Systems.

Clause 5.3.4 UPS Redundancy Requirement.

For Tier III and Tier IV data center configurations, uninterruptible power supply (UPS) systems must have at least N+1 redundancy to prevent outages during maintenance or component failure.

Clause 5.3.5 Battery Autonomy Requirement.

The minimum autonomy battery backup time for active data center loads is 15 minutes at full rated load under standard operating conditions.

Clause 5.4 Mechanical Systems and Temperature Range.

Clause 5.4.1 Operating Temperature.

Operating temperature in the computer room must be maintained between 18 degrees Celsius and 27 degrees Celsius. Relative humidity must be between 30% and 60%.